

BERINGOVSKY, Russian Federation

WMO: 256770

Lat: 63.026N

Lon: 179.295E

Elev: 15

StdP: 14.69

Time Zone: 12.00 (E12)

Period: 90-13

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-27.4	-23.5	-32.7	0.9	-26.7	-28.6	1.1	-23.0	54.9	8.8	48.7	1.7	7.7	260	1.027

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.7	64.8	56.1	61.6	54.5	58.4	52.9	57.4	63.1	55.2	60.4	53.2	57.8	14.3	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
54.4	63.0	60.7	52.1	57.8	58.0	50.4	54.2	55.4	24.7	63.5	23.4	60.6	22.1	58.0	64.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 45.4	40.3	35.4	DB	-30.5	71.9	9.0	5.0	-36.9	75.5	-42.2	78.4	-47.2	81.3	-53.8	84.9	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.4	-1.3	-4.2	0.6	15.5	30.5	43.1	50.8	49.9	40.9	29.1	18.0	6.3
	DBStd	21.72	12.47	13.46	12.24	11.31	6.10	6.01	5.90	4.29	6.20	7.09	11.56	14.51
	HDD50	9860	1590	1518	1531	1036	605	222	63	56	275	648	961	1355
	HDD65	15178	2055	1938	1996	1486	1070	656	441	469	723	1113	1411	1820
	CDD50	158	0	0	0	0	0	16	88	52	2	0	0	0
	CDD65	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDH74	2	0	0	0	0	0	0	2	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	15.0	18.2	16.6	16.1	14.6	11.7	11.1	11.5	12.4	14.0	15.2	18.2	20.4
Precipitation	PrecAvg	28.7	2.7	2.9	2.5	1.6	1.3	1.0	1.8	2.7	2.6	3.3	3.4	2.9
	PrecMax	40.6	5.2	7.5	7.7	4.5	3.0	2.4	4.7	4.9	4.9	10.1	6.7	5.2
	PrecMin	13.9	0.4	0.4	0.2	0.3	0.4	0.3	0.4	0.9	0.6	1.4	1.3	0.8
	PrecStd	6.2	1.3	1.7	1.7	0.9	0.7	0.5	1.1	1.1	1.2	2.0	1.4	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.6	31.5	32.2	36.1	45.1	65.2	71.1	68.0	55.6	43.8	39.3	35.0
		MCWB	32.8	30.0	30.9	33.1	40.2	55.0	59.6	56.7	49.6	41.5	38.2	32.4
	2%	DB	28.6	29.1	29.4	34.0	41.8	60.4	66.7	63.1	52.8	41.3	37.2	33.1
		MCWB	27.9	28.2	28.7	31.6	38.0	51.9	57.1	55.7	49.1	39.0	35.7	31.7
	5%	DB	22.5	24.1	25.5	32.3	39.4	56.2	63.0	59.8	50.9	39.6	34.8	31.2
		MCWB	21.5	23.1	24.7	30.4	36.4	49.5	55.5	53.9	48.3	37.4	33.1	30.0
	10%	DB	18.3	16.0	20.6	30.7	37.3	52.0	60.0	57.0	49.5	38.1	32.7	28.5
		MCWB	17.3	15.1	19.8	29.1	34.8	46.6	54.2	52.2	47.3	36.3	31.2	27.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	33.0	30.3	31.5	33.3	40.9	56.0	61.2	59.8	51.7	42.1	38.3	33.8
		MCDB	34.0	31.2	32.0	35.1	44.8	62.3	68.6	65.2	53.9	43.1	38.7	34.6
	2%	WB	28.1	28.1	28.8	31.9	38.2	52.5	58.6	56.4	49.9	39.6	35.8	32.1
		MCDB	28.8	29.1	29.6	33.8	41.3	60.1	64.7	61.7	51.3	41.1	36.8	33.1
	5%	WB	22.1	23.1	24.9	30.8	36.7	49.7	56.4	54.2	48.9	37.8	33.5	30.1
		MCDB	22.8	24.0	25.9	32.4	39.2	55.5	61.8	59.1	50.5	38.9	34.6	31.2
	10%	WB	17.8	15.2	20.3	29.4	35.0	47.2	54.5	52.4	47.6	36.5	31.3	27.4
		MCDB	18.8	16.1	21.2	30.9	37.0	51.5	59.3	56.4	49.3	37.9	32.6	28.8
Mean Daily Temperature Range		MDBR	9.2	9.3	10.5	10.6	6.7	9.9	9.7	8.9	7.2	7.4	9.7	10.1
	5% DB	MCDBR	13.4	14.2	10.8	7.8	10.0	17.5	16.4	15.2	9.6	8.4	8.0	11.4
		MCWBR	11.8	14.2	10.3	6.8	7.5	11.5	10.2	10.5	7.0	8.0	7.6	10.5
	5% WB	MCDBR	11.4	14.2	11.2	7.1	9.5	16.0	14.5	14.2	7.1	7.5	6.9	9.9
		MCWBR	11.7	14.2	10.9	6.5	7.4	11.0	9.8	10.4	5.8	7.6	6.9	10.2
Clear-Sky Solar Irradiance	taub	0.205	0.264	0.310	0.361	0.408	0.385	0.447	0.416	0.343	0.313	0.247	0.212	
	taud	1.982	2.085	2.035	1.935	1.973	2.316	2.147	2.218	2.415	2.246	2.006	1.926	
	Ebn at Noon	137	211	243	253	252	265	241	237	238	190	108	61	
	Edh at Noon	10	21	34	47	49	36	42	36	24	19	10	5	
All-Sky Solar Radiation	RadAvg	66	298	837	1474	1693	1698	1503	1093	689	272	77	27	
	RadStd	10	44	90	106	204	131	159	134	82	51	16	3	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page