

BERINGOVSKY, Russian Federation

WMO: 256770

Lat: 63.026N

Lon: 179.295E

Elev: 5

StdP: 101.27

Time Zone: 12.00 (E12)

Period: 90-13

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-33.0	-30.9	-36.0	0.1	-32.6	-33.7	0.2	-30.6	24.6	-12.9	21.8	-16.8	3.4	260	1.027

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.4	18.2	13.4	16.4	12.5	14.7	11.6	14.1	17.3	12.9	15.8	11.8	14.3	6.4	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.4	9.0	16.0	11.2	8.3	14.4	10.2	7.7	13.0	39.7	17.5	36.5	15.9	33.6	14.5	18.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.3	18.0	15.8	DB	-34.7	22.2	5.0	2.8	-38.3	24.2	-41.2	25.8	-44.0	27.4	-47.6	29.4	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-4.8	-18.5	-20.1	-17.4	-9.2	-0.8	6.2	10.5	9.9	4.9	-1.6	-7.8	-14.3	(6)	
	DBStd	12.07	6.93	7.48	6.80	6.28	3.39	3.34	3.28	2.38	3.45	3.94	6.42	8.06	(7)	
	HDD10.0	5478	883	843	851	576	336	123	35	31	153	360	534	753	(8)	
	HDD18.3	8432	1142	1077	1109	826	594	364	245	261	402	618	784	1011	(9)	
	CDD10.0	88	0	0	0	0	0	9	49	29	1	0	0	0	(10)	
	CDD18.3	1	0	0	0	0	0	0	1	0	0	0	0	0	(11)	
	CDH23.3	1	0	0	0	0	0	0	1	0	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	6.7	8.1	7.4	7.2	6.5	5.2	5.0	5.2	5.5	6.3	6.8	8.2	9.1	(14)	
(15) Precipitation	PrecAvg	730	69	73	63	40	34	26	46	69	67	85	86	73	(15)	
	PrecMax	1030	132	190	195	114	75	62	120	125	124	256	170	133	(16)	
	PrecMin	352	9	9	6	8	10	7	9	24	14	36	34	21	(17)	
	PrecStd	158	33	42	44	23	17	12	27	27	31	50	35	33	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.9	-0.3	0.1	2.3	7.3	18.4	21.7	20.0	13.1	6.6	4.1	1.7	(19)	
		MCWB	0.4	-1.1	-0.6	0.6	4.6	12.8	15.3	13.7	9.8	5.3	3.5	0.2	(20)	
	2%	DB	-1.9	-1.6	-1.4	1.1	5.5	15.8	19.3	17.3	11.5	5.2	2.9	0.6	(21)	
		MCWB	-2.3	-2.1	-1.8	-0.2	3.3	11.1	13.9	13.2	9.5	3.9	2.1	-0.2	(22)	
	5%	DB	-5.3	-4.4	-3.6	0.2	4.1	13.5	17.2	15.5	10.5	4.2	1.5	-0.5	(23)	
		MCWB	-5.8	-5.0	-4.1	-0.9	2.4	9.7	13.0	12.2	9.0	3.0	0.6	-1.1	(24)	
	10%	DB	-7.6	-8.9	-6.3	-0.7	3.0	11.1	15.5	13.9	9.7	3.4	0.4	-1.9	(25)	
		MCWB	-8.1	-9.4	-6.8	-1.6	1.5	8.1	12.3	11.2	8.5	2.4	-0.5	-2.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.6	-1.0	-0.3	0.7	4.9	13.3	16.2	15.4	10.9	5.6	3.5	1.0	(27)	
		MCDB	1.1	-0.5	0.0	1.7	7.1	16.8	20.3	18.4	12.2	6.2	3.7	1.4	(28)	
	2%	WB	-2.1	-2.2	-1.8	0.0	3.5	11.4	14.8	13.6	10.0	4.2	2.1	0.1	(29)	
		MCDB	-1.8	-1.6	-1.3	1.0	5.2	15.6	18.2	16.5	10.7	5.0	2.7	0.6	(30)	
	5%	WB	-5.5	-5.0	-3.9	-0.7	2.6	9.8	13.5	12.4	9.4	3.2	0.8	-1.1	(31)	
		MCDB	-5.1	-4.4	-3.4	0.2	4.0	13.0	16.6	15.1	10.3	3.9	1.5	-0.4	(32)	
	10%	WB	-7.9	-9.3	-6.5	-1.4	1.7	8.4	12.5	11.4	8.7	2.5	-0.4	-2.5	(33)	
		MCDB	-7.4	-8.8	-6.0	-0.6	2.8	10.8	15.2	13.5	9.6	3.3	0.3	-1.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.1	5.1	5.8	5.9	3.7	5.5	5.4	4.9	4.0	4.1	5.4	5.6	(35)	
		MCDBR	7.4	7.9	6.0	4.3	5.6	9.7	9.1	8.4	5.3	4.6	4.5	6.3	(36)	
	5% WB	MCWBR	6.6	7.9	5.7	3.8	4.1	6.4	5.6	5.8	3.9	4.5	4.2	5.8	(37)	
		MCWBR	6.3	7.9	6.2	3.9	5.3	8.9	8.1	7.9	3.9	4.2	3.8	5.5	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.205	0.264	0.310	0.361	0.408	0.385	0.447	0.416	0.343	0.313	0.247	0.212	(40)	
		taud	1.982	2.085	2.035	1.935	1.973	2.316	2.147	2.218	2.415	2.246	2.006	1.926	(41)	
	Edn at Noon		432	666	767	799	794	834	759	748	751	600	342	192	(42)	
		Edh at Noon	32	67	106	147	155	113	131	112	75	59	31	17	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.21	0.94	2.64	4.65	5.34	5.35	4.74	3.45	2.17	0.86	0.24	0.09	(44)	
	RadStd		0.03	0.14	0.28	0.33	0.64	0.41	0.50	0.42	0.26	0.16	0.05	0.01	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page