

EVENSK, Russian Federation

WMO: 258200

Lat: 61.917N

Lon: 159.217E

Elev: 39

StdP: 14.68

Time Zone: 11.00 (E11)

Period: 90-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -24.7	(c) -21.6	(d) -33.2	(e) 0.8	(f) -24.3	(g) -29.8	(h) 1.0	(i) -21.0	(j) 31.0	(k) 5.0	(l) 28.7	(m) -4.4	(n) 7.2	(o) 10	(p) 0.817

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.0	68.8	57.7	65.3	56.2	62.4	55.1	59.3	65.6	57.6	63.3	56.2	61.2	6.7	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.5	68.1	61.3	54.8	64.1	59.5	53.4	60.7	58.0	26.0	66.0	24.9	63.8	23.9	61.2	68.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 27.9	(b) 24.4	(c) 21.3	(e) -28.8	(f) 77.3	(g) 2.6	(h) 4.8	(i) -30.6	(j) 80.8	(k) -32.1	(l) 83.6	(m) -33.6	(n) 86.3	(o) -35.5	(p) 89.8		
(a) 27.9	(b) 24.4	(c) 21.3	(e) -29.0	(f) 63.5	(g) 2.5	(h) 2.3	(i) -30.9	(j) 65.1	(k) -32.4	(l) 66.5	(m) -33.8	(n) 67.7	(o) -35.6	(p) 69.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	26.2	1.1	2.3	8.4	23.3	36.3	48.0	53.7	53.1	43.4	28.4	13.0	1.6		
	DBStd	21.80	13.22	13.52	11.29	8.28	5.59	5.18	4.18	4.44	6.21	8.34	11.83	12.30		
	HDD50	8984	1515	1336	1290	802	426	97	8	21	210	669	1109	1501		
	HDD65	14172	1980	1756	1755	1252	890	510	352	369	649	1134	1559	1966		
	CDD50	287	0	0	0	0	0	37	122	117	11	0	0	0		
	CDD65	1	0	0	0	0	0	0	1	0	0	0	0	0		
	CDH74	18	0	0	0	0	0	1	16	1	0	0	0	0		
	CDH80	6	0	0	0	0	0	0	6	0	0	0	0	0		
	WSAvg	8.5	11.3	9.9	10.7	8.2	6.5	6.2	5.8	6.3	7.2	8.2	11.9	10.2		
	PrecAvg	24.5	1.5	1.4	1.3	1.2	1.2	1.7	2.4	3.5	2.8	2.8	2.7	2.2		
(15) Precipitation	PrecMax	36.3	3.7	2.8	2.6	3.9	2.5	3.5	4.1	7.3	7.5	5.4	9.3	6.1		
	PrecMin	14.0	0.1	0.2	0.2	0.1	0.3	0.6	0.3	0.7	0.9	1.1	0.8	0.4		
	PrecStd	5.3	0.7	0.7	0.7	0.7	0.6	0.9	0.9	1.8	1.7	1.0	1.7	1.4		
	PrecStd	5.3	0.7	0.7	0.7	0.7	0.6	0.9	0.9	1.8	1.7	1.0	1.7	1.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.6	36.9	33.7	43.1	59.8	70.8	75.2	70.7	64.1	48.1	37.2	32.6		
		MCWB	33.0	34.9	30.2	35.7	48.0	55.4	60.9	59.8	53.6	41.5	34.4	30.1		
	2%	DB	30.2	31.1	30.4	39.8	51.9	64.9	70.1	67.1	58.0	45.3	34.8	28.1		
		MCWB	28.5	28.4	27.8	34.0	43.1	53.4	58.8	57.5	50.2	39.7	32.7	27.3		
	5%	DB	25.5	26.6	28.1	36.4	48.4	61.2	66.1	64.4	55.6	42.8	33.0	23.6		
		MCWB	23.8	24.3	25.9	32.5	41.4	52.4	56.9	56.4	48.5	38.7	31.1	21.7		
	10%	DB	20.0	21.7	25.1	34.3	45.5	58.6	62.7	61.9	53.1	40.0	30.6	18.8		
		MCWB	17.9	19.6	22.9	31.2	39.7	50.8	55.8	55.7	48.4	36.3	28.8	16.9		
	0.4%	WB	33.7	34.7	30.5	36.8	48.3	57.3	62.8	61.8	55.3	43.6	34.8	30.2		
		MCDB	35.5	36.8	33.4	41.9	59.0	66.0	74.4	67.3	62.6	45.9	36.7	31.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	28.5	28.7	28.1	34.6	44.7	55.2	59.9	59.2	52.2	41.2	33.2	26.8		
		MCDB	30.0	30.9	30.1	38.1	50.7	63.1	67.7	63.9	55.5	44.6	34.6	28.0		
	5%	WB	23.8	24.1	26.2	33.2	41.9	53.3	58.2	57.7	50.8	38.8	31.3	21.8		
		MCDB	25.5	26.3	28.0	36.0	47.2	60.1	64.7	62.8	54.2	41.7	32.8	23.4		
	10%	WB	17.9	19.3	23.1	31.4	40.1	51.5	56.5	56.4	49.2	36.7	28.8	17.0		
		MCDB	19.9	21.6	25.0	33.9	44.7	57.1	61.7	61.1	52.4	39.7	30.5	18.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.6	11.0	12.2	12.4	11.5	12.9	11.0	13.2	13.7	11.4	10.6	9.8		
		MCDBR	8.9	7.6	9.7	11.8	17.7	21.4	20.8	19.2	18.2	11.8	8.9	11.0		
		MCWBR	8.9	6.6	8.2	8.5	10.6	12.0	11.7	10.9	11.5	8.2	8.2	10.8		
		MCDBR	8.8	8.1	8.4	9.8	15.9	19.2	18.4	15.6	13.8	9.7	8.5	11.7		
	5% WB	MCWBR	8.8	7.4	7.3	7.5	9.9	11.6	11.2	10.0	9.6	7.8	8.2	11.4		
		MCWBR	8.8	7.4	7.3	7.5	9.9	11.6	11.2	10.0	9.6	7.8	8.2	11.4		
(40) Clear-Sky Solar Irradiance	taub		0.209	0.264	0.327	0.400	0.441	0.409	0.467	0.437	0.337	0.304	0.236	0.190		
	taud		2.027	2.111	2.009	1.865	1.903	2.246	2.110	2.173	2.458	2.264	2.046	1.928		
	Ebn at Noon		157	220	240	242	243	258	236	233	246	203	136	98		
	Edh at Noon		11	22	36	51	54	39	43	38	23	19	11	7		
(44) All-Sky Solar Radiation	RadAvg		98	365	876	1463	1663	1610	1489	1133	751	377	120	42		
	RadStd		12	27	63	115	166	157	148	140	82	49	17	5		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page