

KORF, Russian FederationWMO: **259540**Lat: **60.376N**Lon: **166.024E**Elev: **12**StdP: **14.69**Time Zone: **12.00 (E12)**Period: **94-12**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.3	-14.6	-26.6	1.3	-17.4	-23.3	1.5	-14.0	29.5	19.7	26.5	16.2	10.4	350	0.817

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.7	67.5	57.2	64.0	56.1	61.1	54.9	59.0	64.3	57.4	62.2	55.8	59.9	9.9	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
56.7	68.6	60.7	55.0	64.4	59.0	53.7	61.3	57.6	25.8	64.6	24.7	62.5	23.7	60.3	64.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.1	21.9	19.3	-22.6	76.0	3.8	3.1	-25.4	78.3	-27.6	80.1	-29.8	81.9	-32.6	84.2		
(5)			-22.8	61.5	3.7	1.7	-25.4	62.7	-27.6	63.7	-29.6	64.6	-32.3	65.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	28.8	5.1	5.1	13.4	21.6	36.0	47.7	55.3	54.9	47.2	31.9	17.6	8.6
	DBStd	20.67	13.79	12.46	12.25	8.78	4.95	5.03	4.62	3.68	5.13	8.36	11.55	12.94
	HDD50	8107	1392	1257	1133	852	433	101	6	7	110	561	973	1282
	HDD65	13196	1857	1677	1598	1302	898	518	302	314	534	1026	1423	1747
	CDD50	387	0	0	0	0	0	33	171	158	25	0	0	0
	CDD65	2	0	0	0	0	0	0	2	0	0	0	0	0
	CDH74	14	0	0	0	0	0	0	12	2	0	0	0	0
	CDH80	1	0	0	0	0	0	0	1	0	0	0	0	0
Wind	WSAvg	9.3	11.4	12.3	10.6	9.2	7.0	7.6	7.2	7.4	8.0	8.8	10.9	11.7
Precipitation	PrecAvg	16.8	1.1	0.9	0.9	0.8	0.9	1.2	2.0	2.4	2.1	1.9	1.7	0.9
	PrecMax	24.9	3.2	3.5	3.5	3.9	3.4	2.6	6.1	5.9	4.7	4.3	5.7	3.5
	PrecMin	11.9	0.0	0.0	0.1	0.0	0.1	0.2	0.2	0.0	0.2	0.0	0.0	0.0
	PrecStd	3.3	0.8	0.7	0.7	0.7	0.7	0.6	1.2	1.2	1.3	1.0	1.2	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.5	33.0	34.2	38.5	54.8	68.5	75.1	71.1	59.7	48.3	41.5	35.2
		MCWB	32.6	30.9	32.1	34.7	45.1	55.7	60.0	59.1	51.8	45.1	38.9	33.3
	2%	DB	32.4	31.4	32.9	35.3	49.7	62.3	69.3	65.2	57.3	45.4	38.7	33.3
		MCWB	30.9	29.8	31.2	32.1	43.0	52.1	58.0	56.4	51.1	42.2	36.6	31.7
	5%	DB	30.2	29.7	31.6	33.9	46.0	58.4	65.7	62.3	55.7	43.8	36.6	31.2
		MCWB	28.5	28.2	30.0	31.4	40.7	50.7	57.0	55.5	51.3	40.8	34.9	29.6
	10%	DB	26.9	26.1	30.2	32.6	43.2	55.2	62.7	59.9	54.3	42.1	34.3	28.9
		MCWB	25.0	24.5	28.6	30.6	39.0	49.8	56.1	55.0	50.5	39.2	32.6	27.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	33.1	32.0	33.2	35.0	46.3	56.6	62.1	60.3	54.8	46.1	39.4	33.9
		MCDB	34.1	32.4	33.6	37.9	53.4	65.9	70.1	65.3	56.7	48.1	41.2	34.7
	2%	WB	31.3	30.0	31.6	32.9	43.5	53.7	59.8	58.7	53.5	43.2	37.1	32.1
		MCDB	32.3	31.0	32.5	34.6	49.3	59.9	66.4	62.6	55.4	44.9	38.4	33.3
	5%	WB	28.4	27.9	30.3	31.8	41.2	51.9	58.3	57.0	52.3	41.3	35.1	29.8
		MCDB	29.9	29.5	31.6	33.4	45.5	56.7	63.9	60.7	54.6	43.1	36.4	31.1
	10%	WB	25.2	24.2	28.6	30.8	39.3	50.2	56.7	55.7	51.0	39.5	32.7	27.0
		MCDB	26.8	26.2	30.2	32.5	42.8	54.5	61.6	58.9	53.7	41.7	34.2	28.8
Mean Daily Temperature Range	5% DB	MDBR	9.5	9.9	10.2	10.7	8.8	8.2	8.7	8.1	8.4	8.4	9.0	9.2
		MCDBR	10.2	10.6	7.4	8.5	14.3	15.2	15.5	13.1	10.0	8.8	7.7	10.5
		MCWBR	10.0	10.4	7.0	7.0	8.7	8.4	8.0	6.8	6.3	6.8	7.3	10.3
	5% WB	MCDBR	9.3	9.8	7.6	7.2	13.5	12.1	13.2	10.4	7.4	7.5	8.0	9.7
		MCWBR	9.2	9.9	7.4	6.2	8.5	7.4	7.5	6.0	5.7	6.7	7.9	9.8
Clear-Sky Solar Irradiance	taub	0.232	0.280	0.336	0.393	0.442	0.411	0.441	0.429	0.341	0.315	0.261	0.215	
	taud	2.074	2.124	2.016	1.898	1.924	2.236	2.180	2.189	2.448	2.305	2.092	1.981	
	Ebn at Noon	168	223	242	248	246	259	246	238	248	210	148	118	
	Edh at Noon	13	23	37	50	53	40	41	38	24	20	13	9	
All-Sky Solar Radiation	RadAvg	118	370	854	1460	1607	1548	1542	1134	767	406	137	54	
	RadStd	18	43	126	110	170	206	169	116	82	42	22	5	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page