

KORF, Russian FederationWMO: **259540**Lat: **60.376N**Lon: **166.024E**Elev: **4**StdP: **101.28**Time Zone: **12.00 (E12)**Period: **94-12**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-27.9	-25.9	-32.6	0.2	-27.4	-30.7	0.2	-25.6	13.2	-6.9	11.8	-8.8	4.7	350	0.817

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.8	19.7	14.0	17.8	13.4	16.1	12.7	15.0	18.0	14.1	16.8	13.2	15.5	4.4	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.7	9.8	15.9	12.8	9.2	15.0	12.1	8.8	14.2	42.1	18.1	39.7	17.0	37.3	15.7	18.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.2	9.8	8.6	-30.3	24.5	2.1	1.7	-31.9	25.7	-33.1	26.7	-34.3	27.7	-35.9	29.0		
(5)			-30.4	16.4	2.0	0.9	-31.9	17.1	-33.1	17.6	-34.2	18.1	-35.7	18.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-1.8	-14.9	-14.9	-10.3	-5.8	2.2	8.7	12.9	12.7	8.4	-0.1	-8.0	-13.0
	DBStd	11.49	7.66	6.92	6.81	4.88	2.75	2.79	2.57	2.04	2.85	4.64	6.41	7.19
	HDD10.0	4504	773	698	629	473	241	56	3	4	61	312	541	712
	HDD18.3	7331	1032	932	888	723	499	288	168	174	297	570	791	971
	CDD10.0	215	0	0	0	0	0	18	95	88	14	0	0	0
	CDD18.3	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDH23.3	8	0	0	0	0	0	0	7	1	0	0	0	0
	CDH26.7	1	0	0	0	0	0	0	1	0	0	0	0	0
Wind	WSAvg	4.2	5.1	5.5	4.7	4.1	3.1	3.4	3.2	3.3	3.6	4.0	4.9	5.2
Precipitation	PrecAvg	426	27	23	24	21	24	30	50	62	53	49	44	24
	PrecMax	632	82	88	88	98	86	67	155	149	119	110	146	89
	PrecMin	301	0	0	2	0	3	6	5	1	4	0	0	1
	PrecStd	83	20	18	19	18	18	16	31	31	32	26	30	21
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	1.4	0.6	1.2	3.6	12.7	20.3	23.9	21.7	15.4	9.1	5.3	1.8
		MCWB	0.3	-0.6	0.0	1.5	7.3	13.1	15.6	15.1	11.0	7.3	3.8	0.7
	2%	DB	0.2	-0.3	0.5	1.9	9.8	16.8	20.7	18.4	14.1	7.4	3.7	0.7
		MCWB	-0.6	-1.2	-0.5	0.1	6.1	11.1	14.4	13.6	10.6	5.7	2.5	-0.2
	5%	DB	-1.0	-1.3	-0.2	1.1	7.8	14.6	18.7	16.8	13.2	6.6	2.6	-0.4
		MCWB	-2.0	-2.1	-1.1	-0.3	4.9	10.4	13.9	13.0	10.7	4.9	1.6	-1.3
	10%	DB	-2.8	-3.3	-1.0	0.3	6.2	12.9	17.1	15.5	12.4	5.6	1.3	-1.7
		MCWB	-3.9	-4.2	-1.9	-0.8	3.9	9.9	13.4	12.8	10.3	4.0	0.3	-2.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.6	0.0	0.6	1.7	7.9	13.7	16.7	15.7	12.7	7.9	4.1	1.0
		MCDB	1.2	0.2	0.9	3.3	11.9	18.8	21.2	18.5	13.7	8.9	5.1	1.5
	2%	WB	-0.4	-1.1	-0.2	0.5	6.4	12.1	15.4	14.8	12.0	6.2	2.8	0.0
		MCDB	0.2	-0.6	0.3	1.4	9.6	15.5	19.1	17.0	13.0	7.2	3.5	0.7
	5%	WB	-2.0	-2.3	-1.0	-0.1	5.1	11.0	14.6	13.9	11.3	5.2	1.7	-1.2
		MCDB	-1.2	-1.4	-0.2	0.8	7.5	13.7	17.7	15.9	12.6	6.2	2.4	-0.5
	10%	WB	-3.8	-4.3	-1.9	-0.7	4.1	10.1	13.7	13.2	10.6	4.2	0.4	-2.8
		MCDB	-2.9	-3.2	-1.0	0.3	6.0	12.5	16.5	14.9	12.1	5.4	1.2	-1.8
Mean Daily Temperature Range	5% DB	MDBR	5.3	5.5	5.7	5.9	4.9	4.6	4.8	4.5	4.7	4.7	5.0	5.1
		MCDBR	5.7	5.9	4.1	4.7	7.9	8.5	8.6	7.3	5.5	4.9	4.3	5.8
		MCWBR	5.6	5.8	3.9	3.9	4.8	4.6	4.4	3.8	3.5	3.8	4.1	5.7
	5% WB	MCDBR	5.1	5.4	4.2	4.0	7.5	6.7	7.3	5.8	4.1	4.2	4.4	5.4
		MCWBR	5.1	5.5	4.1	3.4	4.7	4.1	4.2	3.4	3.1	3.7	4.4	5.4
Clear-Sky Solar Irradiance	taub	0.232	0.280	0.336	0.393	0.442	0.411	0.441	0.429	0.341	0.315	0.261	0.215	
	taud	2.074	2.124	2.016	1.898	1.924	2.236	2.180	2.189	2.448	2.305	2.092	1.981	
	Ebn at Noon	529	704	762	783	774	817	777	751	782	661	467	373	
	Edh at Noon	42	74	116	159	167	125	130	119	77	63	41	29	
All-Sky Solar Radiation	RadAvg	0.37	1.17	2.69	4.60	5.07	4.88	4.86	3.58	2.42	1.28	0.43	0.17	
	RadStd	0.06	0.14	0.40	0.35	0.54	0.65	0.53	0.37	0.26	0.13	0.07	0.02	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page