

TALLINN, Estonia

WMO: 260380

Lat: 59.3981N

Lon: 24.6028E

Elev: 34

StdP: 100.91

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-18.5	-15.1	-21.0	0.6	-17.9	-18.0	0.8	-14.5	10.2	-0.8	9.2	-0.7	2.3	130	0.617

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.0	26.9	19.4	25.0	18.2	23.1	17.2	20.4	24.9	19.2	23.4	18.2	22.0	3.8	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.8	13.7	22.5	17.8	12.8	21.3	16.6	11.9	20.1	58.4	25.0	54.7	23.2	51.4	22.0	24.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.0	8.0	7.1	-22.1	29.3	4.9	2.1	-25.6	30.8	-28.4	32.0	-31.1	33.2	-34.7	34.7		
(5)			-22.3	21.9	4.7	1.1	-25.7	22.7	-28.5	23.3	-31.1	23.9	-34.6	24.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	6.1	-3.8	-4.2	-1.0	4.8	9.9	14.2	17.5	16.3	12.0	6.4	1.9	-1.3	(6)
(7)		DBStd	8.53	5.46	5.69	4.29	3.81	3.98	3.02	2.88	2.83	3.13	3.71	3.94	4.99	(7)
(8)		HDD10.0	2111	427	398	342	162	51	2	0	0	17	120	243	349	(8)
(9)		HDD18.3	4506	685	631	601	406	264	129	51	76	192	370	492	608	(9)
(10)		CDD10.0	691	0	0	0	6	47	128	232	196	75	8	0	0	(10)
(11)		CDD18.3	45	0	0	0	0	2	5	24	13	1	0	0	0	(11)
(12)		CDH23.3	364	0	0	0	1	19	52	199	91	3	0	0	0	(12)
(13)		CDH26.7	61	0	0	0	0	3	7	38	14	0	0	0	0	(13)
(14)	Wind	WSAvg	3.4	3.7	3.6	3.6	3.5	3.4	3.3	3.0	2.9	3.2	3.4	3.7	3.9	(14)
(15)	Precipitation	PrecAvg	668	54	39	35	34	36	61	77	79	55	73	66	57	(15)
(16)		PrecMax	941	100	103	69	90	92	121	231	154	131	138	125	121	(16)
(17)		PrecMin	460	7	4	6	3	5	12	1	10	22	12	5	15	(17)
(18)		PrecStd	103	23	22	17	22	20	27	46	41	28	30	28	24	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.9	5.9	12.2	20.6	25.7	27.7	30.1	28.8	23.1	16.0	10.3	8.9	(19)
(20)			MCWB	5.6	4.6	6.0	11.8	17.0	18.9	20.8	19.5	16.2	12.8	9.3	7.8	(20)
(21)		2%	DB	4.2	4.2	8.0	16.8	22.2	24.8	27.4	25.8	20.3	14.0	9.2	7.1	(21)
(22)			MCWB	3.7	3.3	4.7	10.2	14.6	17.6	19.7	18.9	15.6	12.1	8.5	6.4	(22)
(23)		5%	DB	3.2	3.2	5.8	14.0	19.7	22.2	25.6	23.8	18.5	12.8	8.2	5.9	(23)
(24)			MCWB	2.7	2.5	3.3	8.2	13.3	16.0	18.9	17.8	14.8	11.3	7.5	5.3	(24)
(25)		10%	DB	2.2	2.3	4.0	11.8	17.3	20.3	23.8	22.0	17.0	11.7	7.2	4.8	(25)
(26)			MCWB	1.8	1.7	2.4	7.4	11.7	14.8	18.0	17.0	14.1	10.4	6.5	4.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.4	4.7	6.9	12.6	18.6	20.4	22.1	21.3	17.5	13.6	9.7	7.9	(27)
(28)			MCDWB	5.6	5.2	10.3	18.1	23.7	24.9	27.8	25.7	20.8	14.9	10.0	8.4	(28)
(29)		2%	WB	3.8	3.5	5.0	10.6	16.0	18.7	20.8	19.6	16.3	12.6	8.6	6.5	(29)
(30)			MCDWB	4.1	4.0	7.4	15.6	20.5	23.2	25.7	23.8	19.0	13.7	9.0	6.9	(30)
(31)		5%	WB	2.7	2.6	3.7	9.1	14.1	17.2	19.7	18.6	15.4	11.6	7.7	5.2	(31)
(32)			MCDWB	3.0	3.1	5.1	13.2	18.2	20.8	24.0	22.4	17.8	12.7	8.1	5.6	(32)
(33)		10%	WB	1.9	1.7	2.6	7.6	12.4	15.7	18.6	17.6	14.5	10.6	6.6	4.0	(33)
(34)			MCDWB	2.2	2.2	3.7	10.9	16.5	19.4	22.6	21.2	16.6	11.5	7.1	4.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.7	5.3	6.8	8.8	9.9	9.1	9.0	8.9	7.8	5.7	4.0	4.2	(35)
(36)			MCDBR	4.0	4.8	8.9	13.3	13.8	12.9	12.2	11.7	10.0	6.7	4.6	3.8	(36)
(37)			MCWBR	3.9	4.3	6.0	7.6	7.5	6.7	6.0	5.9	6.0	4.8	4.3	3.7	(37)
(38)		5% WB	MCDWR	3.9	4.4	7.4	12.2	11.7	11.1	10.9	10.1	8.6	6.0	4.3	3.7	(38)
(39)			MCWBR	3.9	4.2	5.4	7.6	7.2	6.6	5.8	5.8	5.7	4.8	4.3	3.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.277	0.309	0.332	0.366	0.362	0.360	0.385	0.380	0.350	0.334	0.311	0.266	(40)	
(41)		taud	2.140	2.182	2.238	2.320	2.403	2.456	2.409	2.422	2.494	2.406	2.220	2.098	(41)	
(42)		Ebn at Noon	505	688	796	835	868	874	839	814	784	668	460	372	(42)	
(43)		Edh at Noon	46	75	96	106	105	101	104	96	76	61	44	33	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.26	0.83	2.33	3.89	5.44	5.66	5.41	4.25	2.59	1.12	0.31	0.16	(44)	
(45)		RadStd	0.04	0.13	0.30	0.42	0.58	0.41	0.47	0.42	0.33	0.15	0.05	0.02	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.45	N/A	N/A	N/A	N/A	N/A	-152	-178	N/A	N/A
(47) Regional (59 neighbors)		+0.40	N/A	N/A	N/A	N/A	N/A	-136	N/A	N/A	N/A

Nomenclature: See separate page