

JOHVI, Estonia

WMO: 260460

Lat: 59.3289N

Lon: 27.3983E

Elev: 244

StdP: 14.57

Time Zone: 2.00 (EUE)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.7	-1.3	-11.8	2.9	-7.6	-5.6	4.1	-0.4	25.6	28.3	23.9	29.6	4.5	180	0.620

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.4	80.9	66.7	77.3	64.7	74.1	63.3	68.6	77.3	66.7	74.8	64.8	72.1	8.2	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.5	94.9	72.5	63.7	89.0	70.8	61.7	82.8	68.6	32.9	77.2	31.4	75.1	29.9	71.9	74.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.3	18.8	17.0	-13.4	84.4	9.6	3.8	-20.3	87.1	-25.9	89.3	-31.3	91.4	-38.2	94.1
			-14.1	70.9	9.6	1.9	-21.0	72.3	-26.7	73.4	-32.0	74.5	-39.0	75.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	41.7	21.8	22.0	28.5	39.5	50.9	57.1	63.3	60.7	52.4	41.5	33.8	27.9
	DBStd	16.44	11.77	11.18	8.77	6.80	7.65	5.89	5.82	5.49	5.30	7.11	7.16	9.66
	HDD50	4209	875	784	665	320	78	8	0	1	35	272	485	686
	HDD65	8575	1340	1204	1130	764	440	246	104	156	377	728	935	1151
	CDD50	1200	0	0	0	7	107	223	411	334	109	9	0	0
	CDD65	89	0	0	0	0	4	10	51	24	0	0	0	0
	CDH74	746	0	0	0	0	43	96	412	194	1	0	0	0
	CDH80	136	0	0	0	0	6	8	81	41	0	0	0	0
Wind	WSAvg	8.0	9.2	9.1	8.7	7.8	7.1	7.1	6.2	6.6	7.1	8.2	9.3	10.2
Precipitation	PrecAvg	27.0	1.8	1.3	1.4	1.2	2.0	3.1	2.9	3.5	2.5	2.9	2.5	1.8
	PrecMax	36.3	3.8	3.3	2.7	2.8	4.2	5.7	6.3	8.9	5.7	5.9	5.1	3.1
	PrecMin	15.7	0.7	0.3	0.4	0.2	0.1	0.7	0.6	0.4	0.5	0.7	0.4	0.4
	PrecStd	4.8	0.7	0.6	0.7	0.6	1.1	1.4	1.5	2.1	1.2	1.3	0.9	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.5	40.7	53.7	67.1	78.4	81.2	86.3	84.5	71.1	58.7	48.9	47.4
		MCWB	40.5	38.1	42.1	51.4	62.3	66.5	69.2	66.6	61.2	53.9	47.1	45.5
	2%	DB	38.4	38.2	46.3	61.5	73.6	76.8	82.1	79.0	67.0	55.7	46.7	43.7
		MCWB	37.3	36.6	39.8	48.2	59.9	63.0	67.8	65.3	59.3	53.1	45.3	42.1
	5%	DB	36.4	36.2	41.8	56.7	69.0	72.8	78.5	74.8	64.1	53.6	45.0	40.6
		MCWB	35.5	35.0	37.5	46.0	57.1	61.2	66.7	64.0	57.6	51.5	43.8	39.2
	10%	DB	34.7	34.4	38.7	52.1	65.0	69.1	75.2	71.6	61.6	51.4	43.1	38.2
		MCWB	34.0	33.6	35.6	43.6	54.7	59.2	64.8	62.4	56.4	49.6	42.0	37.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	40.5	39.2	44.7	52.8	66.3	68.4	71.5	70.2	62.5	55.6	47.6	45.9
		MCDB	41.4	40.1	50.8	63.2	76.2	76.0	81.5	78.8	68.5	57.2	48.4	47.1
	2%	WB	37.5	36.7	40.4	49.7	62.3	65.4	69.4	67.0	60.6	53.6	45.7	42.3
		MCDB	38.1	37.7	45.1	59.1	69.7	73.7	79.1	75.0	65.4	55.4	46.6	43.6
	5%	WB	35.6	35.1	37.9	47.1	59.1	62.9	67.8	65.2	58.7	51.7	44.0	39.4
		MCDB	36.2	35.9	41.1	54.8	66.6	70.8	76.3	72.4	62.8	53.3	44.9	40.5
	10%	WB	34.0	33.6	36.1	44.5	55.9	60.2	66.1	63.6	57.0	49.9	42.1	37.1
		MCDB	34.6	34.3	38.2	51.3	63.7	67.2	73.9	70.2	60.8	51.3	43.0	37.9
Mean Daily Temperature Range	5% DB	MDBR	8.4	8.9	11.7	15.9	18.5	16.8	16.4	16.5	13.4	9.7	6.5	6.7
		MCDBR	6.1	7.5	15.7	24.3	23.5	22.6	21.1	21.8	18.1	12.0	7.4	7.2
		MCWBR	6.0	6.7	10.4	13.8	12.5	11.4	9.6	10.4	11.1	9.1	7.1	6.9
	5% WB	MCDBR	6.1	7.2	14.2	21.5	20.3	19.3	19.0	18.6	15.6	10.7	7.0	6.9
		MCWBR	6.1	6.6	9.8	13.1	11.8	11.2	9.6	10.3	10.2	8.7	6.9	6.7
Clear-Sky Solar Irradiance	taub	0.276	0.307	0.332	0.371	0.367	0.364	0.387	0.385	0.354	0.333	0.308	0.263	
	taud	2.127	2.144	2.196	2.289	2.400	2.444	2.400	2.401	2.471	2.400	2.208	2.092	
	Ebn at Noon	161	218	252	263	274	276	266	257	247	213	148	120	
	Edh at Noon	15	25	32	35	33	33	33	31	25	20	14	10	
All-Sky Solar Radiation	RadAvg	83	270	729	1218	1696	1752	1716	1325	812	336	94	49	
	RadStd	13	52	103	141	179	146	157	136	99	47	15	7	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (38 neighbors)	+0.85	N/A	N/A	N/A	N/A	N/A	-301	-308	N/A	N/A

Nomenclature: See separate page