

NARVA-JOESUU, Estonia

WMO: 260580

Lat: 59.3894N

Lon: 28.1090E

Elev: 30

StdP: 100.97

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-21.9	-18.4	-24.3	0.4	-21.8	-20.8	0.6	-18.1	10.3	0.1	9.6	-0.1	1.9	140	0.591

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.9	27.7	19.4	25.6	18.5	23.7	17.7	20.7	25.3	19.5	24.0	18.5	22.7	3.3	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.9	13.8	23.0	17.8	12.9	22.0	16.7	12.0	20.7	59.6	25.2	55.8	24.1	52.4	22.8	24.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.7	7.8	6.9	-23.7	29.9	4.5	2.2	-27.0	31.5	-29.6	32.8	-32.2	34.0	-35.5	35.6		
(5)			-23.9	21.9	4.5	1.1	-27.1	22.7	-29.8	23.4	-32.3	24.0	-35.6	24.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	5.8	-5.0	-5.2	-1.6	4.6	10.2	14.8	18.1	16.6	11.9	6.2	1.1	-2.5	(6)
(7)		DBStd	9.26	6.27	6.36	4.54	4.08	4.42	3.32	3.29	3.00	3.25	3.77	4.43	5.57	(7)
(8)		HDD10.0	2274	466	426	359	169	51	3	0	0	18	127	266	388	(8)
(9)		HDD18.3	4634	724	659	618	412	254	116	45	72	193	377	516	647	(9)
(10)		CDD10.0	748	0	0	0	7	58	146	251	203	76	8	0	0	(10)
(11)		CDD18.3	66	0	0	0	0	3	9	37	17	1	0	0	0	(11)
(12)		CDH23.3	490	0	0	0	1	32	78	257	121	2	0	0	0	(12)
(13)		CDH26.7	100	0	0	0	0	5	12	59	23	0	0	0	0	(13)
(14)	Wind	WSAvg	3.3	3.6	3.6	3.5	3.2	3.1	3.2	2.8	2.9	3.1	3.5	3.6	4.0	(14)
(15)	Precipitation	PrecAvg	676	48	38	38	32	46	77	70	86	62	70	60	49	(15)
(16)		PrecMax	873	82	84	75	68	91	188	135	176	136	123	117	80	(16)
(17)		PrecMin	449	20	6	7	8	8	22	14	11	18	22	5	16	(17)
(18)		PrecStd	119	16	17	18	16	23	36	34	43	34	27	22	19	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.9	5.3	11.2	21.6	27.1	28.4	30.9	29.3	22.9	15.6	10.1	8.6	(19)
(20)			MCWB	4.1	3.7	6.0	12.1	17.5	19.0	20.6	19.5	16.7	12.5	8.7	7.4	(20)
(21)		2%	DB	3.5	3.9	7.4	17.2	23.3	25.7	28.3	26.4	20.2	13.7	8.7	6.4	(21)
(22)			MCWB	2.7	2.7	4.0	10.1	15.3	18.1	20.3	18.6	15.6	11.8	7.6	5.4	(22)
(23)		5%	DB	2.6	2.9	5.4	14.0	20.3	23.3	26.2	24.2	18.3	12.5	7.7	5.1	(23)
(24)			MCWB	1.8	2.0	2.9	8.6	13.9	16.9	19.2	17.9	14.6	11.0	6.7	4.2	(24)
(25)		10%	DB	1.7	2.0	3.8	11.3	17.8	20.8	24.2	22.2	16.9	11.3	6.7	3.6	(25)
(26)			MCWB	1.1	1.3	2.0	7.0	12.7	15.6	18.6	17.2	13.9	9.9	5.7	2.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.3	4.2	6.4	12.9	18.9	20.5	22.2	21.2	17.7	13.2	9.1	7.4	(27)
(28)			MCDWB	4.7	4.9	9.9	19.1	25.0	25.4	27.8	25.7	20.8	14.6	9.8	8.3	(28)
(29)		2%	WB	2.9	2.9	4.5	10.9	16.6	19.0	21.2	19.7	16.4	12.2	7.9	5.7	(29)
(30)			MCDWB	3.4	3.6	6.9	16.4	21.0	24.0	26.2	24.1	19.2	13.4	8.6	6.4	(30)
(31)		5%	WB	2.0	2.1	3.4	9.0	14.8	17.6	20.2	18.7	15.3	11.1	6.9	4.2	(31)
(32)			MCDWB	2.4	2.8	5.0	13.3	19.1	21.9	24.6	22.9	17.6	12.3	7.7	4.9	(32)
(33)		10%	WB	1.2	1.3	2.3	7.4	13.1	16.3	19.2	17.7	14.2	10.1	5.8	2.9	(33)
(34)			MCDWB	1.6	1.9	3.6	10.8	17.0	20.2	23.4	21.5	16.2	11.2	6.5	3.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.4	5.2	6.3	8.0	8.7	7.9	8.2	6.9	4.8	3.5	3.8	(35)	
(36)			MCDBR	3.3	4.1	8.3	13.1	13.4	12.5	11.5	11.9	9.3	5.8	3.9	3.7	(36)
(37)			MCWBR	3.2	3.7	5.5	7.3	6.7	6.0	4.9	5.4	5.4	4.2	3.7	3.6	(37)
(38)		5% WB	MCDWR	3.2	4.0	7.1	11.9	12.0	10.4	9.6	9.7	7.9	5.3	3.9	3.4	(38)
(39)			MCWBR	3.2	3.8	5.0	7.1	6.6	5.5	4.7	5.0	5.1	4.2	3.8	3.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.280	0.312	0.336	0.374	0.370	0.367	0.391	0.387	0.358	0.336	0.310	0.267	(40)	
(41)		taud	2.136	2.150	2.203	2.286	2.396	2.441	2.394	2.398	2.466	2.393	2.217	2.102	(41)	
(42)		Ebn at Noon	500	680	789	825	859	867	834	806	774	665	461	372	(42)	
(43)		Edh at Noon	46	77	99	110	106	103	106	98	78	62	44	33	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.27	0.87	2.30	3.80	5.24	5.41	5.29	4.11	2.52	1.04	0.29	0.15	(44)	
(45)		RadStd	0.05	0.17	0.31	0.47	0.55	0.43	0.53	0.43	0.29	0.15	0.04	0.02	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (33 neighbors)	+0.48	N/A	N/A	N/A	N/A	N/A	-175	-176	N/A	N/A

Nomenclature: See separate page