

KINGISEPP, Russian Federation

WMO: 260590

Lat: 59.3671N

Lon: 28.6012E

Elev: 62

StdP: 14.66

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-9.3	-3.1	-13.5	2.7	-9.1	-7.4	3.7	-2.7	14.9	30.8	13.6	31.0	2.2	120	0.544

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.2	82.8	68.1	79.2	66.2	75.8	64.2	69.9	79.3	67.7	76.4	65.8	73.8	5.7	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.5	97.8	74.9	64.5	91.0	72.3	62.6	85.0	70.1	34.0	79.3	32.1	76.6	30.6	73.8	76.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.6	11.4	9.9	DB	-14.1	86.9	7.8	3.2	-19.6	89.2	-24.2	91.1	-28.5	92.9	-34.2	95.3	(4)
(5)			WB	-14.4	72.9	7.7	2.2	-19.9	74.4	-24.4	75.7	-28.7	76.9	-34.3	78.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	42.4	22.0	21.7	29.4	41.7	51.7	59.5	64.7	61.6	52.9	42.4	33.2	26.7	(6)	
	DBStd	17.12	11.76	11.99	8.17	7.76	7.85	6.23	5.78	5.40	6.11	6.91	8.21	10.38	(7)	
	HDD50	4155	869	792	637	270	71	3	0	0	40	248	504	721	(8)	
	HDD65	8369	1334	1212	1102	700	418	188	77	135	363	700	954	1186	(9)	
	CDD50	1389	0	0	0	20	126	289	455	358	128	13	0	0	(10)	
	CDD65	126	0	0	0	0	7	23	67	28	1	0	0	0	(11)	
	CDH74	1105	0	0	0	2	77	220	565	233	8	0	0	0	(12)	
	CDH80	227	0	0	0	0	14	41	130	42	0	0	0	0	(13)	
(14) Wind	WSAvg	4.8	5.3	5.1	5.1	5.1	4.8	4.5	4.1	3.9	4.1	4.7	5.4	5.7	(14)	
(15) Precipitation	PrecAvg	27.0	1.6	1.2	1.4	1.4	1.8	2.8	3.0	3.5	3.1	2.7	2.4	2.0	(15)	
	PrecMax	35.7	3.3	3.1	3.3	3.4	4.1	8.0	5.2	8.5	5.8	5.8	4.0	3.8	(16)	
	PrecMin	17.6	0.2	0.2	0.3	0.3	0.5	0.3	0.7	0.2	0.6	0.4	0.0	0.8	(17)	
	PrecStd	4.1	0.7	0.6	0.8	0.8	0.9	1.5	1.4	2.0	1.5	1.3	0.8	0.7	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.3	41.8	55.2	72.1	81.8	84.7	87.5	84.7	74.4	60.8	49.7	46.8	(19)	
		MCWB	40.2	38.6	43.5	55.6	64.1	67.9	69.8	68.2	63.1	54.9	47.4	44.7	(20)	
	2%	DB	38.4	39.3	46.8	65.5	75.2	80.2	83.7	79.8	69.0	56.8	47.6	43.0	(21)	
		MCWB	37.1	37.1	39.6	52.6	60.5	65.6	69.4	66.7	60.7	53.3	45.6	41.5	(22)	
	5%	DB	36.6	37.3	42.7	60.0	70.7	75.9	80.2	76.1	65.6	54.4	45.7	40.9	(23)	
		MCWB	35.3	35.6	37.1	48.7	57.3	63.3	67.8	64.8	58.4	51.5	44.1	39.6	(24)	
	10%	DB	34.9	35.6	39.8	55.4	66.5	71.6	76.7	72.7	62.8	52.2	43.4	38.6	(25)	
		MCWB	33.9	34.3	36.1	46.0	55.2	60.6	65.7	63.0	56.9	49.7	42.0	37.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	40.6	39.5	45.1	57.5	67.3	70.4	72.7	71.5	65.1	56.0	47.8	44.8	(27)	
		MCDB	41.2	41.2	52.6	68.3	78.3	80.5	83.2	79.4	71.6	59.0	49.3	46.4	(28)	
	2%	WB	37.4	37.5	40.6	53.4	62.6	67.4	70.8	68.0	61.8	53.8	45.9	41.7	(29)	
		MCDB	38.1	38.9	45.3	64.1	70.9	77.3	80.8	76.5	66.8	56.1	47.3	42.8	(30)	
	5%	WB	35.5	35.8	38.4	50.0	59.3	64.9	68.9	66.1	59.6	52.0	44.2	39.7	(31)	
		MCDB	36.3	37.0	41.8	58.1	68.3	73.4	77.8	74.0	64.1	54.2	45.5	40.7	(32)	
	10%	WB	34.0	34.3	36.6	47.0	56.3	62.3	66.9	64.3	57.7	49.9	42.2	37.4	(33)	
		MCDB	34.8	35.4	39.3	54.1	64.9	69.5	74.9	71.3	61.6	51.9	43.3	38.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.7	10.7	13.4	16.7	18.5	16.5	16.2	16.3	14.0	9.7	6.8	7.2	(35)	
		MCDBR	6.1	8.7	17.5	25.8	25.6	23.4	21.3	22.7	18.8	11.9	7.7	6.6	(36)	
	5% WB	MCWBR	5.8	7.4	11.5	14.2	12.5	11.4	9.6	11.1	10.9	8.5	6.9	6.2	(37)	
		MCWBR	6.4	7.7	14.2	23.1	21.9	20.6	19.2	19.4	16.0	11.0	7.3	6.4	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.279	0.312	0.338	0.376	0.371	0.368	0.392	0.388	0.359	0.336	0.309	0.266	(40)	
		taud	2.126	2.138	2.196	2.282	2.385	2.426	2.377	2.384	2.450	2.388	2.217	2.095	(41)	
	Ebn at Noon	Ebn at Noon	159	215	249	261	272	275	264	255	245	211	147	118	(42)	
		Edh at Noon	15	25	32	35	34	33	34	31	25	20	14	10	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	89	284	732	1200	1639	1693	1652	1287	792	326	93	48	(44)	
	RadStd	RadStd	16	57	94	152	170	131	176	136	87	49	13	8	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.95	N/A	N/A	N/A	N/A	N/A	-349	-400	N/A	N/A	(46)
(47)	Regional (25 neighbors)	+0.88	N/A	N/A	N/A	N/A	N/A	-319	-317	N/A	N/A	(47)

Nomenclature: See separate page