

TURI, Estonia

WMO: 261350

Lat: 58.8086N

Lon: 25.4092E

Elev: 202

StdP: 14.59

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-6.0	0.9	-10.3	3.2	-5.4	-3.5	4.6	1.6	15.3	32.7	13.9	31.8	2.4	110	0.554

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.6	81.7	67.1	78.4	65.0	75.4	63.6	69.1	78.3	67.1	75.3	65.2	72.9	5.5	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.9	96.1	73.1	63.9	89.7	71.4	62.0	83.7	69.0	33.3	78.5	31.7	75.7	30.2	72.7	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.3	11.8	10.4	DB	-12.3	85.5	7.6	3.4	-17.8	87.9	-22.2	89.9	-26.5	91.8	-32.0	94.2	(4)
(5)			WB	-12.7	72.1	7.4	2.2	-18.0	73.7	-22.4	75.0	-26.5	76.2	-31.9	77.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	42.6	23.6	23.1	29.8	41.5	51.1	58.4	63.8	61.0	52.8	42.3	34.1	28.1
	DBStd	16.18	10.79	11.06	7.93	7.36	7.62	5.90	5.53	5.31	6.03	7.11	7.73	9.64
	HDD50	4001	818	754	627	273	77	4	0	0	42	251	476	679
	HDD65	8278	1283	1174	1092	706	435	212	89	146	367	704	926	1144
	CDD50	1293	0	0	0	16	111	256	429	343	125	13	0	0
	CDD65	94	0	0	0	0	4	14	53	23	0	0	0	0
	CDH74	923	0	0	0	1	57	154	500	208	3	0	0	0
	CDH80	152	0	0	0	0	6	14	103	29	0	0	0	0
Wind	WSAvg	5.1	5.7	5.5	5.5	5.3	5.0	4.8	4.3	4.1	4.5	5.1	5.5	5.9
Precipitation	PrecAvg	28.3	2.2	1.7	1.5	1.4	1.8	2.9	2.9	3.5	2.3	2.9	2.6	2.4
	PrecMax	37.4	5.0	4.4	3.4	3.7	4.1	6.4	6.5	7.6	4.9	5.5	4.8	5.8
	PrecMin	14.6	0.4	0.3	0.3	0.4	0.5	0.6	0.2	0.4	0.4	0.5	0.5	0.9
	PrecStd	4.9	1.1	0.9	0.8	0.9	1.0	1.3	1.5	1.9	1.3	1.1	1.1	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.2	41.9	54.9	70.6	80.0	82.1	86.6	83.7	73.4	60.2	50.2	47.0
		MCWB	41.3	39.0	43.8	54.5	63.1	66.5	69.2	67.7	62.7	54.8	48.3	45.2
	2%	DB	39.2	39.3	47.4	65.2	74.7	78.7	83.3	79.1	68.9	56.8	47.9	44.1
		MCWB	38.5	37.7	40.0	51.5	59.7	63.9	68.4	65.6	60.0	53.8	46.5	42.9
	5%	DB	37.0	37.4	42.8	60.3	70.7	74.7	79.8	75.8	65.6	54.5	46.2	41.6
		MCWB	36.1	36.2	37.9	48.7	57.2	62.4	66.5	64.4	58.3	52.3	44.9	40.5
	10%	DB	35.5	35.7	39.4	55.4	66.3	71.1	76.3	72.4	62.7	52.4	44.3	39.3
		MCWB	34.8	34.6	35.9	46.2	54.7	59.9	64.8	62.7	57.1	50.4	43.3	38.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.5	39.9	45.2	57.1	67.1	69.5	72.0	70.2	63.6	56.4	48.8	45.6
		MCDB	42.0	40.9	53.3	68.5	75.4	78.3	82.0	78.5	70.3	58.3	49.7	46.6
	2%	WB	38.5	38.0	41.3	53.0	62.4	66.5	70.0	67.4	61.4	54.4	46.8	43.0
		MCDB	39.0	39.0	46.2	62.1	70.9	74.3	80.1	75.4	66.5	56.2	47.8	43.9
	5%	WB	36.4	36.4	38.6	49.9	59.2	63.8	68.1	65.6	59.7	52.7	45.2	40.6
		MCDB	36.9	37.3	41.7	58.7	67.5	71.7	76.6	73.3	63.9	54.4	46.1	41.5
	10%	WB	34.8	34.7	36.7	47.1	55.9	61.3	66.2	63.9	57.9	50.8	43.4	38.4
		MCDB	35.3	35.5	38.9	54.3	64.7	69.3	74.5	70.8	61.6	52.3	44.2	39.2
Mean Daily Temperature Range	5% DB	MDBR	8.2	10.0	12.9	17.4	19.7	17.7	17.6	17.6	15.1	10.7	7.0	7.2
		MCDBR	6.1	8.0	17.4	26.2	26.3	23.6	23.4	23.3	19.3	12.4	7.9	6.3
		MCWBR	6.1	7.0	11.5	14.5	13.2	11.5	10.2	11.5	11.1	9.2	7.2	6.2
	5% WB	MCDBR	6.1	7.7	14.8	23.7	22.2	20.3	20.3	20.0	16.4	10.7	7.5	6.1
		MCWBR	6.1	7.1	10.4	13.7	12.0	11.2	9.8	10.8	10.1	8.6	7.1	6.3
Clear-Sky Solar Irradiance	taub	0.274	0.304	0.332	0.370	0.365	0.364	0.389	0.386	0.354	0.333	0.312	0.265	
	taud	2.120	2.148	2.209	2.307	2.386	2.414	2.366	2.371	2.450	2.404	2.214	2.099	
	Ebn at Noon	167	222	253	264	275	277	266	257	248	215	152	128	
	Edh at Noon	16	25	32	34	34	34	35	32	25	20	15	11	
All-Sky Solar Radiation	RadAvg	96	295	757	1250	1714	1771	1678	1327	830	376	112	61	
	RadStd	19	53	95	137	177	128	156	132	99	52	17	10	

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (48 neighbors)		+0.72	N/A	N/A	N/A	N/A	N/A	-257	N/A	N/A	N/A

Nomenclature: See separate page