

TURI, Estonia

WMO: 261350

Lat: 58.8086N

Lon: 25.4092E

Elev: 62

StdP: 100.59

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-21.1	-17.3	-23.5	0.5	-20.8	-19.7	0.7	-16.9	6.8	0.4	6.2	-0.1	1.1	110	0.554

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.8	27.6	19.5	25.8	18.3	24.1	17.5	20.6	25.7	19.5	24.1	18.4	22.7	2.5	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.8	13.7	22.9	17.7	12.8	21.9	16.7	12.0	20.6	59.6	25.8	55.8	24.3	52.4	22.6	25.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.9	5.3	4.7	DB	-24.6	29.7	4.2	1.9	-27.6	31.1	-30.1	32.2	-32.5	33.2	-35.6	34.6	(4)
(5)			WB	-24.8	22.3	4.1	1.2	-27.8	23.2	-30.2	23.9	-32.5	24.6	-35.5	25.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	5.9	-4.7	-5.0	-1.2	5.3	10.6	14.7	17.7	16.1	11.5	5.7	1.2	-2.2	(6)
(7)		DBStd	8.99	5.99	6.14	4.41	4.09	4.23	3.28	3.07	2.95	3.35	3.95	4.29	5.36	(7)
(8)		HDD10.0	2223	454	419	348	152	43	2	0	0	23	139	264	377	(8)
(9)		HDD18.3	4599	713	652	607	392	242	118	49	81	204	391	514	636	(9)
(10)		CDD10.0	718	0	0	0	9	62	142	238	191	69	7	0	0	(10)
(11)		CDD18.3	52	0	0	0	0	2	8	29	13	0	0	0	0	(11)
(12)		CDH23.3	513	0	0	0	1	32	86	278	116	2	0	0	0	(12)
(13)		CDH26.7	84	0	0	0	0	3	8	57	16	0	0	0	0	(13)
(14)	Wind	WSAvg	2.3	2.6	2.5	2.5	2.4	2.2	2.1	1.9	1.8	2.0	2.3	2.5	2.7	(14)
(15)	Precipitation	PrecAvg	718	57	43	39	36	46	74	73	90	59	73	67	61	(15)
(16)		PrecMax	951	126	112	86	94	105	163	164	192	124	139	122	148	(16)
(17)		PrecMin	370	11	8	7	9	13	15	5	11	10	13	12	22	(17)
(18)		PrecStd	125	27	23	20	22	25	34	38	48	32	29	29	26	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.7	5.5	12.7	21.4	26.7	27.8	30.4	28.7	23.0	15.7	10.1	8.3	(19)
(20)			MCWB	5.1	3.9	6.6	12.5	17.3	19.1	20.7	19.9	17.1	12.7	9.1	7.3	(20)
(21)		2%	DB	4.0	4.1	8.6	18.4	23.7	25.9	28.5	26.2	20.5	13.8	8.8	6.7	(21)
(22)			MCWB	3.6	3.2	4.4	10.9	15.4	17.7	20.2	18.7	15.5	12.1	8.1	6.1	(22)
(23)		5%	DB	2.8	3.0	6.0	15.7	21.5	23.7	26.5	24.3	18.6	12.5	7.9	5.3	(23)
(24)			MCWB	2.3	2.3	3.3	9.3	14.0	16.9	19.1	18.0	14.6	11.3	7.2	4.7	(24)
(25)		10%	DB	1.9	2.0	4.1	13.0	19.1	21.7	24.6	22.4	17.0	11.4	6.9	4.1	(25)
(26)			MCWB	1.5	1.4	2.2	7.9	12.6	15.5	18.2	17.0	13.9	10.2	6.3	3.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.3	4.4	7.3	14.0	19.5	20.9	22.2	21.2	17.6	13.6	9.3	7.5	(27)
(28)			MCDWB	5.5	4.9	11.9	20.3	24.1	25.7	27.8	25.9	21.3	14.6	9.8	8.1	(28)
(29)		2%	WB	3.6	3.3	5.2	11.6	16.9	19.1	21.1	19.7	16.3	12.4	8.2	6.1	(29)
(30)			MCDWB	3.9	3.9	7.9	16.7	21.6	23.5	26.7	24.1	19.2	13.4	8.8	6.6	(30)
(31)		5%	WB	2.4	2.4	3.6	9.9	15.1	17.7	20.1	18.7	15.4	11.5	7.3	4.8	(31)
(32)			MCDWB	2.7	2.9	5.4	14.9	19.7	22.1	24.8	22.9	17.7	12.4	7.8	5.3	(32)
(33)		10%	WB	1.5	1.5	2.6	8.4	13.3	16.3	19.0	17.7	14.4	10.4	6.3	3.6	(33)
(34)			MCDWB	1.8	2.0	3.8	12.4	18.2	20.7	23.6	21.6	16.4	11.3	6.8	4.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.5	5.5	7.2	9.7	10.9	9.8	9.8	8.4	6.0	3.9	4.0	(35)	
(36)			MCDBR	3.4	4.4	9.7	14.6	14.6	13.1	13.0	12.9	10.7	6.9	4.4	3.5	(36)
(37)			MCWBR	3.4	3.9	6.4	8.0	7.3	6.4	5.6	6.4	6.2	5.1	4.0	3.5	(37)
(38)		5% WB	MCDWB	3.4	4.3	8.2	13.2	12.3	11.3	11.3	11.1	9.1	5.9	4.2	3.4	(38)
(39)			MCWBR	3.4	3.9	5.8	7.6	6.7	6.2	5.4	6.0	5.6	4.8	4.0	3.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.274	0.304	0.332	0.370	0.365	0.364	0.389	0.386	0.354	0.333	0.312	0.265	(40)	
(41)		taud	2.120	2.148	2.209	2.307	2.386	2.414	2.366	2.371	2.450	2.404	2.214	2.099	(41)	
(42)		Ebn at Noon	526	700	799	833	866	872	837	810	782	679	478	402	(42)	
(43)		Edh at Noon	49	79	100	108	107	106	109	101	80	63	46	35	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.30	0.93	2.39	3.94	5.40	5.58	5.29	4.18	2.62	1.18	0.35	0.19	(44)	
(45)		RadStd	0.06	0.17	0.30	0.43	0.56	0.40	0.49	0.42	0.31	0.16	0.05	0.03	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (48 neighbors)		+0.40	N/A	N/A	N/A	N/A	N/A	-143	N/A	N/A	N/A

Nomenclature: See separate page