

JOGEVA, Estonia

WMO: 261440

Lat: 58.7497N

Lon: 26.4150E

Elev: 235

StdP: 14.57

Time Zone: 2.00 (EUE)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.3	-4.2	-15.6	2.4	-11.3	-8.0	3.6	-3.8	19.2	27.4	17.2	25.3	2.6	70	0.572

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.5	82.0	66.8	78.7	65.0	75.3	63.6	69.2	78.0	67.1	75.2	65.2	73.0	6.5	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.1	96.9	73.4	64.1	90.3	71.3	62.0	83.8	68.9	33.4	78.0	31.7	75.1	30.2	73.2	74.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.4	14.2	12.5	-15.5	85.3	10.0	2.9	-22.7	87.3	-28.6	89.0	-34.2	90.6	-41.5	92.7		
(5)			-15.6	71.6	9.6	1.7	-22.5	72.9	-28.1	73.9	-33.5	74.8	-40.5	76.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	42.1	21.4	22.0	29.1	40.8	51.8	57.9	63.5	60.9	52.4	41.8	34.3	28.2		
	DBStd	16.70	12.68	12.14	9.52	6.61	7.70	5.78	5.85	5.38	5.70	7.30	7.53	9.94		
	HDD50	4129	886	785	647	285	67	6	0	1	40	266	470	676		
	HDD65	8446	1351	1205	1112	727	415	225	100	151	378	721	920	1141		
	CDD50	1252	0	0	0	7	123	242	419	338	112	11	0	0		
	CDD65	92	0	0	0	0	5	11	53	23	0	0	0	0		
	CDH74	969	0	0	0	0	68	154	522	222	3	0	0	0		
	CDH80	171	0	0	0	0	8	17	110	36	0	0	0	0		
(14) Wind	WSAvg	5.9	6.1	6.1	6.5	6.3	5.9	6.0	5.3	5.0	5.3	5.9	6.2	6.7		
(15) Precipitation	PrecAvg	26.3	2.0	1.5	1.4	1.2	2.0	3.2	2.8	3.3	2.0	2.6	2.2	2.0		
	PrecMax	34.8	4.0	3.3	2.7	2.6	4.0	7.0	6.4	7.7	4.0	4.4	3.5	4.1		
	PrecMin	18.7	0.7	0.3	0.5	0.3	0.1	0.4	0.6	0.1	0.2	0.3	0.4	0.7		
	PrecStd	4.4	0.8	0.7	0.6	0.6	0.9	1.5	1.3	1.7	1.0	0.9	0.8	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.7	41.3	55.9	68.7	80.7	82.5	86.7	84.2	73.0	59.3	49.5	47.4		
		MCWB	41.8	38.8	44.5	52.3	63.9	66.6	68.9	67.1	61.5	54.1	47.3	45.4		
	2%	DB	39.8	39.0	47.8	63.4	74.9	78.7	83.2	79.6	68.3	56.4	47.4	44.0		
		MCWB	38.8	37.5	40.8	49.3	60.3	63.4	67.6	66.1	59.7	53.3	45.8	42.3		
	5%	DB	37.2	36.9	43.1	58.6	70.8	74.5	79.9	76.0	65.2	54.4	45.8	41.7		
		MCWB	36.2	35.7	38.4	47.0	58.5	62.2	66.6	63.9	57.9	52.1	44.6	40.3		
	10%	DB	35.4	35.1	39.7	54.1	66.8	70.6	76.3	72.4	62.5	52.4	43.9	39.2		
		MCWB	34.5	34.1	36.6	44.5	55.7	59.7	65.0	62.5	56.6	50.3	42.8	38.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.9	39.8	45.7	53.6	67.4	70.1	71.8	70.5	62.9	55.8	47.6	46.0		
		MCDB	42.6	40.9	53.6	64.7	74.7	77.4	82.0	79.6	68.8	57.4	48.6	47.3		
	2%	WB	38.9	37.6	41.4	50.6	63.4	66.3	70.0	67.5	60.9	54.0	46.2	42.7		
		MCDB	39.5	38.5	46.5	61.5	71.8	74.9	79.5	75.1	66.1	55.7	47.1	43.9		
	5%	WB	36.4	35.8	38.9	48.1	60.2	63.6	68.1	65.6	59.2	52.5	44.8	40.4		
		MCDB	37.1	36.7	42.0	56.6	67.9	71.3	76.4	73.0	63.9	54.2	45.7	41.5		
	10%	WB	34.6	34.2	37.1	45.7	57.2	61.0	66.2	63.8	57.4	50.6	42.9	38.0		
		MCDB	35.2	35.0	39.5	52.4	64.7	69.4	74.7	71.0	61.3	52.2	43.7	38.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.4	10.3	13.9	17.7	19.9	18.4	18.5	18.2	15.2	10.8	6.7	7.0		
		MCDBR	6.3	7.4	16.9	28.0	25.1	25.3	23.8	24.3	20.3	12.7	7.7	7.0		
	5% WB	MCWBR	6.0	6.5	11.0	15.3	12.5	12.5	10.4	11.9	12.3	9.7	7.1	6.6		
		MCWBR	6.5	6.7	14.5	24.4	21.1	20.8	20.6	20.2	17.6	10.8	7.2	6.7		
(40) Clear-Sky Solar Irradiance	taub		0.273	0.304	0.332	0.370	0.365	0.363	0.387	0.386	0.354	0.333	0.309	0.263		
		taud	2.111	2.133	2.192	2.305	2.388	2.420	2.373	2.373	2.450	2.400	2.205	2.087		
	Ebn at Noon		167	222	253	265	275	277	266	257	248	216	153	128		
		Edh at Noon	16	25	32	34	34	33	34	32	25	20	15	11		
(44) All-Sky Solar Radiation	RadAvg		98	297	759	1225	1686	1727	1676	1312	825	357	105	60		
	RadStd		18	54	97	144	179	142	162	134	99	52	15	10		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (42 neighbors)		+0.79	N/A	N/A	N/A	N/A	N/A	-288	-297	N/A	N/A

Nomenclature: See separate page