

GDOV, Russian Federation

WMO: 261570

Lat: 58.733N

Lon: 27.833E

Elev: 135

StdP: 14.62

Time Zone: 3.00 (E03)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-8.9	-3.4	-13.0	2.7	-8.6	-7.9	3.6	-2.6	21.3	32.3	19.7	30.0	3.0	40	0.584

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.2	82.1	68.2	78.9	66.8	75.6	65.1	70.3	78.9	68.3	75.9	66.4	73.7	7.1	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.2	100.6	74.6	65.4	94.1	73.0	63.5	88.1	71.0	34.3	79.7	32.7	75.6	31.1	73.8	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.6	16.6	14.9	DB	-14.3	86.6	7.9	3.3	-20.0	89.0	-24.6	90.9	-29.1	92.8	-34.8	95.2	(4)
(5)			WB	-14.6	72.8	7.8	2.1	-20.2	74.3	-24.8	75.5	-29.2	76.7	-34.9	78.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	43.0	20.0	22.7	29.2	41.5	53.4	59.6	65.4	61.9	54.6	42.0	35.5	28.7		
	DBStd	17.17	11.92	12.02	8.30	6.58	7.57	6.04	5.96	5.57	5.55	6.62	7.43	9.01		
	HDD50	4037	931	765	645	267	49	4	0	1	21	259	435	660		
	HDD65	8177	1396	1185	1110	704	369	182	68	126	313	714	885	1125		
	CDD50	1473	0	0	0	12	153	292	477	371	159	9	0	0		
	CDD65	140	0	0	0	0	8	20	80	31	1	0	0	0		
	CDH74	1015	0	0	0	0	79	153	565	213	5	0	0	0		
	CDH80	193	0	0	0	0	11	16	116	50	0	0	0	0		
	WSAvg	7.4	7.9	7.5	7.8	7.0	6.7	6.9	6.3	6.4	7.1	7.6	8.5	9.1		
	PrecAvg	25.7	1.8	1.4	1.3	1.3	2.0	3.1	2.8	3.3	2.2	2.5	2.2	1.8		
	PrecMax	33.0	3.3	2.4	2.5	3.0	4.2	5.6	6.1	9.1	4.6	4.3	4.1	3.5		
(15) Precipitation	PrecMin	18.3	0.7	0.4	0.4	0.3	0.5	0.4	0.4	0.0	0.4	0.6	0.2	0.8		
	PrecStd	3.9	0.6	0.6	0.6	0.7	1.0	1.4	1.4	2.1	1.1	0.9	0.9	0.7		
	DB	40.8	40.9	51.4	68.9	81.0	82.1	87.0	85.4	74.1	58.3	49.6	44.3			
	MCWB	39.5	37.8	39.4	52.5	62.9	67.4	70.8	68.7	65.6	53.8	47.3	42.4			
	2% DB	38.2	37.7	45.3	62.8	75.4	78.6	83.5	80.0	69.2	55.5	46.7	42.1			
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	MCWB	37.0	35.4	39.1	49.2	61.4	64.7	69.4	68.0	61.1	52.2	45.3	40.6			
	5% DB	35.9	36.1	41.7	57.9	71.0	74.7	79.9	75.4	65.7	53.2	45.4	40.2			
	MCWB	34.9	34.6	37.3	46.7	58.5	63.6	68.5	64.9	59.5	50.7	44.2	38.8			
	10% DB	34.0	34.9	39.0	53.4	67.4	71.0	76.9	71.9	63.0	51.4	43.6	38.5			
	MCWB	33.3	33.7	35.6	43.9	56.0	60.8	66.7	63.7	57.5	49.2	42.6	37.3			
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	39.8	38.4	42.2	53.5	66.8	70.0	73.7	72.1	65.3	55.2	48.0	43.1			
	MCDB	40.4	40.3	46.4	64.4	78.9	78.3	81.6	81.8	72.3	57.1	49.4	43.8			
	2% WB	37.1	36.0	39.7	50.3	63.3	67.3	71.4	68.5	62.7	53.0	45.6	40.8			
	MCDB	37.9	37.0	43.8	61.0	71.7	75.1	81.1	75.8	67.8	54.9	46.4	41.7			
	5% WB	35.0	34.9	37.9	48.0	60.4	64.8	69.6	66.3	60.4	51.4	44.4	39.0			
(30) Mean Daily Temperature Range	MCDB	35.8	35.9	41.0	56.5	68.6	72.8	77.6	74.0	64.1	52.9	45.4	40.0			
	10% WB	33.3	33.9	36.2	45.3	57.7	62.3	67.8	64.4	58.5	49.5	42.7	37.4			
	MCDB	33.8	34.9	38.8	51.8	65.4	69.0	74.8	70.9	61.8	51.1	43.4	38.5			
	5% DB	8.9	9.2	11.9	15.9	17.9	15.4	15.2	14.8	11.9	9.3	5.5	5.8			
	MCDBR	5.5	6.4	12.9	25.2	23.2	20.7	19.9	21.2	16.3	10.2	5.6	5.9			
(35) Clear-Sky Solar Irradiance	MCWBR	5.3	5.6	9.0	13.7	11.5	10.8	8.9	10.5	9.6	8.2	5.3	6.0			
	5% WB	5.6	6.0	11.3	22.0	19.4	18.1	17.3	18.5	14.2	9.6	5.5	5.8			
	MCDBR	5.4	5.5	8.6	12.8	10.8	11.0	8.7	10.4	9.1	8.3	5.3	6.0			
	taub	0.276	0.309	0.337	0.376	0.370	0.367	0.390	0.389	0.360	0.336	0.311	0.266			
	taud	2.112	2.131	2.205	2.306	2.395	2.436	2.386	2.382	2.446	2.397	2.203	2.090			
(40) All-Sky Solar Radiation	Ebn at Noon	166	220	252	263	273	276	265	256	246	214	152	128			
	Edh at Noon	16	25	32	35	34	33	34	32	26	20	15	11			
	RadAvg	99	300	757	1222	1669	1715	1666	1306	819	350	104	59			
(45)	RadStd	19	56	97	148	176	148	170	131	96	53	15	10			

Historical Trends

		Heating		Cooling		Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (26 neighbors)	+0.83	N/A	N/A	N/A	N/A	N/A	-306	-306	N/A	N/A

Nomenclature: See separate page