

RETYUN', Russian Federation

WMO: 261670

Lat: 58.567N

Lon: 29.800E

Elev: 299

StdP: 14.54

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-9.0	-3.7	-13.3	2.7	-8.5	-7.9	3.6	-3.3	16.9	31.7	15.5	30.4	2.3	20	0.562

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.5	81.6	67.7	78.4	65.9	75.3	64.2	70.0	78.3	67.8	75.1	65.9	72.9	6.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.1	100.7	74.2	65.1	93.8	71.7	63.2	87.7	69.3	34.1	78.5	32.3	75.0	30.8	73.2	78.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.7	13.1	11.7	DB	-14.8	86.2	7.4	3.0	-20.1	88.3	-24.4	90.1	-28.5	91.8	-33.9	94.0	(4)
(5)			WB	-15.8	72.7	6.3	2.6	-20.4	74.6	-24.0	76.2	-27.5	77.7	-32.1	79.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	42.0	21.2	21.2	29.6	42.1	52.2	59.4	64.4	61.0	52.4	41.5	31.8	25.2	(6)
(7)		DBStd	17.39	11.87	12.08	8.12	7.96	7.85	6.29	5.62	5.41	6.07	7.09	8.84	10.59	(7)
(8)		HDD50	4301	892	808	633	261	68	5	0	1	44	274	545	770	(8)
(9)		HDD65	8524	1357	1228	1097	688	402	189	79	148	378	728	995	1235	(9)
(10)		CDD50	1364	0	0	0	23	136	287	448	342	117	11	0	0	(10)
(11)		CDD65	114	0	0	0	0	5	21	62	25	1	0	0	0	(11)
(12)		CDH74	925	0	0	0	2	58	184	475	201	5	0	0	0	(12)
(13)		CDH80	162	0	0	0	0	7	25	99	31	0	0	0	0	(13)
(14)	Wind	WSAvg	5.6	6.0	6.0	6.2	5.8	5.4	5.1	4.4	4.6	5.1	5.7	6.2	6.5	(14)
(15)	Precipitation	PrecAvg	25.7	1.6	1.2	1.5	1.5	1.9	2.5	3.1	3.4	2.6	2.2	2.3	1.8	(15)
(16)		PrecMax	32.6	2.8	3.1	3.6	3.4	3.5	5.2	6.1	9.4	5.8	4.6	4.6	3.5	(16)
(17)		PrecMin	17.5	0.3	0.2	0.3	0.1	0.4	0.3	1.2	0.9	0.5	0.3	0.1	0.8	(17)
(18)		PrecStd	3.9	0.7	0.6	0.7	0.9	0.8	1.1	1.4	2.0	1.3	0.9	0.8	0.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.6	41.6	55.4	72.2	79.9	83.3	87.0	83.8	74.1	61.5	49.2	45.4	(19)
(20)			MCWB	40.2	38.3	43.1	54.5	63.1	67.8	71.0	68.4	63.5	54.6	47.3	42.9	(20)
(21)		2%	DB	37.6	38.7	47.9	66.4	74.7	79.2	82.7	79.0	68.8	56.2	46.6	41.8	(21)
(22)			MCWB	36.2	36.1	40.0	51.6	60.4	65.4	69.1	65.7	60.8	53.0	44.9	40.4	(22)
(23)		5%	DB	35.8	36.8	43.0	61.0	70.6	75.4	79.3	75.7	65.0	53.8	44.8	39.3	(23)
(24)			MCWB	34.7	35.2	37.1	48.9	57.5	63.4	67.5	64.8	58.2	51.4	43.5	38.2	(24)
(25)		10%	DB	34.1	35.0	39.8	56.1	66.6	71.7	75.9	72.0	61.9	51.6	42.5	37.0	(25)
(26)			MCWB	33.2	33.8	36.1	46.7	55.4	61.5	65.7	62.9	56.8	49.4	41.3	35.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	40.5	39.1	45.1	56.7	67.8	70.6	73.1	71.9	65.3	56.1	47.5	43.2	(27)
(28)			MCD B	41.3	40.7	53.5	68.8	76.4	78.8	82.8	80.0	71.6	59.0	48.4	44.5	(28)
(29)		2%	WB	36.6	36.9	40.8	53.2	63.0	67.4	70.9	68.1	62.0	53.7	45.3	40.6	(29)
(30)			MCD B	37.3	38.1	45.5	63.6	71.1	75.8	79.7	74.9	66.4	55.7	46.3	41.6	(30)
(31)		5%	WB	34.8	35.4	38.5	50.4	59.8	65.1	69.0	65.9	59.7	51.9	43.6	38.4	(31)
(32)			MCD B	35.5	36.6	41.9	59.3	67.1	72.6	76.7	73.0	63.5	53.7	44.6	39.3	(32)
(33)		10%	WB	33.2	33.9	36.6	47.6	56.9	62.9	66.9	64.1	57.6	49.8	41.4	36.0	(33)
(34)			MCD B	34.0	34.8	39.3	55.0	64.3	69.6	73.9	70.5	61.2	51.4	42.3	36.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.0	10.3	12.0	16.4	18.3	16.6	16.5	16.3	13.8	9.4	6.7	7.1	(35)
(36)			MCDBR	6.1	8.0	16.3	25.1	24.4	22.6	21.7	22.4	18.8	12.0	8.0	6.5	(36)
(37)			MCWBR	5.9	6.6	10.4	13.0	12.0	10.7	9.7	10.6	10.9	8.7	7.2	6.1	(37)
(38)		5% WB	MCD BR	6.1	7.5	13.6	21.9	20.8	19.1	19.6	19.9	15.8	11.5	7.4	6.1	(38)
(39)			MCWBR	6.1	6.7	9.5	12.1	11.7	10.3	9.7	10.7	10.2	8.9	7.0	5.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.278	0.314	0.337	0.378	0.371	0.368	0.393	0.391	0.361	0.337	0.313	0.270	(40)	
(41)		taud	2.125	2.128	2.187	2.282	2.377	2.412	2.359	2.359	2.423	2.383	2.223	2.109	(41)	
(42)		Ebn at Noon	168	218	252	262	273	275	264	256	245	214	154	129	(42)	
(43)		Edh at Noon	16	26	33	35	34	34	35	33	26	20	15	11	(43)	
(44)	All-Sky Solar Radiation	RadAvg	105	312	756	1214	1648	1708	1650	1302	812	344	105	60	(44)	
(45)		RadStd	23	60	99	154	164	162	187	119	91	59	15	11	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	-308	N/A	N/A	N/A	
(47)	Regional (14 neighbors)	+0.88	N/A	N/A	N/A	N/A	N/A	-333	-355	N/A	N/A	

Nomenclature: See separate page