

KURESSAARE-ROOMASSAARE, Estonia

WMO: 262150

Lat: 58.2181N

Lon: 22.5064E

Elev: 8

StdP: 14.69

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	2.7	8.9	-1.5	5.1	2.9	4.9	7.1	10.6	27.0	30.6	24.5	30.6	6.1	30	0.646

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.3	78.6	66.7	75.4	65.5	72.5	63.9	68.9	75.8	66.9	73.3	65.2	70.9	9.7	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.2	96.7	73.0	64.4	90.5	70.5	62.7	85.3	68.6	32.9	75.9	31.4	73.2	30.1	70.4	74.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.7	20.9	18.7	DB	-1.7	81.5	7.2	3.9	-6.9	84.3	-11.1	86.5	-15.2	88.7	-20.5	91.5	(4)
(5)			WB	-2.2	71.0	7.2	2.1	-7.3	72.5	-11.5	73.7	-15.6	74.9	-20.8	76.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	44.6	28.3	27.1	31.6	40.8	50.4	58.5	63.5	62.2	55.4	45.5	38.1	32.6	(6)	
	DBStd	14.36	7.51	9.80	6.50	6.48	7.05	5.33	5.09	4.76	5.36	5.71	6.71	7.44	(7)	
	HDD50	3324	673	641	572	286	79	2	0	0	16	157	358	540	(8)	
	HDD65	7530	1138	1061	1037	725	454	207	90	114	287	604	808	1005	(9)	
	CDD50	1354	0	0	0	11	91	256	420	379	179	18	0	0	(10)	
	CDD65	87	0	0	0	0	2	11	45	28	1	0	0	0	(11)	
	CDH74	419	0	0	0	0	18	43	255	103	0	0	0	0	(12)	
	CDH80	43	0	0	0	0	1	32	9	0	0	0	0	0	(13)	
	WSAvg	9.5	10.3	9.8	9.7	9.3	9.0	9.1	8.6	8.3	9.0	9.8	10.2	11.1	(14)	
(15) Precipitation	PrecAvg	23.9	1.9	1.5	1.3	1.2	1.3	2.1	2.2	3.0	2.4	2.6	2.2	2.1	(15)	
	PrecMax	30.9	3.5	2.9	2.7	2.2	2.5	4.0	5.1	5.4	5.0	4.5	4.4	3.8	(16)	
	PrecMin	17.9	0.5	0.4	0.3	0.2	0.4	0.4	0.1	0.5	0.6	0.4	0.3	1.1	(17)	
	PrecStd	3.6	0.8	0.6	0.6	0.6	0.6	1.0	1.4	1.6	1.1	1.2	1.2	0.7	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.6	42.6	48.2	64.9	76.7	78.7	83.9	80.8	69.7	59.3	51.5	46.8	(19)	
		MCWB	42.2	39.2	41.3	52.3	61.8	64.3	68.2	68.3	61.9	54.8	49.1	45.3	(20)	
	2%	DB	40.0	39.5	44.4	59.3	71.2	74.6	80.2	76.7	67.6	57.0	49.6	44.9	(21)	
		MCWB	39.0	37.5	39.5	49.7	59.3	64.0	67.9	66.6	61.3	54.0	48.1	43.6	(22)	
	5%	DB	38.7	37.8	41.4	55.5	66.6	71.2	76.9	73.8	65.8	55.2	48.2	43.0	(23)	
		MCWB	37.8	36.4	37.9	47.5	56.3	61.9	67.0	65.5	60.5	52.5	47.0	42.0	(24)	
	10%	DB	37.3	36.8	39.3	51.7	62.7	68.0	73.5	71.3	63.0	53.6	46.5	41.2	(25)	
		MCWB	36.5	35.8	37.0	45.6	54.8	60.5	64.8	63.7	58.9	51.1	45.5	40.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.5	39.6	42.2	54.5	64.5	67.5	72.1	71.5	64.0	56.3	49.5	45.9	(27)	
		MCDB	42.6	41.1	45.4	63.4	72.4	73.7	78.9	78.2	67.3	58.3	50.2	46.3	(28)	
	2%	WB	39.3	37.8	40.1	50.7	60.9	65.2	69.7	68.2	62.7	54.7	48.2	43.8	(29)	
		MCDB	39.5	38.9	42.7	57.6	67.9	72.0	76.9	74.4	66.1	56.6	48.8	44.4	(30)	
	5%	WB	37.5	36.9	38.6	48.5	58.1	63.2	67.8	66.5	61.2	53.2	46.8	41.8	(31)	
		MCDB	38.0	37.7	40.6	54.3	65.2	68.8	74.9	72.1	64.4	54.8	47.5	42.5	(32)	
	10%	WB	36.3	35.7	37.1	45.9	55.0	61.4	65.7	64.9	59.7	51.8	45.3	40.3	(33)	
		MCDB	36.9	36.4	38.8	50.6	61.5	66.9	71.9	69.9	62.7	53.5	46.0	40.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.3	8.4	9.9	12.0	14.9	12.8	13.3	13.1	10.9	8.8	6.7	6.7	(35)	
		MCDBR	5.9	7.5	11.8	19.1	21.1	17.5	18.0	16.0	13.1	9.7	6.6	6.2	(36)	
		MCWBR	5.5	6.7	8.4	11.1	11.5	9.8	8.9	8.7	9.1	7.5	6.6	6.4	(37)	
	5% WB	MCDBR	5.5	7.2	10.4	16.8	18.9	15.0	15.9	13.7	11.6	8.5	6.5	5.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.293	0.318	0.340	0.376	0.369	0.368	0.397	0.391	0.359	0.342	0.328	0.288	(40)	
		taud	2.197	2.230	2.278	2.311	2.413	2.454	2.394	2.403	2.472	2.407	2.239	2.157	(41)	
	Ebn at Noon		169	222	254	264	274	276	264	257	248	215	153	130	(42)	
		Edh at Noon	16	24	30	35	33	32	34	31	25	20	15	12	(43)	
(44) All-Sky Solar Radiation	RadAvg		100	287	769	1281	1794	1891	1769	1393	882	404	119	67	(44)	
	RadStd		18	53	84	146	159	105	139	123	104	51	23	8	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (34 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page