

KURESSAARE-ROOMASSAARE, Estonia

WMO: 262150

Lat: 58.2181N

Lon: 22.5064E

Elev: 3

StdP: 101.29

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-16.3	-12.8	-18.6	0.7	-16.2	-15.1	1.0	-11.9	12.1	-0.8	10.9	-0.8	2.7	30	0.646

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.4	25.9	19.3	24.1	18.6	22.5	17.7	20.5	24.3	19.4	22.9	18.4	21.6	4.3	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.0	13.8	22.8	18.0	12.9	21.4	17.1	12.2	20.3	58.7	24.4	55.1	22.9	52.1	21.3	23.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.6	9.3	8.4	DB	-18.7	27.5	4.0	2.1	-21.6	29.1	-24.0	30.3	-26.2	31.5	-29.1	33.1	(4)
(5)			WB	-19.0	21.6	4.0	1.2	-21.8	22.5	-24.2	23.2	-26.4	23.9	-29.3	24.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	7.0	-2.1	-2.7	-0.2	4.9	10.2	14.7	17.5	16.8	13.0	7.5	3.4	0.3	(6)
(7)		DBStd	7.98	4.17	5.44	3.61	3.60	3.91	2.96	2.83	2.64	2.98	3.17	3.73	4.13	(7)
(8)		HDD10.0	1847	374	356	318	159	44	1	0	0	9	87	199	300	(8)
(9)		HDD18.3	4183	632	589	576	403	252	115	50	63	159	336	449	558	(9)
(10)		CDD10.0	752	0	0	0	6	51	142	233	211	99	10	0	0	(10)
(11)		CDD18.3	48	0	0	0	0	1	6	25	16	1	0	0	0	(11)
(12)		CDH23.3	233	0	0	0	0	10	24	142	57	0	0	0	0	(12)
(13)		CDH26.7	24	0	0	0	0	1	1	18	5	0	0	0	0	(13)
(14)	Wind	WSAvg	4.3	4.6	4.4	4.3	4.2	4.0	4.1	3.8	3.7	4.0	4.4	4.6	5.0	(14)
(15)	Precipitation	PrecAvg	607	47	38	34	31	34	54	56	75	60	67	57	53	(15)
(16)		PrecMax	784	88	74	69	55	64	101	129	136	127	114	112	97	(16)
(17)		PrecMin	455	12	11	7	6	9	10	2	12	15	10	7	27	(17)
(18)		PrecStd	92	20	15	16	16	14	26	35	40	29	31	30	17	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.9	5.9	9.0	18.3	24.8	25.9	28.8	27.1	20.9	15.2	10.8	8.2	(19)
(20)			MCWB	5.6	4.0	5.2	11.3	16.6	17.9	20.1	20.2	16.6	12.7	9.5	7.4	(20)
(21)		2%	DB	4.4	4.2	6.9	15.2	21.8	23.7	26.8	24.8	19.8	13.9	9.8	7.2	(21)
(22)			MCWB	3.9	3.0	4.2	9.8	15.2	17.8	20.0	19.2	16.3	12.2	9.0	6.4	(22)
(23)		5%	DB	3.7	3.2	5.2	13.0	19.2	21.8	24.9	23.2	18.8	12.9	9.0	6.1	(23)
(24)			MCWB	3.2	2.4	3.3	8.6	13.5	16.6	19.4	18.6	15.8	11.4	8.3	5.5	(24)
(25)		10%	DB	2.9	2.7	4.0	10.9	17.0	20.0	23.0	21.8	17.2	12.0	8.1	5.1	(25)
(26)			MCWB	2.5	2.1	2.8	7.5	12.7	15.8	18.2	17.6	14.9	10.6	7.5	4.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.8	4.2	5.7	12.5	18.1	19.7	22.3	21.9	17.8	13.5	9.7	7.7	(27)
(28)			MCDWB	5.9	5.1	7.5	17.5	22.5	23.2	26.0	25.7	19.6	14.6	10.1	7.9	(28)
(29)		2%	WB	4.0	3.2	4.5	10.4	16.1	18.5	21.0	20.1	17.1	12.6	9.0	6.6	(29)
(30)			MCDWB	4.2	3.8	6.0	14.2	20.0	22.2	25.0	23.5	19.0	13.7	9.4	6.9	(30)
(31)		5%	WB	3.1	2.7	3.7	9.2	14.5	17.3	19.9	19.2	16.2	11.8	8.2	5.4	(31)
(32)			MCDWB	3.3	3.2	4.8	12.4	18.4	20.4	23.8	22.3	18.0	12.7	8.6	5.8	(32)
(33)		10%	WB	2.4	2.1	2.9	7.7	12.8	16.3	18.7	18.3	15.4	11.0	7.4	4.6	(33)
(34)			MCDWB	2.7	2.5	3.8	10.3	16.4	19.4	22.2	21.0	17.0	11.9	7.8	5.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.1	4.7	5.5	6.7	8.3	7.1	7.4	7.3	6.1	4.9	3.7	3.7	(35)
(36)			MCDBR	3.3	4.2	6.6	10.6	11.7	9.7	10.0	8.9	7.3	5.4	3.7	3.5	(36)
(37)			MCWBR	3.1	3.7	4.7	6.2	6.4	5.4	4.9	4.8	5.0	4.2	3.7	3.5	(37)
(38)		5% WB	MCDWB	3.1	4.0	5.8	9.3	10.5	8.3	8.8	7.6	6.4	4.7	3.6	3.2	(38)
(39)			MCWBR	3.0	3.7	4.5	5.9	6.0	5.2	4.9	4.6	4.9	4.2	3.7	3.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.293	0.318	0.340	0.376	0.369	0.368	0.397	0.391	0.359	0.342	0.328	0.288	(40)	
(41)		taud	2.197	2.230	2.278	2.311	2.413	2.454	2.394	2.403	2.472	2.407	2.239	2.157	(41)	
(42)		Ebn at Noon	534	701	800	831	865	870	832	809	782	678	482	409	(42)	
(43)		Edh at Noon	49	75	95	109	105	102	107	99	79	64	48	37	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.32	0.91	2.42	4.04	5.66	5.96	5.58	4.39	2.78	1.27	0.37	0.21	(44)	
(45)		RadStd	0.06	0.17	0.26	0.46	0.50	0.33	0.44	0.39	0.33	0.16	0.07	0.03	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (34 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Nomenclature: See separate page