

SORVE, Estonia

WMO: 262180

Lat: 57.9136N

Lon: 22.0578E

Elev: 13

StdP: 14.69

Time Zone: 2.00 (EUE)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	9.3	13.7	4.3	6.9	10.8	8.5	8.5	15.5	34.5	32.3	32.4	31.2	12.6	20	0.724

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.3	75.5	68.5	73.1	66.8	70.8	65.0	69.8	74.3	67.8	72.0	65.9	69.9	9.9	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.0	103.0	73.1	66.0	95.8	70.9	64.1	89.5	68.9	33.8	74.4	32.2	72.1	30.7	70.1	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 33.7	30.0	27.0	6.3	78.2	7.8	3.1	0.7	80.4	-3.8	82.2	-8.2	83.9	-13.8	86.1		
(5)			5.4	70.8	6.9	2.6	0.4	72.7	-3.7	74.3	-7.5	75.7	-12.6	77.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	45.6	29.5	28.5	32.5	40.0	50.2	57.7	64.0	63.8	56.9	47.6	40.6	35.3
	DBStd	13.70	7.78	7.68	5.66	4.86	5.90	4.55	4.73	4.02	4.52	5.74	5.54	6.97
	HDD50	3013	635	602	544	300	68	2	0	0	8	114	283	457
	HDD65	7151	1100	1022	1009	749	460	223	77	70	245	541	733	922
	CDD50	1422	0	0	0	2	74	232	435	427	213	39	0	0
	CDD65	84	0	0	0	0	1	3	47	32	1	0	0	0
	CDH74	135	0	0	0	0	0	3	96	36	0	0	0	0
	CDH80	3	0	0	0	0	0	0	3	0	0	0	0	0
Wind	WSAvg	13.2	14.8	13.6	12.9	12.0	11.3	11.8	10.8	11.7	13.0	15.0	15.3	16.9
Precipitation	PrecAvg	23.4	1.7	1.3	1.2	1.1	1.4	2.0	2.5	3.0	2.0	2.6	2.6	1.9
	PrecMax	32.9	3.9	2.6	2.4	2.4	2.7	4.6	4.7	6.5	3.5	4.8	4.4	3.7
	PrecMin	11.5	0.4	0.2	0.3	0.2	0.4	0.4	0.5	0.1	0.3	0.3	0.5	0.6
	PrecStd	4.6	0.8	0.6	0.6	0.6	0.6	0.9	1.3	1.7	0.9	1.1	1.1	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.6	40.5	44.7	57.9	71.2	72.7	79.4	77.6	68.7	59.4	51.3	47.9
		MCWB	42.5	38.6	40.3	48.3	60.5	63.1	69.5	69.7	62.0	56.0	49.3	46.2
	2%	DB	42.2	39.0	41.5	52.9	65.4	69.3	76.7	74.5	66.0	57.6	49.9	46.3
		MCWB	40.9	37.7	38.7	45.9	57.0	61.4	69.5	68.0	60.8	54.9	48.3	44.6
	5%	DB	40.5	38.0	40.0	49.5	61.9	66.8	74.4	72.1	64.3	56.3	48.7	44.8
		MCWB	39.1	36.8	37.8	44.3	55.8	60.5	68.1	66.1	60.2	54.0	46.9	43.2
	10%	DB	38.8	36.7	38.7	46.8	58.9	64.9	72.3	70.2	62.8	55.0	47.5	43.1
		MCWB	37.4	35.7	36.9	42.5	53.6	59.6	66.7	64.7	59.1	52.8	45.7	41.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.0	39.5	41.2	49.8	62.2	65.7	72.5	71.5	63.7	57.1	50.0	46.7
		MCDB	43.3	40.0	43.7	55.8	68.8	70.1	76.5	75.4	66.9	58.3	50.8	47.4
	2%	WB	41.3	38.0	39.3	46.6	58.7	63.4	70.6	69.3	62.3	55.7	48.6	45.0
		MCDB	42.0	38.7	40.8	51.8	63.1	67.4	75.1	73.4	64.8	57.0	49.6	46.1
	5%	WB	39.3	37.0	38.3	44.7	56.7	61.7	68.9	67.2	60.9	54.4	47.3	43.2
		MCDB	40.2	37.7	39.6	48.6	61.3	65.6	73.5	70.8	63.4	55.9	48.4	44.3
	10%	WB	37.6	35.9	37.3	43.0	54.1	60.3	67.1	65.6	59.6	53.1	46.0	41.8
		MCDB	38.7	36.7	38.5	46.3	58.2	64.0	71.7	69.1	62.3	54.7	47.1	42.9
Mean Daily Temperature Range	5% DB	MDBR	5.5	5.6	6.2	7.7	8.8	8.4	8.3	7.7	6.8	5.9	4.8	4.9
		MCDBR	4.5	4.2	7.0	12.5	13.5	11.7	10.8	9.4	8.1	5.6	4.8	3.9
		MCWBR	4.7	3.9	5.6	7.6	7.8	6.7	6.5	6.1	6.0	5.0	5.1	4.3
	5% WB	MCDBR	4.6	4.2	6.7	11.3	12.2	10.0	9.6	7.4	6.8	5.1	4.6	3.9
		MCWBR	4.9	4.1	5.6	7.4	7.6	6.6	6.5	5.7	5.8	5.1	5.0	4.5
Clear-Sky Solar Irradiance	taub	0.297	0.322	0.342	0.376	0.370	0.369	0.398	0.392	0.360	0.344	0.329	0.292	
	taud	2.219	2.257	2.303	2.321	2.416	2.463	2.401	2.410	2.476	2.411	2.249	2.172	
	Ebn at Noon	172	224	254	264	274	276	264	257	249	216	156	134	
	Edh at Noon	16	24	30	34	33	32	34	31	25	21	16	12	
All-Sky Solar Radiation	RadAvg	102	292	768	1312	1813	1923	1802	1420	910	416	126	68	
	RadStd	18	50	89	147	154	102	145	120	108	53	23	9	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (26 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page