

SORVE, Estonia

WMO: 262180

Lat: 57.9136N

Lon: 22.0578E

Elev: 4

StdP: 101.28

Time Zone: 2.00 (EUE)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-12.6	-10.2	-15.4	1.0	-11.8	-13.1	1.2	-9.2	15.4	0.1	14.5	-0.5	5.6	20	0.724

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.6	24.1	20.3	22.8	19.3	21.6	18.4	21.0	23.5	19.9	22.2	18.8	21.1	4.4	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.0	14.7	22.8	18.9	13.7	21.6	17.8	12.8	20.5	60.8	23.6	56.9	22.3	53.5	21.2	24.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.1	13.4	12.1	-14.3	25.7	4.3	1.7	-17.4	26.9	-19.9	27.9	-22.3	28.8	-25.4	30.1		
(5)			-14.8	21.6	3.8	1.5	-17.6	22.6	-19.8	23.5	-22.0	24.3	-24.8	25.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	7.6	-1.4	-1.9	0.3	4.5	10.1	14.3	17.8	17.7	13.8	8.6	4.8	1.8	(6)
(7)		DBStd	7.61	4.32	4.27	3.14	2.70	3.28	2.53	2.63	2.24	2.51	3.19	3.08	3.87	(7)
(8)		HDD10.0	1674	353	334	302	167	38	1	0	0	4	63	157	254	(8)
(9)		HDD18.3	3973	611	568	561	416	256	124	43	39	136	301	407	512	(9)
(10)		CDD10.0	790	0	0	0	1	41	129	242	237	118	22	0	0	(10)
(11)		CDD18.3	47	0	0	0	0	1	2	26	18	1	0	0	0	(11)
(12)		CDH23.3	75	0	0	0	0	0	2	53	20	0	0	0	0	(12)
(13)		CDH26.7	2	0	0	0	0	0	0	2	0	0	0	0	0	(13)
(14)	Wind	WSAvg	5.9	6.6	6.1	5.8	5.4	5.0	5.3	4.8	5.2	5.8	6.7	6.8	7.5	(14)
(15)	Precipitation	PrecAvg	594	44	34	31	28	35	52	64	75	52	66	65	48	(15)
(16)		PrecMax	836	98	65	60	60	69	117	119	165	89	122	113	95	(16)
(17)		PrecMin	293	10	5	8	6	11	9	12	3	8	8	12	16	(17)
(18)		PrecStd	117	21	15	16	15	14	22	34	43	22	28	28	19	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.4	4.7	7.0	14.4	21.8	22.6	26.3	25.3	20.4	15.2	10.7	8.8	(19)
(20)			MCWB	5.8	3.7	4.6	9.1	15.8	17.3	20.9	20.9	16.6	13.4	9.6	7.9	(20)
(21)		2%	DB	5.7	3.9	5.3	11.6	18.6	20.7	24.8	23.6	18.9	14.2	10.0	7.9	(21)
(22)			MCWB	5.0	3.1	3.7	7.7	13.9	16.3	20.8	20.0	16.0	12.7	9.1	7.0	(22)
(23)		5%	DB	4.7	3.3	4.5	9.7	16.6	19.3	23.6	22.3	18.0	13.5	9.3	7.1	(23)
(24)			MCWB	3.9	2.7	3.2	6.8	13.2	15.9	20.1	18.9	15.7	12.2	8.3	6.2	(24)
(25)		10%	DB	3.8	2.6	3.7	8.2	14.9	18.3	22.4	21.2	17.1	12.8	8.6	6.1	(25)
(26)			MCWB	3.0	2.1	2.7	5.8	12.0	15.3	19.3	18.2	15.0	11.5	7.6	5.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.1	4.1	5.1	9.9	16.8	18.7	22.5	21.9	17.6	13.9	10.0	8.2	(27)
(28)			MCDWB	6.3	4.4	6.5	13.2	20.4	21.1	24.7	24.1	19.4	14.6	10.4	8.6	(28)
(29)		2%	WB	5.2	3.4	4.0	8.1	14.8	17.4	21.4	20.7	16.8	13.2	9.2	7.2	(29)
(30)			MCDWB	5.6	3.7	4.9	11.0	17.3	19.7	23.9	23.0	18.2	13.9	9.8	7.8	(30)
(31)		5%	WB	4.1	2.8	3.5	7.1	13.7	16.5	20.5	19.6	16.1	12.5	8.5	6.2	(31)
(32)			MCDWB	4.6	3.2	4.2	9.2	16.3	18.6	23.1	21.6	17.5	13.3	9.1	6.9	(32)
(33)		10%	WB	3.1	2.2	2.9	6.1	12.3	15.7	19.5	18.6	15.3	11.7	7.8	5.4	(33)
(34)			MCDWB	3.7	2.6	3.6	7.9	14.6	17.8	22.1	20.6	16.8	12.6	8.4	6.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	3.0	3.1	3.4	4.3	4.9	4.7	4.6	4.3	3.8	3.3	2.7	2.7	(35)
(36)			MCDBR	2.5	2.3	3.9	7.0	7.5	6.5	6.0	5.2	4.5	3.1	2.6	2.2	(36)
(37)			MCWBR	2.6	2.2	3.1	4.2	4.4	3.7	3.6	3.4	3.3	2.8	2.8	2.4	(37)
(38)		5% WB	MCDWB	2.6	2.3	3.7	6.3	6.8	5.6	5.4	4.1	3.8	2.8	2.5	2.2	(38)
(39)			MCWBR	2.7	2.3	3.1	4.1	4.2	3.7	3.6	3.2	3.2	2.8	2.8	2.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.297	0.322	0.342	0.376	0.370	0.369	0.398	0.392	0.360	0.344	0.329	0.292	(40)	
(41)		taud	2.219	2.257	2.303	2.321	2.416	2.463	2.401	2.410	2.476	2.411	2.249	2.172	(41)	
(42)		Ebn at Noon	542	706	802	832	865	870	832	810	784	681	492	421	(42)	
(43)		Edh at Noon	49	75	93	108	105	102	106	98	80	65	49	38	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.32	0.92	2.42	4.14	5.71	6.06	5.68	4.47	2.87	1.31	0.40	0.21	(44)	
(45)		RadStd	0.06	0.16	0.28	0.46	0.49	0.32	0.46	0.38	0.34	0.17	0.07	0.03	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (26 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page