

KIHNU, Estonia

WMO: 262260

Lat: 58.0986N

Lon: 23.9703E

Elev: 13

StdP: 14.69

Time Zone: 2.00 (EUE)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	1.6	8.3	-3.1	4.7	2.6	3.1	6.5	9.6	32.7	35.5	30.1	32.7	7.7	50	0.657

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.9	78.7	69.1	75.7	67.8	72.8	65.7	70.8	76.9	68.7	74.4	66.7	71.8	6.0	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.3	104.1	75.3	66.4	97.1	72.6	64.6	91.1	70.5	34.6	77.1	32.9	74.5	31.3	71.9	76.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 30.7	27.6	25.1	DB	0.4	82.5	9.2	3.5	-6.2	85.0	-11.6	87.1	-16.8	89.1	-23.5	91.7	(4)
(5)			WB	-0.5	72.4	8.5	2.5	-6.6	74.3	-11.6	75.7	-16.4	77.1	-22.7	79.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	45.3	27.3	25.9	30.9	40.0	51.9	59.0	65.6	64.8	56.9	46.8	39.2	33.7
	DBStd	15.27	9.62	9.05	6.45	6.05	7.07	5.26	5.20	4.50	4.89	6.40	6.15	7.81
	HDD50	3306	704	674	592	306	56	1	0	0	9	136	323	505
	HDD65	7337	1169	1094	1057	749	410	195	54	57	244	565	773	970
	CDD50	1588	0	0	0	7	116	270	484	459	216	36	0	0
	CDD65	142	0	0	0	0	5	14	72	50	1	0	0	0
	CDH74	462	0	0	0	0	24	43	279	116	0	0	0	0
	CDH80	60	0	0	0	0	2	3	44	11	0	0	0	0
Wind	WSAvg	11.4	13.4	11.9	10.4	9.2	8.6	9.8	9.0	10.6	11.4	12.8	14.2	15.9
Precipitation	PrecAvg	24.2	1.9	1.5	1.3	1.3	1.5	2.3	2.6	2.8	2.0	2.7	2.3	2.1
	PrecMax	35.0	4.1	3.3	2.4	3.0	3.3	4.8	5.5	7.1	4.1	5.0	4.2	5.3
	PrecMin	13.5	0.4	0.3	0.3	0.3	0.2	0.4	0.3	0.0	0.2	0.4	0.1	0.6
	PrecStd	4.7	0.9	0.7	0.6	0.8	0.8	1.2	1.3	1.7	1.0	1.2	1.1	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.3	38.5	48.3	64.0	77.4	79.4	84.8	81.3	69.8	59.2	50.2	46.6
		MCWB	41.0	37.3	40.1	51.0	64.5	66.3	71.2	70.8	63.5	56.5	48.5	45.1
	2%	DB	41.0	36.9	41.8	56.2	71.1	73.5	80.2	77.0	66.9	57.8	48.8	45.0
		MCWB	40.1	35.8	38.2	46.9	60.0	64.6	70.0	69.2	61.4	55.2	47.0	43.7
	5%	DB	39.3	35.9	38.9	52.5	66.8	69.8	76.8	74.2	64.9	56.5	47.6	43.5
		MCWB	38.0	34.9	36.5	45.0	58.4	62.6	68.7	67.3	60.2	54.1	45.8	42.2
	10%	DB	37.3	35.0	37.2	48.7	62.5	66.9	74.1	71.7	63.3	54.9	46.5	41.9
		MCWB	36.1	34.2	35.3	43.2	55.8	61.1	67.4	65.4	59.1	52.8	44.9	40.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.4	37.6	41.4	51.7	65.2	68.4	73.5	72.9	64.3	57.4	48.9	45.6
		MCDB	42.0	37.9	46.2	62.1	73.5	75.4	81.2	78.5	68.3	58.7	49.7	46.2
	2%	WB	40.1	36.1	38.6	48.2	62.3	66.0	71.5	70.4	62.6	55.7	47.5	43.9
		MCDB	40.7	36.5	41.4	55.0	68.6	71.3	77.8	75.9	65.7	57.1	48.4	44.6
	5%	WB	38.2	35.3	37.0	45.8	59.3	63.6	69.6	68.1	61.1	54.4	46.3	42.2
		MCDB	39.1	35.8	38.4	50.9	65.4	69.1	75.8	72.8	64.1	55.9	47.3	43.3
	10%	WB	36.4	34.3	35.7	43.7	56.4	61.4	67.9	66.3	59.6	53.2	45.1	40.7
		MCDB	37.3	34.9	36.8	48.0	61.7	66.2	73.6	70.7	62.6	54.8	46.3	41.7
Mean Daily Temperature Range	5% DB	MDBR	6.1	6.3	7.2	8.5	9.9	8.4	8.9	8.4	7.1	6.1	4.8	4.8
		MCDBR	4.1	3.4	8.6	15.9	17.7	13.5	14.0	11.9	9.0	5.3	4.2	3.5
		MCWBR	4.2	3.4	6.0	8.5	8.8	7.1	6.4	6.5	6.1	4.8	4.6	3.8
	5% WB	MCDBR	4.2	3.3	7.6	14.1	15.8	12.1	12.5	10.3	7.0	4.6	3.9	3.3
		MCWBR	4.3	3.4	5.4	8.2	8.6	7.1	6.5	6.6	5.8	4.8	4.4	3.6
Clear-Sky Solar Irradiance	taub	0.291	0.315	0.340	0.376	0.371	0.370	0.400	0.395	0.362	0.342	0.329	0.287	
	taud	2.179	2.188	2.213	2.292	2.404	2.449	2.388	2.399	2.465	2.410	2.243	2.162	
	Ebn at Noon	170	223	253	263	274	275	263	256	247	216	154	132	
	Edh at Noon	16	25	32	35	34	33	34	31	25	20	15	12	
All-Sky Solar Radiation	RadAvg	108	309	775	1274	1751	1831	1726	1362	868	401	122	70	
	RadStd	22	58	94	142	164	116	146	127	100	54	21	10	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (40 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page