

KIHNU, Estonia

WMO: 262260

Lat: 58.0986N

Lon: 23.9703E

Elev: 4

StdP: 101.28

Time Zone: 2.00 (EUE)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-16.9	-13.2	-19.5	0.7	-16.3	-16.0	0.9	-12.5	14.6	1.9	13.5	0.4	3.5	50	0.657

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.0	26.0	20.6	24.3	19.9	22.7	18.7	21.5	24.9	20.4	23.6	19.3	22.1	2.7	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.2	14.9	24.0	19.1	13.9	22.6	18.1	13.0	21.4	62.7	25.0	58.6	23.6	55.0	22.2	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
(4) 13.7	12.3	11.2		-17.5	28.0	5.1	2.0	-21.2	29.5	-24.2	30.6	-27.1	31.7	-30.8		
(5)				-18.1	22.5	4.7	1.4	-21.5	23.5	-24.2	24.3	-26.9	25.1	-30.4	26.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.4	-2.6	-3.4	-0.6	4.5	11.1	15.0	18.7	18.2	13.8	8.2	4.0	1.0
	DBStd	8.48	5.34	5.03	3.58	3.36	3.93	2.92	2.89	2.50	2.71	3.55	3.42	4.34
	HDD10.0	1837	391	374	329	170	31	1	0	0	5	76	179	281
	HDD18.3	4076	649	608	587	416	228	108	30	32	136	314	429	539
	CDD10.0	882	0	0	0	4	64	150	269	255	120	20	0	0
	CDD18.3	79	0	0	0	0	3	8	40	28	1	0	0	0
	CDH23.3	257	0	0	0	0	13	24	155	64	0	0	0	0
	CDH26.7	33	0	0	0	0	1	2	24	6	0	0	0	0
(14) Wind	WSAvg	5.1	6.0	5.3	4.7	4.1	3.9	4.4	4.0	4.7	5.1	5.7	6.4	7.1
(15) Precipitation	PrecAvg	614	47	37	32	33	37	58	65	72	52	68	59	53
	PrecMax	890	105	83	60	77	83	121	140	181	105	128	106	135
	PrecMin	343	9	7	7	7	6	10	8	1	5	11	2	16
	PrecStd	119	24	17	16	21	20	30	34	44	25	30	28	25
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.7	3.6	9.1	17.8	25.2	26.3	29.3	27.4	21.0	15.1	10.1	8.1
		MCWB	5.0	2.9	4.5	10.6	18.1	19.0	21.8	21.6	17.5	13.6	9.2	7.3
	2%	DB	5.0	2.7	5.4	13.5	21.7	23.1	26.8	25.0	19.4	14.3	9.3	7.2
		MCWB	4.5	2.1	3.4	8.3	15.6	18.1	21.1	20.6	16.3	12.9	8.3	6.5
	5%	DB	4.1	2.2	3.8	11.4	19.3	21.0	24.9	23.4	18.3	13.6	8.6	6.4
		MCWB	3.3	1.6	2.5	7.2	14.7	17.0	20.4	19.6	15.7	12.3	7.7	5.7
	10%	DB	3.0	1.7	2.9	9.3	17.0	19.4	23.4	22.0	17.4	12.7	8.1	5.5
		MCWB	2.3	1.2	1.8	6.2	13.2	16.2	19.7	18.5	15.1	11.6	7.2	4.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.2	3.1	5.2	10.9	18.5	20.2	23.0	22.7	18.0	14.1	9.4	7.6
		MCDB	5.5	3.3	7.9	16.7	23.1	24.1	27.3	25.8	20.2	14.8	9.8	7.9
	2%	WB	4.5	2.3	3.7	9.0	16.8	18.9	21.9	21.4	17.0	13.2	8.6	6.6
		MCDB	4.9	2.5	5.2	12.8	20.3	21.8	25.4	24.4	18.7	13.9	9.1	7.0
	5%	WB	3.4	1.8	2.8	7.6	15.2	17.6	20.9	20.0	16.2	12.5	7.9	5.7
		MCDB	3.9	2.1	3.5	10.5	18.5	20.6	24.3	22.7	17.9	13.3	8.5	6.3
	10%	WB	2.4	1.3	2.1	6.5	13.6	16.3	19.9	19.0	15.4	11.8	7.3	4.8
		MCDB	2.9	1.6	2.7	8.9	16.5	19.0	23.1	21.5	17.0	12.7	8.0	5.4
(35) Mean Daily Temperature Range	5% DB	MDBR	3.4	3.5	4.0	4.7	5.5	4.7	5.0	4.6	3.9	3.4	2.6	2.7
		MCDBR	2.3	1.9	4.8	8.8	9.9	7.5	7.8	6.6	5.0	3.0	2.4	2.0
		MCWBR	2.3	1.9	3.3	4.7	4.9	4.0	3.6	3.6	3.4	2.6	2.6	2.1
	5% WB	MCDBR	2.3	1.9	4.2	7.8	8.8	6.7	7.0	5.7	3.9	2.6	2.2	1.8
		MCWBR	2.4	1.9	3.0	4.6	4.8	3.9	3.6	3.7	3.2	2.7	2.4	2.0
(40) Clear-Sky Solar Irradiance	taub		0.291	0.315	0.340	0.376	0.371	0.370	0.400	0.395	0.362	0.342	0.329	0.287
	taud		2.179	2.188	2.213	2.292	2.404	2.449	2.388	2.399	2.465	2.410	2.243	2.162
	Ebn at Noon		537	703	797	830	864	868	829	806	779	680	485	417
	Edh at Noon		50	78	101	111	106	103	107	99	80	64	48	38
(44) All-Sky Solar Radiation	RadAvg		0.34	0.97	2.44	4.01	5.52	5.77	5.44	4.29	2.73	1.26	0.39	0.22
	RadStd		0.07	0.18	0.30	0.45	0.52	0.37	0.46	0.40	0.32	0.17	0.07	0.03

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (40 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page