

AINAZI, Latvia

WMO: 262290

Lat: 57.8679N

Lon: 24.3659E

Elev: 27

StdP: 14.68

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-3.4	3.3	-7.9	3.6	-2.1	-1.9	5.0	4.0	23.7	31.4	21.7	30.4	5.2	90	0.620

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.0	80.1	67.1	76.5	65.9	73.1	64.3	69.3	76.7	67.2	73.9	65.4	71.7	8.1	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.5	97.8	73.4	64.7	91.6	71.0	62.8	85.7	68.6	33.4	77.0	31.7	73.8	30.3	72.0	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.0	18.7	16.8	-8.7	84.3	8.6	2.2	-14.9	85.9	-19.9	87.2	-24.7	88.4	-30.9	90.0
			-9.4	72.5	8.5	2.3	-15.5	74.2	-20.5	75.6	-25.2	76.9	-31.4	78.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	43.5	25.6	24.9	30.5	41.6	50.0	58.2	62.8	61.4	54.1	44.7	36.6	30.0		
	DBStd	15.37	9.78	11.26	7.17	7.45	7.72	6.06	5.34	4.68	5.72	6.59	8.09	9.67		
	HDD50	3672	756	703	605	273	93	5	0	0	28	187	403	619		
	HDD65	7937	1221	1123	1070	703	468	220	106	131	328	630	853	1084		
	CDD50	1291	0	0	0	21	94	251	398	354	151	22	0	0		
	CDD65	80	0	0	0	0	5	16	39	20	0	0	0	0		
	CDH74	580	0	0	0	1	43	120	286	128	2	0	0	0		
	CDH80	88	0	0	0	0	3	18	50	17	0	0	0	0		
(14) Wind	WSAvg	8.8	9.8	9.7	8.9	8.5	7.9	7.8	7.3	7.5	8.4	9.6	10.0	10.0		
(15) Precipitation	PrecAvg	25.9	2.1	1.5	1.4	1.3	1.7	2.6	2.2	3.0	2.2	3.2	2.6	2.2		
	PrecMax	34.3	4.3	2.9	2.5	2.9	4.6	6.3	4.3	7.5	4.1	5.9	4.6	4.6		
	PrecMin	19.0	0.5	0.3	0.4	0.3	0.3	0.8	0.2	0.1	0.3	0.6	0.2	1.0		
	PrecStd	4.3	1.0	0.7	0.6	0.8	1.0	1.4	1.2	1.9	1.0	1.3	1.2	0.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.5	43.2	52.6	69.9	79.9	82.6	85.0	82.6	72.5	62.1	51.0	46.6		
		MCWB	40.4	40.2	42.4	54.9	63.5	68.0	68.7	67.0	61.0	55.2	48.7	44.7		
	2%	DB	39.2	39.9	44.6	64.7	73.9	77.7	80.8	77.4	68.3	57.8	49.4	45.2		
		MCWB	37.9	37.9	39.9	53.1	61.4	65.5	68.5	65.0	60.1	54.1	47.6	43.6		
	5%	DB	37.6	37.7	40.7	59.4	68.8	72.4	77.0	74.1	65.2	55.5	47.8	43.6		
		MCWB	36.4	36.2	37.2	49.8	57.4	63.8	67.9	64.6	59.0	52.9	46.3	42.2		
	10%	DB	36.4	36.3	38.5	54.8	63.8	68.8	73.4	70.8	63.0	53.6	46.4	41.5		
		MCWB	35.3	35.1	35.9	47.0	55.7	61.3	65.8	63.3	58.0	51.4	45.0	40.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.0	40.8	43.9	57.3	66.1	70.1	72.5	70.8	64.3	56.7	49.4	45.5		
		MCDB	41.6	42.5	48.7	67.8	76.7	78.9	80.3	77.1	68.8	59.4	50.3	46.2		
	2%	WB	38.3	38.1	40.1	53.5	62.5	67.2	70.3	67.6	61.9	54.7	47.9	44.0		
		MCDB	38.9	39.4	43.4	62.9	71.0	74.4	78.0	73.5	65.6	57.1	49.1	45.0		
	5%	WB	36.7	36.5	37.9	50.5	59.3	64.8	68.1	65.7	60.3	53.3	46.5	42.2		
		MCDB	37.3	37.6	40.2	57.8	66.8	70.8	75.2	71.8	64.1	55.3	47.6	43.4		
	10%	WB	35.5	35.3	36.4	47.8	56.2	62.2	66.3	64.0	58.7	51.7	45.0	40.4		
		MCDB	36.2	36.1	38.1	53.8	62.2	67.7	72.4	69.5	62.4	53.5	46.3	41.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.8	9.1	10.5	14.0	15.9	13.3	14.0	14.9	13.1	9.6	7.0	7.0		
		MCDBR	5.2	6.2	12.9	22.2	23.9	20.5	20.6	20.9	17.3	10.4	6.0	4.7		
	5% WB	MCWBR	4.9	5.1	8.9	12.6	12.6	11.1	10.4	10.7	10.9	7.5	5.7	4.7		
		MCWBR	5.2	6.5	10.9	20.3	20.3	17.6	17.9	17.6	13.9	8.7	5.9	4.4		
(40) Clear-Sky Solar Irradiance	taub	taub	0.290	0.315	0.341	0.378	0.372	0.371	0.401	0.397	0.363	0.343	0.329	0.286		
		taud	2.177	2.184	2.209	2.287	2.393	2.434	2.371	2.383	2.452	2.407	2.245	2.163		
	Ebn at Noon	Ebn at Noon	173	224	253	263	274	275	263	255	247	216	156	136		
		Edh at Noon	16	25	32	36	34	33	35	32	26	21	16	12		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	119	333	784	1270	1718	1789	1701	1342	862	401	126	76		
	RadStd	RadStd	26	64	104	139	167	126	149	130	94	57	19	11		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (38 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page