

AINAZI, Latvia

WMO: 262290

Lat: 57.8679N

Lon: 24.3659E

Elev: 8

StdP: 101.23

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-19.7	-16.0	-22.2	0.5	-18.9	-18.9	0.7	-15.6	10.6	-0.3	9.7	-0.9	2.3	90	0.620

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.8	26.7	19.5	24.7	18.8	22.9	18.0	20.7	24.8	19.6	23.3	18.6	22.0	3.6	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.2	14.0	23.0	18.2	13.1	21.7	17.1	12.2	20.4	59.8	25.0	55.9	23.2	52.6	22.2	25.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.4	8.4	7.5	-22.6	29.1	4.8	1.2	-26.0	29.9	-28.8	30.6	-31.5	31.3	-35.0	32.2		
(5)			-23.0	22.5	4.7	1.3	-26.4	23.5	-29.2	24.2	-31.8	24.9	-35.2	25.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	6.4	-3.5	-3.9	-0.8	5.3	10.0	14.6	17.1	16.3	12.3	7.0	2.5	-1.1		
	DBStd	8.54	5.43	6.25	3.99	4.14	4.29	3.36	2.97	2.60	3.18	3.66	4.49	5.37		
	HDD10.0	2040	420	391	336	152	52	3	0	0	16	104	224	344		
	HDD18.3	4409	678	624	594	391	260	122	59	73	182	350	474	602		
	CDD10.0	717	0	0	0	12	52	139	221	197	84	12	0	0		
	CDD18.3	44	0	0	0	0	3	9	22	11	0	0	0	0		
	CDH23.3	322	0	0	0	1	24	67	159	71	1	0	0	0		
	CDH26.7	49	0	0	0	0	2	10	28	9	0	0	0	0		
	WSAvg	3.9	4.4	4.3	4.0	3.8	3.5	3.5	3.3	3.4	3.7	4.3	4.4	4.5		
	PrecAvg	659	53	38	35	34	42	66	56	76	57	81	65	57		
(15) Precipitation	PrecMax	870	109	73	63	74	118	159	108	191	105	150	118	117		
	PrecMin	482	12	8	9	7	7	20	5	2	7	16	5	26		
	PrecStd	110	25	18	16	20	25	36	30	49	26	33	30	20		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.3	6.2	11.5	21.1	26.6	28.1	29.4	28.1	22.5	16.7	10.6	8.1		
		MCWB	4.7	4.6	5.8	12.7	17.5	20.0	20.4	19.5	16.1	12.9	9.3	7.1		
	2%	DB	4.0	4.4	7.0	18.1	23.3	25.4	27.1	25.2	20.2	14.3	9.7	7.3		
		MCWB	3.3	3.3	4.4	11.7	16.3	18.6	20.3	18.3	15.6	12.3	8.7	6.4		
	5%	DB	3.1	3.2	4.8	15.2	20.4	22.4	25.0	23.4	18.4	13.1	8.8	6.5		
		MCWB	2.4	2.3	2.9	9.9	14.1	17.7	19.9	18.1	15.0	11.6	7.9	5.7		
	10%	DB	2.4	2.4	3.6	12.6	17.7	20.5	23.0	21.6	17.2	12.0	8.0	5.3		
		MCWB	1.8	1.7	2.2	8.3	13.2	16.3	18.8	17.4	14.5	10.8	7.2	4.5		
	0.4%	WB	5.0	4.9	6.6	14.1	19.0	21.2	22.5	21.5	18.0	13.7	9.7	7.5		
		MCDB	5.3	5.9	9.3	19.9	24.8	26.1	26.8	25.0	20.4	15.2	10.2	7.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	3.5	3.4	4.5	11.9	17.0	19.5	21.3	19.8	16.6	12.6	8.8	6.7		
		MCDB	3.8	4.1	6.3	17.2	21.6	23.6	25.5	23.1	18.7	14.0	9.5	7.2		
	5%	WB	2.6	2.5	3.3	10.3	15.2	18.2	20.1	18.7	15.7	11.8	8.1	5.7		
		MCDB	3.0	3.1	4.6	14.3	19.3	21.6	24.0	22.1	17.9	13.0	8.7	6.3		
	10%	WB	1.9	1.8	2.4	8.8	13.4	16.8	19.0	17.8	14.8	10.9	7.2	4.7		
		MCDB	2.3	2.3	3.4	12.1	16.8	19.8	22.4	20.9	16.9	11.9	7.9	5.3		
	5% DB	MDBR	4.4	5.1	5.8	7.8	8.8	7.4	7.8	8.3	7.3	5.3	3.9	3.9		
		MCDBR	2.9	3.4	7.1	12.3	13.3	11.4	11.5	11.6	9.6	5.8	3.3	2.6		
		MCWBR	2.7	2.8	5.0	7.0	7.0	6.2	5.8	6.0	6.0	4.1	3.2	2.6		
		MCWBR	2.9	3.6	6.1	11.3	11.3	9.8	9.9	9.8	7.7	4.9	3.3	2.4		
(35) Mean Daily Temperature Range	5% WB	MCWBR	2.7	3.1	4.6	6.9	6.5	5.9	5.6	6.0	5.6	4.0	3.3	2.6		
	taub		0.290	0.315	0.341	0.378	0.372	0.371	0.401	0.397	0.363	0.343	0.329	0.286		
		taud	2.177	2.184	2.209	2.287	2.393	2.434	2.371	2.383	2.452	2.407	2.245	2.163		
(42) Clear-Sky Solar Irradiance	Ebn at Noon		545	706	797	829	863	867	828	805	779	682	493	428		
		Edh at Noon	51	79	102	112	107	105	109	101	82	65	49	39		
	RadAvg		0.38	1.05	2.47	4.00	5.42	5.64	5.36	4.23	2.72	1.26	0.40	0.24		
(45) All-Sky Solar Radiation	RadStd		0.08	0.20	0.33	0.44	0.53	0.40	0.47	0.41	0.30	0.18	0.06	0.04		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (38 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page