

PJARNU-SAUGA, Estonia

WMO: 262310

Lat: 58.4197N

Lon: 24.4697E

Elev: 13

StdP: 101.17

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-19.8	-15.9	-22.1	0.5	-19.4	-18.6	0.7	-15.5	11.2	1.1	10.2	1.0	1.9	80	0.600

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.8	27.5	20.0	25.7	19.1	23.9	18.1	21.2	25.7	20.1	24.3	19.0	22.7	3.2	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.5	14.3	23.7	18.5	13.3	22.3	17.5	12.5	21.3	61.3	25.6	57.5	24.3	54.0	22.6	25.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.2	8.9	7.9	DB	-21.7	30.2	4.5	1.6	-24.9	31.3	-27.5	32.2	-30.0	33.1	-33.3	34.2	(4)
(5)			WB	-22.0	23.0	4.4	1.3	-25.1	23.9	-27.7	24.7	-30.1	25.4	-33.3	26.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	6.6	-3.8	-4.2	-0.7	5.4	11.1	15.1	18.2	17.1	12.5	6.7	2.2	-1.2	(6)	
	DBStd	8.81	5.65	5.77	3.89	3.96	4.08	3.18	2.96	2.73	3.07	3.75	4.05	5.01	(7)	
	HDD10.0	2046	429	398	332	147	34	1	0	0	13	113	233	346	(8)	
	HDD18.3	4353	687	632	590	387	228	107	39	58	176	361	483	604	(9)	
	CDD10.0	802	0	0	0	10	67	155	253	219	87	11	0	0	(10)	
	CDD18.3	67	0	0	0	0	3	10	34	19	1	0	0	0	(11)	
	CDH23.3	498	0	0	0	1	37	78	263	118	1	0	0	0	(12)	
	CDH26.7	86	0	0	0	0	3	11	54	17	0	0	0	0	(13)	
(14) Wind	WSAvg	3.7	3.9	3.8	3.7	3.6	3.5	3.6	3.2	3.2	3.4	3.7	3.9	4.2	(14)	
(15) Precipitation	PrecAvg	657	42	29	34	40	39	51	74	74	71	71	74	60	(15)	
	PrecMax	992	88	74	68	135	79	130	162	193	138	187	135	129	(16)	
	PrecMin	446	4	6	4	3	4	5	20	5	31	9	23	16	(17)	
	PrecStd	130	19	14	19	27	19	28	42	46	30	46	25	24	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.8	5.2	12.2	21.2	26.8	28.1	30.3	28.9	22.7	15.8	10.1	8.2	(19)	
		MCWB	5.3	3.8	6.8	12.6	17.1	20.0	21.7	20.1	17.2	13.3	9.1	7.3	(20)	
	2%	DB	4.2	3.5	7.5	17.9	24.0	25.7	28.2	26.2	20.3	14.1	9.0	7.0	(21)	
		MCWB	3.6	2.6	4.5	10.9	15.9	18.4	20.7	19.7	16.1	12.4	8.2	6.2	(22)	
	5%	DB	3.1	2.7	5.4	15.2	21.4	23.2	26.3	24.3	18.8	12.9	8.2	5.8	(23)	
		MCWB	2.5	2.0	3.2	9.4	14.3	17.2	19.8	18.8	15.2	11.6	7.5	5.1	(24)	
	10%	DB	2.1	2.0	3.8	12.6	18.8	21.3	24.4	22.5	17.4	12.0	7.4	4.6	(25)	
		MCWB	1.6	1.4	2.1	8.0	13.0	16.1	18.9	17.8	14.6	10.8	6.7	4.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.5	4.2	7.3	13.8	19.5	21.1	23.0	22.2	18.2	13.9	9.2	7.7	(27)	
		MCDB	5.9	4.9	10.9	19.8	24.3	26.3	28.7	26.0	21.2	15.0	9.6	8.1	(28)	
	2%	WB	3.8	2.9	4.9	11.7	17.1	19.6	21.7	20.6	16.9	12.8	8.4	6.3	(29)	
		MCDB	4.1	3.3	7.2	16.7	22.4	24.1	26.7	24.6	19.4	13.7	8.8	6.8	(30)	
	5%	WB	2.5	2.1	3.6	10.0	15.2	18.1	20.6	19.5	15.9	11.9	7.6	5.2	(31)	
		MCDB	2.9	2.5	5.1	14.3	19.9	21.9	25.0	23.3	18.0	12.8	8.1	5.7	(32)	
	10%	WB	1.7	1.5	2.4	8.4	13.6	16.7	19.5	18.5	15.0	11.0	6.8	4.1	(33)	
		MCDB	2.0	1.9	3.4	11.9	18.1	20.4	23.5	21.7	16.9	11.8	7.3	4.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.5	5.2	6.4	8.5	9.8	8.7	8.8	8.7	7.5	5.6	3.8	3.8	(35)	
		MCDBR	3.5	3.9	8.4	13.2	14.1	11.9	12.0	11.5	9.4	6.1	4.0	3.4	(36)	
	5% WB	MCWBR	3.4	3.5	5.8	7.4	7.4	6.3	5.8	6.3	5.9	4.8	3.8	3.2	(37)	
		MCDWR	3.3	3.7	7.4	11.4	11.9	10.3	10.5	9.7	7.7	5.2	3.8	3.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.285	0.311	0.338	0.374	0.369	0.368	0.396	0.391	0.359	0.339	0.322	0.279	(40)	
		taud	2.156	2.177	2.229	2.304	2.391	2.424	2.366	2.377	2.450	2.404	2.232	2.137	(41)	
	Ebn at Noon		531	701	798	831	864	869	831	807	779	678	481	408	(42)	
		Edh at Noon	49	78	99	109	107	105	109	101	81	64	47	37	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.33	0.99	2.42	3.97	5.39	5.56	5.25	4.16	2.64	1.22	0.38	0.21	(44)	
	RadStd		0.07	0.19	0.30	0.44	0.54	0.40	0.50	0.42	0.30	0.17	0.06	0.03	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (44 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page