

KOLKA, Latvia

WMO: 263130

Lat: 57.7467N

Lon: 22.5891E

Elev: 6

StdP: 101.26

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-13.2	-10.3	-15.9	0.9	-12.0	-13.4	1.2	-9.2	10.7	-2.4	9.6	-3.1	3.3	230	0.588

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.6	24.4	19.6	22.9	18.8	21.6	17.9	20.6	23.4	19.5	22.2	18.5	21.0	3.0	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.4	14.2	22.5	18.4	13.2	21.5	17.3	12.4	20.3	59.3	23.5	55.7	22.2	52.3	21.1	24.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.2	8.1	7.2	DB	-15.4	26.9	4.7	2.0	-18.8	28.4	-21.5	29.6	-24.2	30.7	-27.6	32.1	(4)
(5)			WB	-15.9	21.2	4.6	1.4	-19.2	22.2	-21.9	23.0	-24.4	23.8	-27.8	24.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	7.1	-1.3	-2.1	0.1	4.4	9.3	13.9	17.2	16.8	13.1	8.0	3.8	0.8	(6)
(7)		DBStd	7.52	4.13	4.78	3.68	3.01	3.35	2.64	2.61	2.34	2.64	3.07	3.23	3.95	(7)
(8)		HDD10.0	1772	349	338	308	170	53	2	0	0	6	75	185	286	(8)
(9)		HDD18.3	4147	608	572	566	418	279	136	54	59	159	319	434	544	(9)
(10)		CDD10.0	699	0	0	0	2	32	118	223	212	97	14	0	0	(10)
(11)		CDD18.3	33	0	0	0	0	0	2	19	12	1	0	0	0	(11)
(12)		CDH23.3	93	0	0	0	0	0	5	64	24	1	0	0	0	(12)
(13)		CDH26.7	4	0	0	0	0	0	1	2	2	0	0	0	0	(13)
(14)	Wind	WSAvg	3.6	4.3	4.0	3.6	3.3	3.1	3.2	3.0	3.4	3.8	4.1	4.2	(14)	
(15)	Precipitation	PrecAvg	653	48	37	35	33	38	65	75	82	56	67	59	51	(15)
(16)		PrecMax	881	94	70	62	72	71	131	171	213	113	123	103	102	(16)
(17)		PrecMin	458	10	5	7	7	11	13	3	10	8	8	5	20	(17)
(18)		PrecStd	106	22	16	18	18	17	26	40	47	26	27	27	19	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.4	7.9	10.2	16.3	21.4	23.5	26.6	25.6	21.7	15.8	11.5	9.6	(19)
(20)			MCWB	6.2	5.7	6.2	10.5	15.1	17.4	20.7	19.7	16.7	13.5	9.8	8.3	(20)
(21)		2%	DB	5.7	5.9	7.2	13.1	18.6	21.5	25.1	23.7	19.8	14.5	10.1	8.0	(21)
(22)			MCWB	4.8	4.3	4.8	8.9	14.0	16.5	20.4	19.3	16.1	12.6	8.9	6.9	(22)
(23)		5%	DB	4.6	4.8	5.9	11.1	16.6	20.2	23.7	22.4	18.4	13.4	9.1	6.8	(23)
(24)			MCWB	3.7	3.6	4.1	7.8	12.9	16.0	19.5	18.6	15.4	11.8	7.9	5.7	(24)
(25)		10%	DB	3.6	3.7	4.7	9.2	14.9	18.8	22.3	21.2	17.2	12.5	8.2	5.7	(25)
(26)			MCWB	2.8	2.7	3.3	6.5	11.5	15.0	18.8	17.9	14.7	11.0	7.2	4.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.5	6.1	6.7	11.3	16.6	19.2	22.4	21.5	17.7	14.0	10.1	8.5	(27)
(28)			MCDWB	7.2	7.7	9.0	14.9	19.6	22.0	25.2	24.0	20.0	15.2	11.1	9.3	(28)
(29)		2%	WB	4.9	4.7	5.1	9.2	14.8	17.6	21.1	20.1	16.8	12.9	9.0	7.0	(29)
(30)			MCDWB	5.5	5.7	6.7	12.3	17.7	20.4	24.0	22.6	19.1	14.2	10.0	7.8	(30)
(31)		5%	WB	3.9	3.7	4.2	8.0	13.3	16.5	20.1	19.2	15.9	12.0	8.2	5.9	(31)
(32)			MCDWB	4.5	4.6	5.6	10.5	16.3	19.2	23.0	21.7	17.9	13.2	9.0	6.7	(32)
(33)		10%	WB	2.9	2.7	3.3	6.7	11.9	15.4	19.1	18.2	15.1	11.2	7.3	4.9	(33)
(34)			MCDWB	3.6	3.6	4.5	8.8	14.5	18.0	21.8	20.7	16.9	12.4	8.1	5.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	3.5	4.1	5.0	6.3	7.1	6.7	6.6	5.7	4.6	3.4	3.4	(35)	
(36)			MCDBR	3.8	4.4	6.5	9.9	9.6	9.2	8.3	8.2	7.5	5.5	4.0	3.4	(36)
(37)			MCWBR	3.5	3.6	4.6	6.2	5.6	5.2	4.5	4.8	4.8	4.2	3.7	3.1	(37)
(38)		5% WB	MCDWR	3.7	4.3	6.0	9.0	8.6	7.8	7.3	7.3	6.9	5.0	3.8	3.4	(38)
(39)			MCWBR	3.6	3.8	4.7	6.0	5.3	5.0	4.4	4.7	4.8	4.2	3.7	3.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.295	0.319	0.342	0.377	0.371	0.370	0.400	0.394	0.362	0.344	0.331	0.292	(40)	
(41)		taud	2.202	2.221	2.260	2.304	2.407	2.448	2.385	2.399	2.466	2.410	2.251	2.176	(41)	
(42)		Ebn at Noon	547	707	801	832	865	869	830	808	783	684	495	429	(42)	
(43)		Edh at Noon	51	77	97	110	106	103	108	100	81	65	49	39	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.35	0.97	2.46	4.04	5.61	5.90	5.55	4.38	2.81	1.31	0.40	0.23	(44)	
(45)		RadStd	0.07	0.18	0.31	0.47	0.49	0.34	0.44	0.39	0.34	0.17	0.07	0.03	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (27 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page