

STENDE, Latvia

WMO: 263180

Lat: 57.1833N

Lon: 22.5508E

Elev: 81

StdP: 100.35

Time Zone: 2.00 (EUE)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.6	-13.8	-19.3	0.7	-15.7	-16.8	0.9	-13.1	10.0	-5.5	8.8	-5.5	1.8	140	0.574

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.3	27.2	19.1	25.5	18.3	23.8	17.5	20.5	24.8	19.3	23.8	18.3	22.7	3.5	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.9	13.9	22.8	17.6	12.8	21.4	16.6	11.9	20.3	59.2	24.5	55.4	23.8	52.1	22.7	24.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.0	7.1	6.3	-20.4	30.0	3.9	1.5	-23.2	31.1	-25.5	31.9	-27.6	32.8	-30.5	33.8		
(5)			-21.0	22.7	3.4	0.8	-23.4	23.3	-25.4	23.7	-27.3	24.2	-29.7	24.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	6.7	-3.8	-2.5	0.3	6.0	11.0	14.9	17.3	16.5	12.2	6.5	2.5	-1.0	(6)
(7)		DBStd	8.37	5.13	5.37	4.27	3.99	4.47	3.58	3.15	2.92	3.13	3.68	4.12	4.87	(7)
(8)		HDD10.0	1953	427	351	301	132	39	3	0	15	120	226	340		(8)
(9)		HDD18.3	4299	685	584	559	371	229	114	58	73	185	368	475	598	(9)
(10)		CDD10.0	752	0	0	0	11	72	151	227	201	81	11	0	0	(10)
(11)		CDD18.3	58	0	0	0	0	3	12	27	16	1	0	0	0	(11)
(12)		CDH23.3	444	0	0	0	0	30	96	202	114	3	0	0	0	(12)
(13)		CDH26.7	64	0	0	0	0	2	13	34	15	0	0	0	0	(13)
(14)	Wind	WSAvg	3.1	3.5	3.6	3.5	3.3	2.9	2.7	2.6	2.5	2.8	3.2	3.4	3.5	(14)
(15)	Precipitation	PrecAvg	709	54	39	39	36	49	73	82	84	65	74	59	55	(15)
(16)		PrecMax	933	117	74	71	85	90	127	167	200	133	142	104	105	(16)
(17)		PrecMin	517	14	3	8	9	18	31	8	3	32	7	5	31	(17)
(18)		PrecStd	94	26	17	20	20	21	28	42	44	26	29	26	17	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.2	6.9	12.5	20.8	26.4	28.3	29.5	28.5	22.7	16.9	11.3	8.8	(19)
(20)			MCWB	5.6	4.7	7.5	12.2	17.5	19.8	20.5	19.9	16.4	13.0	9.5	7.8	(20)
(21)		2%	DB	4.6	5.2	9.5	18.1	23.8	25.9	27.6	26.0	20.5	14.5	9.8	7.4	(21)
(22)			MCWB	3.8	3.6	5.8	11.0	15.9	17.9	19.5	18.6	15.1	12.4	8.5	6.4	(22)
(23)		5%	DB	3.4	4.1	7.1	15.4	21.7	23.9	25.7	24.5	19.0	12.9	8.5	5.9	(23)
(24)			MCWB	2.8	3.1	4.5	9.5	14.9	17.3	19.0	17.8	14.8	11.2	7.5	5.1	(24)
(25)		10%	DB	2.4	3.2	5.5	13.0	19.4	21.9	23.6	22.7	17.4	11.8	7.6	4.9	(25)
(26)			MCWB	1.8	2.3	3.6	8.2	13.5	16.2	18.2	17.0	13.9	10.4	6.8	4.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.7	4.9	8.3	13.0	18.5	21.6	22.1	21.9	17.5	13.8	9.9	8.1	(27)
(28)			MCDWB	6.1	6.5	11.5	17.8	24.4	26.3	26.6	26.3	21.3	15.6	10.8	8.5	(28)
(29)		2%	WB	4.1	3.9	6.2	11.4	17.1	19.3	20.6	20.1	16.2	12.6	8.6	6.5	(29)
(30)			MCDWB	4.5	4.8	8.7	16.8	22.7	24.4	24.9	24.6	19.0	14.2	9.6	7.1	(30)
(31)		5%	WB	2.8	3.2	4.9	10.0	15.5	18.0	19.7	18.6	15.3	11.7	7.7	5.2	(31)
(32)			MCDWB	3.2	4.0	6.6	14.9	20.0	22.4	23.8	22.6	17.8	12.8	8.4	5.8	(32)
(33)		10%	WB	1.9	2.4	3.8	8.6	14.2	16.8	18.7	17.7	14.5	10.6	6.9	4.2	(33)
(34)			MCDWB	2.4	3.1	5.4	12.4	19.2	20.9	23.3	21.5	16.9	11.7	7.6	4.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.2	4.5	6.4	9.2	10.5	9.7	9.3	9.4	7.8	5.9	3.5	3.6	(35)
(36)			MCDBR	3.5	4.4	8.3	13.4	12.9	12.5	11.9	12.0	10.3	7.1	4.1	3.8	(36)
(37)			MCWBR	3.4	3.4	5.4	7.5	6.7	6.3	5.3	5.5	5.9	5.0	3.7	3.7	(37)
(38)		5% WB	MCDBR	3.5	4.5	7.6	12.0	11.3	10.6	10.2	10.2	8.4	6.2	4.1	3.7	(38)
(39)			MCWBR	3.5	3.6	5.4	7.1	6.3	5.9	5.1	5.5	5.3	4.8	3.9	3.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.290	0.317	0.343	0.377	0.371	0.369	0.399	0.393	0.361	0.342	0.327	0.288	(40)	
(41)		taud	2.197	2.216	2.264	2.297	2.377	2.414	2.351	2.370	2.440	2.410	2.265	2.180	(41)	
(42)		Ebn at Noon	570	719	805	834	866	871	832	811	786	694	519	457	(42)	
(43)		Edh at Noon	53	79	98	111	109	107	112	103	83	66	50	41	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.40	1.06	2.48	4.03	5.51	5.77	5.45	4.32	2.85	1.36	0.43	0.26	(44)	
(45)		RadStd	0.09	0.20	0.35	0.49	0.48	0.36	0.44	0.40	0.34	0.19	0.07	0.03	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (29 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page