

SKULTE, Latvia

WMO: 263260

Lat: 57.3006N

Lon: 24.4122E

Elev: 9

StdP: 101.22

Time Zone: 2.00 (EUE)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.4	-15.2	-21.6	0.5	-17.0	-18.7	0.7	-14.5	7.8	0.8	7.2	0.8	2.2	80	0.538

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.2	27.8	19.9	25.6	18.9	23.7	18.2	21.2	25.8	19.8	23.8	18.8	22.5	2.8	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.5	14.3	23.6	18.3	13.2	22.1	17.3	12.4	20.9	61.6	25.9	56.8	23.8	53.3	22.6	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.7	6.1	5.4	-21.8	30.6	3.7	1.1	-24.5	31.4	-26.7	32.0	-28.8	32.6	-31.5	33.4		
(5)			-21.9	23.2	3.5	1.1	-24.5	23.9	-26.5	24.6	-28.5	25.2	-31.1	25.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.0	-3.9	-2.7	0.2	5.7	11.2	15.6	18.2	17.3	13.0	7.1	2.7	-1.2		
	DBStd	8.76	5.50	5.63	4.00	4.18	4.74	3.54	3.16	2.68	3.17	3.57	4.55	5.15		
	HDD10.0	1955	432	355	303	142	42	1	0	0	11	102	218	348		
	HDD18.3	4221	691	588	561	380	227	99	40	53	160	347	468	607		
	CDD10.0	853	0	0	0	13	78	169	254	225	102	13	0	0		
	CDD18.3	76	0	0	0	0	5	16	36	19	1	0	0	0		
	CDH23.3	481	0	0	0	0	42	110	222	105	3	0	0	0		
	CDH26.7	97	0	0	0	0	4	22	56	14	0	0	0	0		
(14) Wind	WSAvg	2.7	3.0	3.0	2.8	2.6	2.4	2.5	2.4	2.4	2.7	2.9	3.0	3.1		
(15) Precipitation	PrecAvg	745	59	47	41	37	49	71	79	86	63	87	70	62		
	PrecMax	970	108	75	75	78	92	192	158	171	128	188	110	98		
	PrecMin	541	20	11	12	9	15	20	7	1	13	43	9	32		
	PrecStd	102	25	19	19	19	22	38	42	48	29	33	28	19		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.4	6.8	12.5	21.0	27.2	29.0	30.4	28.6	23.3	16.8	10.9	7.1		
		MCWB	4.5	4.4	6.7	12.1	17.4	19.4	21.6	20.8	17.2	13.1	9.5	5.7		
	2%	DB	4.2	4.8	8.6	17.7	24.1	26.6	28.4	26.1	20.8	14.7	9.7	6.1		
		MCWB	3.4	3.2	5.0	11.0	16.2	18.5	20.8	19.0	15.8	12.5	8.3	5.0		
	5%	DB	3.3	3.7	6.4	15.1	21.2	23.7	25.7	24.2	19.0	13.2	8.7	5.4		
		MCWB	2.6	2.6	4.0	9.3	14.4	18.0	20.0	18.1	15.2	11.4	7.6	4.5		
	10%	DB	2.4	2.7	4.8	12.8	19.0	21.5	23.6	22.4	17.6	12.1	7.9	4.6		
		MCWB	1.8	1.9	3.1	8.1	14.1	16.6	19.1	17.5	14.6	10.7	7.0	3.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.7	5.0	7.6	12.9	18.5	21.4	22.9	22.4	18.1	14.1	9.7	6.2		
		MCDB	5.1	6.4	11.1	18.5	25.4	26.7	27.7	26.7	21.9	15.9	10.4	6.7		
	2%	WB	3.6	3.5	5.4	11.3	17.1	19.4	21.8	20.1	16.7	12.7	8.5	5.4		
		MCDB	4.0	4.5	7.9	16.8	22.0	24.2	26.6	24.2	19.1	14.1	9.2	5.9		
	5%	WB	2.6	2.7	4.3	9.8	15.7	18.3	20.6	18.9	15.8	11.8	7.8	4.6		
		MCDB	3.1	3.5	6.0	14.2	20.0	22.6	24.9	22.6	18.3	13.0	8.6	5.3		
	10%	WB	1.9	2.0	3.4	8.4	14.3	17.2	19.5	18.0	14.9	10.8	7.0	3.9		
		MCDB	2.4	2.6	4.7	12.3	18.1	21.3	23.0	21.6	17.3	11.9	7.9	4.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.3	4.2	5.4	7.8	8.6	7.2	7.2	7.9	6.4	5.1	3.4	3.3		
		MCDBR	2.9	3.6	7.1	11.8	11.9	10.4	10.7	10.7	8.5	5.3	3.1	2.9		
	5% WB	MCWBR	2.9	2.7	4.6	6.4	5.9	5.1	4.9	5.3	5.2	3.9	3.1	2.8		
		MCWBR	3.1	3.5	6.3	10.5	10.3	8.9	9.4	8.6	7.4	4.8	3.2	3.0		
(40) Clear-Sky Solar Irradiance	taub		0.290	0.318	0.347	0.384	0.376	0.375	0.406	0.402	0.368	0.345	0.331	0.289		
		taud	2.178	2.179	2.200	2.272	2.375	2.415	2.348	2.360	2.432	2.406	2.253	2.175		
	Ebn at Noon		562	711	795	826	860	865	826	802	778	688	509	450		
		Edh at Noon	53	81	104	114	110	107	112	104	84	66	51	41		
(44) All-Sky Solar Radiation	RadAvg		0.42	1.12	2.50	4.00	5.38	5.62	5.37	4.25	2.76	1.30	0.42	0.26		
	RadStd		0.10	0.22	0.36	0.45	0.52	0.42	0.46	0.41	0.29	0.19	0.06	0.04		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (37 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page