

ALUKSNE, Latvia

WMO: 263460

Lat: 57.4396N

Lon: 27.0353E

Elev: 200

StdP: 98.95

Time Zone: 2.00 (EUE)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -21.0	(c) -17.5	(d) -23.2	(e) 0.5	(f) -20.7	(g) -20.1	(h) 0.6	(i) -16.9	(j) 7.8	(k) -0.2	(l) 7.1	(m) -0.5	(n) 1.4	(o) 100	(p) 0.558

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 8.3	(c) 26.6	(d) 18.9	(e) 24.9	(f) 17.8	(g) 23.4	(h) 17.1	(i) 20.2	(j) 24.6	(k) 19.1	(l) 23.0	(m) 18.1	(n) 22.0	(o) 2.4	(p) 110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.6	13.8	22.4	17.5	12.9	21.3	16.5	12.0	20.1	59.0	25.0	55.0	23.1	51.8	21.9	23.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 6.5	(b) 5.9	(c) 5.2	(e) -23.6	(f) 29.1	(g) 3.9	(h) 1.7	(i) -26.4	(j) 30.3	(k) -28.7	(l) 31.3	(m) -30.9	(n) 32.3	(o) -33.7	(p) 33.5		
(a) 6.5	(b) 5.9	(c) 5.2	(e) -23.8	(f) 21.5	(g) 3.8	(h) 1.0	(i) -26.6	(j) 22.3	(k) -28.8	(l) 22.9	(m) -31.0	(n) 23.4	(o) -33.8	(p) 24.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	5.8	-5.7	-5.3	-1.1	5.4	11.2	14.7	17.4	16.2	11.4	5.4	1.1	-2.3
	DBStd	9.14	6.15	6.08	4.70	4.01	4.49	3.33	3.29	3.02	3.30	3.78	4.03	4.98
	HDD10.0	2268	487	428	346	147	39	3	0	1	23	148	266	382
	HDD18.3	4643	746	661	604	387	226	116	58	81	208	401	516	641
	CDD10.0	722	0	0	0	9	75	146	229	193	65	5	0	0
	CDD18.3	56	0	0	0	0	3	8	29	15	1	0	0	0
	CDH23.3	351	0	0	0	0	24	53	185	86	2	0	0	0
	CDH26.7	46	0	0	0	0	1	4	31	11	0	0	0	0
Wind	WSAvg	2.5	2.8	2.7	2.9	2.6	2.3	2.3	2.0	2.1	2.3	2.6	2.9	3.0
Precipitation	PrecAvg	720	54	43	40	37	65	84	83	76	58	70	61	50
	PrecMax	906	98	76	87	91	109	184	183	157	107	129	103	77
	PrecMin	532	20	13	17	7	8	23	7	4	16	9	3	33
	PrecStd	99	20	15	18	22	28	38	43	40	26	26	25	13
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.2	5.2	13.0	20.9	26.2	26.9	29.5	28.2	23.1	15.5	9.7	8.4
		MCWB	5.6	3.3	6.9	10.7	17.5	18.5	20.5	20.7	16.8	12.9	8.6	7.6
	2%	DB	3.8	3.4	9.2	17.8	23.5	24.9	27.2	25.7	20.0	13.3	8.1	6.0
		MCWB	3.1	2.3	4.5	9.8	15.6	17.0	19.4	18.8	15.3	11.3	7.1	5.2
	5%	DB	2.2	2.2	6.3	15.0	21.2	23.1	25.4	23.8	18.1	11.9	7.1	4.5
		MCWB	1.7	1.5	3.3	8.4	13.9	16.3	18.5	17.9	14.2	10.5	6.4	3.9
	10%	DB	1.2	1.4	4.6	12.5	18.9	21.1	23.6	22.0	16.5	10.7	6.2	3.3
		MCWB	0.8	0.9	2.6	7.0	12.8	15.5	17.8	17.1	13.5	9.6	5.6	2.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.6	3.8	7.6	11.9	19.2	20.1	21.8	21.8	17.4	13.2	8.9	7.7
		MCDB	6.2	4.6	12.5	18.0	24.2	24.5	27.1	26.7	20.6	14.9	9.6	8.3
	2%	WB	3.3	2.5	5.1	10.4	16.9	18.6	20.5	20.0	16.0	11.7	7.4	5.3
		MCDB	3.8	3.0	7.8	16.6	21.3	22.5	25.3	23.8	18.8	12.8	7.9	5.8
	5%	WB	1.8	1.7	3.9	9.1	15.4	17.2	19.5	18.6	14.9	10.7	6.6	3.9
		MCDB	2.0	2.2	5.6	14.0	19.6	21.3	23.6	22.2	17.3	11.7	7.0	4.4
	10%	WB	0.9	0.9	2.8	7.7	13.8	16.2	18.5	17.5	13.8	9.7	5.7	2.7
		MCDB	1.1	1.4	4.3	11.4	17.9	20.0	22.4	21.3	16.0	10.6	6.1	3.1
Mean Daily Temperature Range	5% DB	MDBR	4.1	4.9	6.1	8.7	9.5	8.7	8.3	8.1	6.8	4.8	3.1	3.3
		MCDBR	3.5	4.0	8.5	12.6	12.0	11.1	10.8	10.6	9.1	6.1	4.0	3.3
		MCWBR	3.4	3.5	5.2	6.4	5.6	4.9	4.4	4.8	5.0	4.5	3.5	3.3
	5% WB	MCDBR	3.5	3.7	7.2	11.3	10.4	9.2	9.5	9.2	7.9	5.2	3.6	3.3
		MCWBR	3.5	3.4	5.0	6.2	5.7	5.1	4.4	4.8	4.8	4.3	3.4	3.3
Clear-Sky Solar Irradiance	taub	0.271	0.303	0.333	0.374	0.367	0.364	0.392	0.390	0.358	0.333	0.312	0.267	
	taud	2.137	2.136	2.181	2.286	2.375	2.411	2.350	2.352	2.423	2.408	2.240	2.137	
	Ebn at Noon	579	723	808	836	868	875	839	812	786	701	527	469	
	Edh at Noon	53	84	105	112	109	107	112	104	84	65	50	40	
All-Sky Solar Radiation	RadAvg	0.46	1.18	2.59	3.95	5.25	5.44	5.19	4.16	2.68	1.21	0.41	0.27	
	RadStd	0.10	0.21	0.34	0.48	0.55	0.45	0.54	0.41	0.30	0.19	0.06	0.05	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (26 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page