

GULBENE, Latvia

WMO: 263480

Lat: 57.1322N

Lon: 26.7189E

Elev: 143

StdP: 99.62

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.2	-18.0	-23.8	0.4	-20.7	-20.6	0.6	-17.5	8.3	-1.7	7.4	-2.5	1.7	310	0.554

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.0	27.6	19.7	25.8	18.5	24.2	17.6	20.8	25.9	19.6	24.1	18.6	22.7	2.4	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.0	14.0	23.4	18.0	13.1	21.9	16.9	12.3	20.7	60.7	26.1	56.6	24.1	53.1	22.6	24.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.1	6.2	5.5	DB	-24.3	30.2	3.6	1.6	-26.9	31.4	-29.1	32.4	-31.1	33.3	-33.7	34.5	(4)
(5)			WB	-24.5	22.4	3.5	1.2	-27.0	23.3	-29.1	24.0	-31.0	24.7	-33.6	25.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	5.9	-5.6	-5.1	-0.6	6.3	11.7	15.3	17.8	16.4	11.3	5.6	0.5	-3.5	(6)	
	DBStd	9.41	5.93	6.46	4.10	4.55	4.31	3.54	3.33	2.94	3.23	3.86	4.60	5.82	(7)	
	HDD10.0	2269	484	424	328	129	31	3	0	0	23	143	285	418	(8)	
	HDD18.3	4602	742	657	587	361	209	102	51	77	211	395	535	677	(9)	
	CDD10.0	776	0	0	0	19	84	163	243	197	63	7	0	0	(10)	
	CDD18.3	68	0	0	0	0	4	13	35	16	1	0	0	0	(11)	
	CDH23.3	533	0	0	0	1	36	100	261	131	4	0	0	0	(12)	
	CDH26.7	94	0	0	0	0	3	11	59	21	0	0	0	0	(13)	
	WSAvg	2.6	3.0	3.0	3.1	2.9	2.5	2.3	2.1	2.1	2.3	2.7	3.0	2.9	(14)	
	PrecAvg	665	49	40	38	32	58	76	76	69	56	70	53	46	(15)	
(16) Precipitation	PrecMax	802	83	68	95	93	109	144	222	134	95	116	78	78	(16)	
	PrecMin	508	18	16	16	5	18	21	11	1	18	32	2	33	(17)	
	PrecStd	78	19	15	20	21	27	31	48	38	23	23	21	12	(18)	
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.6	6.0	12.0	22.6	26.9	28.2	30.6	29.0	24.0	16.2	10.3	8.0	(19)	
		MCWB	3.8	3.5	6.0	13.2	17.6	19.5	21.7	20.6	16.5	12.5	8.9	6.9	(20)	
	2%	DB	2.9	4.3	8.9	19.7	23.9	26.1	28.4	26.5	20.5	13.9	8.7	6.0	(21)	
		MCWB	2.1	2.8	4.4	11.1	16.0	18.3	20.4	18.7	15.2	11.8	7.7	5.3	(22)	
	5%	DB	2.0	3.1	6.5	16.9	21.6	24.2	26.2	24.6	18.5	12.4	7.5	4.6	(23)	
		MCWB	1.3	2.1	3.5	9.9	14.4	17.6	19.4	17.7	14.3	10.9	6.7	3.9	(24)	
	10%	DB	1.2	2.2	4.7	14.3	19.6	22.1	24.3	22.7	16.6	11.1	6.3	3.3	(25)	
		MCWB	0.7	1.4	2.6	8.6	13.4	16.5	18.4	16.9	13.3	9.7	5.6	2.7	(26)	
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.0	4.5	6.9	14.0	19.0	21.1	22.6	22.4	17.8	13.4	9.4	7.3	(27)	
		MCDB	4.3	5.4	10.5	20.8	24.9	26.0	28.7	27.6	20.6	15.1	10.0	8.0	(28)	
	2%	WB	2.3	3.0	5.2	12.1	17.1	19.5	21.2	20.1	16.0	12.1	7.9	5.3	(29)	
		MCDB	2.6	3.8	7.8	17.5	22.1	24.3	26.8	24.4	18.9	13.4	8.6	5.8	(30)	
	5%	WB	1.4	2.3	3.9	10.7	15.6	18.3	20.1	18.7	14.9	11.1	6.8	4.0	(31)	
		MCDB	1.8	3.0	5.9	15.8	19.9	22.9	24.8	22.7	18.0	12.4	7.4	4.5	(32)	
	10%	WB	0.7	1.4	2.9	9.3	14.3	17.2	19.1	17.5	13.8	10.0	5.6	2.6	(33)	
		MCDB	1.1	2.1	4.5	13.7	18.4	21.0	23.1	21.4	16.0	11.0	6.2	3.2	(34)	
(36) Mean Daily Temperature Range	5% DB	MDBR	4.2	5.3	6.4	9.0	10.1	9.1	9.0	9.4	7.6	5.5	3.8	3.8	(35)	
		MCDBR	3.5	4.6	8.8	13.1	12.9	11.9	11.7	12.5	10.5	6.9	4.3	3.6	(36)	
		MCWBR	3.4	3.9	5.8	6.5	6.4	5.6	5.1	5.5	5.8	4.9	4.0	3.5	(37)	
	5% WB	MCDBR	3.4	4.3	7.6	11.3	11.0	10.4	10.5	10.7	8.9	6.4	4.3	3.5	(38)	
		MCWBR	3.4	3.9	5.5	5.9	6.1	5.6	5.0	5.4	5.6	5.1	4.1	3.6	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.276	0.309	0.339	0.380	0.373	0.369	0.398	0.396	0.362	0.338	0.318	0.273	(40)	
	taud		2.147	2.141	2.187	2.273	2.364	2.402	2.337	2.339	2.411	2.404	2.246	2.152	(41)	
	Ebn at Noon		583	721	804	831	864	872	833	807	783	699	529	475	(42)	
	Edh at Noon		54	84	105	114	111	108	114	106	86	66	51	41	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.47	1.21	2.60	3.95	5.27	5.47	5.20	4.18	2.71	1.23	0.42	0.28	(44)	
	RadStd		0.10	0.22	0.35	0.49	0.54	0.44	0.54	0.41	0.30	0.20	0.07	0.05	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (27 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page