

PUSHKINSKIYE GORY, Russian Federation

WMO: 263590

Lat: 57.017N

Lon: 28.900E

Elev: 354

StdP: 14.51

Time Zone: 3.00 (E03)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.4	-1.6	-12.3	2.9	-6.5	-6.9	3.9	-0.5	15.9	29.6	14.0	30.7	3.0	20	0.522

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.9	82.7	68.7	79.5	66.7	76.4	64.9	70.2	79.8	68.4	76.8	66.6	74.3	5.1	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.8	100.0	74.9	65.1	94.2	73.1	63.5	88.7	71.3	34.4	80.5	32.8	77.0	31.4	74.1	78.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.1	11.6	10.1	DB	-11.7	87.1	8.4	3.6	-17.8	89.7	-22.8	91.8	-27.5	93.8	-33.6	96.4	(4)
(5)			WB	-12.2	73.1	8.3	1.8	-18.2	74.4	-23.0	75.5	-27.7	76.6	-33.7	77.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	43.6	21.5	23.0	31.6	43.7	55.0	60.2	65.4	62.9	54.2	42.4	34.4	27.3	(6)	
	DBStd	17.31	12.36	11.48	8.58	7.46	7.71	6.16	5.99	5.90	6.20	7.25	7.67	9.90	(7)	
	HDD50	3916	885	755	570	214	36	4	0	0	29	251	469	703	(8)	
	HDD65	7984	1350	1175	1035	638	323	168	69	112	328	700	918	1168	(9)	
	CDD50	1575	0	0	0	26	191	309	479	400	154	16	0	0	(10)	
	CDD65	169	0	0	0	0	12	24	83	47	3	0	0	0	(11)	
	CDH74	1217	0	0	0	2	104	178	569	350	14	0	0	0	(12)	
	CDH80	242	0	0	0	0	17	23	121	81	0	0	0	0	(13)	
	WSAvg	5.0	5.8	5.4	5.6	5.3	4.6	4.3	3.9	4.2	4.4	5.1	5.8	6.1	(14)	
	PrecAvg	27.3	2.0	1.6	1.5	1.5	2.4	3.3	2.8	3.1	2.4	2.6	2.2	1.7	(15)	
(16) Precipitation	PrecMax	36.3	3.2	2.7	3.3	3.0	4.6	7.0	6.7	6.0	4.9	5.2	3.4	2.7	(16)	
	PrecMin	20.2	0.6	0.4	0.4	0.1	0.6	0.4	0.5	0.0	0.6	0.5	0.0	0.7	(17)	
	PrecStd	3.8	0.7	0.6	0.7	0.9	1.0	1.8	1.7	1.7	1.1	1.2	0.8	0.4	(18)	
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.1	42.1	57.6	72.0	82.3	83.2	87.5	87.8	75.9	62.6	50.9	47.6	(19)	
		MCWB	42.1	38.7	46.2	52.3	66.9	68.2	71.0	72.3	64.1	55.2	48.3	45.9	(20)	
	2%	DB	39.8	39.2	50.8	65.6	76.5	79.0	83.4	81.6	71.0	57.3	47.9	44.3	(21)	
		MCWB	38.1	36.6	41.4	50.7	62.0	65.1	69.7	68.0	61.9	53.4	45.7	42.6	(22)	
	5%	DB	37.1	37.2	45.9	61.0	72.6	75.4	80.1	77.7	67.3	54.7	45.5	41.0	(23)	
		MCWB	35.5	35.3	39.3	48.5	59.3	63.4	68.0	66.1	60.2	51.6	43.7	39.6	(24)	
	10%	DB	35.1	35.3	42.1	56.8	68.7	72.2	76.8	74.1	63.8	52.5	43.5	38.3	(25)	
		MCWB	33.9	33.7	37.5	46.1	57.2	61.9	66.2	64.6	58.0	50.0	42.0	36.9	(26)	
	0.4%	WB	42.6	40.0	46.7	54.4	67.9	70.0	72.5	73.1	66.3	57.3	49.5	46.2	(27)	
		MCDB	44.2	41.6	56.7	66.1	80.5	80.1	83.4	85.4	71.7	60.0	50.5	47.5	(28)	
(30) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	38.4	36.9	42.5	52.0	64.2	67.1	70.7	70.0	63.1	54.1	46.0	42.7	(29)	
		MCDB	39.5	38.3	48.3	62.3	73.6	75.7	80.7	79.0	69.3	56.3	47.3	43.9	(30)	
	5%	WB	35.8	35.5	40.1	50.1	61.3	64.9	69.0	67.5	60.9	52.2	43.9	39.8	(31)	
		MCDB	36.9	37.0	44.6	59.8	69.4	72.8	77.9	74.9	66.1	54.2	45.2	40.9	(32)	
	10%	WB	34.0	34.0	38.1	47.3	58.8	62.9	67.4	65.5	58.9	50.4	42.1	36.9	(33)	
		MCDB	35.0	35.2	41.3	55.4	67.0	70.6	75.2	72.6	63.4	52.4	43.4	38.1	(34)	
	5% DB	MDBR	7.8	9.1	12.1	16.5	17.9	16.5	15.9	15.9	13.7	9.6	6.5	6.6	(35)	
		MCDBR	6.3	7.7	16.6	23.4	22.8	20.7	20.2	21.2	18.5	12.4	8.6	6.7	(36)	
		MCWBR	6.2	6.2	10.7	12.1	11.0	10.5	9.3	9.9	10.6	8.8	7.5	6.2	(37)	
		MCWBR	6.1	6.6	14.3	20.4	19.9	17.7	18.0	18.4	16.5	10.7	8.3	6.6	(38)	
(42) Clear-Sky Solar Irradiance	taub		0.281	0.315	0.343	0.386	0.379	0.373	0.399	0.401	0.366	0.342	0.322	0.279	(40)	
		taud	2.137	2.126	2.169	2.253	2.350	2.389	2.334	2.323	2.398	2.386	2.239	2.151	(41)	
	Ebn at Noon		183	226	254	261	272	275	264	254	247	220	167	149	(42)	
		Edh at Noon	17	27	34	37	36	35	36	34	28	22	16	13	(43)	
(44) All-Sky Solar Radiation	RadAvg		148	406	843	1249	1661	1752	1681	1343	856	384	129	84	(44)	
	RadStd		35	74	135	167	167	124	170	118	86	71	20	22	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (14 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	-275	N/A	N/A	N/A	

Nomenclature: See separate page