

PAVILOSTA, Latvia

WMO: 264030

Lat: 56.8883N

Lon: 21.1894E

Elev: 9

StdP: 101.21

Time Zone: 2.00 (EUE)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.9	-12.5	-19.2	0.7	-14.1	-16.6	0.9	-11.5	10.3	-1.3	9.4	-0.8	2.0	150	0.557

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.1	26.6	19.0	24.3	18.2	22.6	17.7	20.5	24.3	19.3	22.7	18.4	21.7	3.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.1	13.9	22.5	18.0	12.9	21.2	17.1	12.2	20.4	58.9	24.2	55.1	22.7	52.0	21.7	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.1	7.1	6.2	-17.5	29.7	5.0	1.8	-21.1	31.0	-24.0	32.0	-26.9	33.1	-30.5	34.4		
(5)			-18.6	21.7	4.8	1.5	-22.0	22.8	-24.9	23.7	-27.6	24.5	-31.1	25.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	7.4	-2.2	-1.6	1.0	5.6	10.3	14.8	17.1	16.9	13.2	7.9	4.3	0.6	(6)
(7)		DBStd	7.77	5.01	5.18	3.49	3.57	4.14	3.34	2.77	2.39	2.90	3.22	3.45	4.60	(7)
(8)		HDD10.0	1723	379	326	279	142	44	2	0	0	8	81	171	291	(8)
(9)		HDD18.3	4051	638	559	537	383	252	117	57	57	155	324	421	549	(9)
(10)		CDD10.0	760	0	0	0	9	53	146	220	214	104	15	0	0	(10)
(11)		CDD18.3	46	0	0	0	0	3	11	19	13	1	0	0	0	(11)
(12)		CDH23.3	306	0	0	0	1	24	86	112	78	4	0	0	0	(12)
(13)		CDH26.7	61	0	0	0	0	2	14	31	13	1	0	0	0	(13)
(14)	Wind	WSAvg	3.1	3.6	3.4	3.3	3.1	2.7	2.7	2.4	2.5	2.9	3.3	3.5	3.5	(14)
(15)	Precipitation	PrecAvg	742	60	48	44	33	35	59	61	83	66	97	88	69	(15)
(16)		PrecMax	1016	134	78	90	68	79	121	145	187	119	188	153	117	(16)
(17)		PrecMin	541	8	7	8	8	12	16	1	7	25	43	9	29	(17)
(18)		PrecStd	111	27	19	20	18	19	24	35	44	31	40	35	21	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.2	7.1	12.5	20.6	26.3	28.7	30.3	28.6	23.1	16.8	11.1	7.7	(19)
(20)			MCWB	5.3	5.2	8.8	11.9	17.8	19.1	21.3	20.1	16.3	13.2	9.9	6.4	(20)
(21)		2%	DB	5.4	5.5	8.2	17.2	22.6	25.8	26.1	25.4	20.5	14.7	10.2	7.2	(21)
(22)			MCWB	4.6	4.3	5.3	10.3	15.1	18.7	19.5	18.1	15.8	12.7	9.0	6.0	(22)
(23)		5%	DB	4.5	4.5	6.2	13.9	19.8	23.2	23.7	23.5	18.9	13.5	9.4	6.5	(23)
(24)			MCWB	3.7	3.5	4.4	8.4	14.4	17.5	19.0	17.9	15.2	11.8	8.2	5.4	(24)
(25)		10%	DB	3.6	3.7	5.2	11.3	17.3	20.7	22.0	21.8	17.7	12.6	8.6	5.8	(25)
(26)			MCWB	2.9	2.9	3.8	7.6	13.0	16.1	18.3	17.6	14.8	11.0	7.5	4.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.7	5.5	8.8	12.9	18.1	20.6	22.2	21.7	18.3	14.2	10.4	7.1	(27)
(28)			MCDWB	6.0	6.5	12.3	19.5	25.7	25.9	27.4	26.4	21.1	16.0	10.9	7.5	(28)
(29)		2%	WB	4.8	4.5	5.9	10.8	16.2	19.3	21.0	19.8	16.8	13.0	9.2	6.3	(29)
(30)			MCDWB	5.2	5.3	7.5	15.4	20.7	23.9	24.6	23.0	18.7	14.3	10.0	6.8	(30)
(31)		5%	WB	3.9	3.7	4.8	9.3	14.7	17.9	19.7	18.9	15.9	12.1	8.4	5.6	(31)
(32)			MCDWB	4.4	4.3	6.0	13.2	19.0	22.9	22.7	21.8	17.9	13.3	9.2	6.3	(32)
(33)		10%	WB	3.0	3.1	3.9	7.9	13.3	16.7	18.6	18.1	15.1	11.3	7.6	4.9	(33)
(34)			MCDWB	3.7	3.7	5.0	11.1	17.2	20.2	21.5	21.1	17.5	12.5	8.4	5.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.1	4.5	5.2	7.5	8.3	7.7	7.1	7.9	6.4	5.3	3.4	3.3	(35)
(36)			MCDBR	3.2	3.9	6.4	12.1	12.0	12.4	10.6	11.7	9.0	6.3	3.5	3.1	(36)
(37)			MCWBR	3.3	3.3	4.4	6.8	6.3	5.9	5.2	5.8	5.5	4.7	3.2	3.1	(37)
(38)		5% WB	MCDBR	3.2	3.5	5.9	10.7	10.8	10.3	8.9	9.1	7.0	5.5	3.3	3.0	(38)
(39)			MCWBR	3.3	3.2	4.4	6.6	6.1	5.5	4.9	5.5	4.9	4.4	3.2	3.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.302	0.328	0.350	0.384	0.378	0.373	0.404	0.398	0.366	0.349	0.335	0.301	(40)	
(41)		taud	2.229	2.273	2.308	2.294	2.375	2.429	2.362	2.376	2.440	2.399	2.267	2.195	(41)	
(42)		Ebn at Noon	567	715	802	829	860	869	829	808	782	688	517	454	(42)	
(43)		Edh at Noon	53	76	95	112	110	106	111	103	84	68	52	42	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.36	0.99	2.41	4.25	5.71	6.06	5.56	4.45	2.98	1.39	0.46	0.24	(44)	
(45)		RadStd	0.06	0.15	0.27	0.48	0.46	0.29	0.48	0.40	0.33	0.18	0.08	0.03	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (26 neighbors)	+0.38	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page