

LIEPAJA, Latvia

WMO: 264060

Lat: 56.4755N

Lon: 21.0206E

Elev: 5

StdP: 101.27

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.9	-12.3	-18.2	0.8	-14.8	-15.3	1.0	-11.3	14.1	5.2	12.3	4.6	2.0	70	0.588

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.9	27.1	19.7	25.2	18.7	23.5	17.9	21.0	25.0	19.8	23.6	18.7	22.3	3.6	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.5	14.3	23.1	18.2	13.1	21.6	17.2	12.3	20.6	60.5	25.2	56.6	23.7	53.3	22.4	27.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.7	9.1	7.9	DB	-19.5	30.1	4.5	1.8	-22.7	31.4	-25.3	32.4	-27.8	33.4	-31.0	34.7	(4)
(5)			WB	-19.7	22.8	4.4	2.0	-22.9	24.2	-25.4	25.4	-27.9	26.5	-31.1	27.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.7	-1.6	-1.6	1.0	6.3	11.0	14.5	17.6	17.4	13.4	8.3	4.1	0.9
	DBStd	7.86	5.26	5.03	3.65	3.96	4.01	3.12	2.83	2.68	2.89	3.53	3.82	4.77
	HDD10.0	1664	360	324	279	126	33	2	0	0	7	74	178	283
	HDD18.3	3955	618	558	537	361	231	123	48	51	151	310	427	541
	CDD10.0	809	0	0	0	15	64	136	236	229	107	22	0	0
	CDD18.3	58	0	0	0	0	3	7	26	21	1	0	0	0
	CDH23.3	416	0	0	0	3	37	61	188	122	6	0	0	0
	CDH26.7	72	0	0	0	0	3	10	38	19	1	0	0	0
Wind	WSAvg	3.5	4.1	3.8	3.7	3.4	3.2	3.2	3.0	3.1	3.3	3.8	3.8	4.1
Precipitation	PrecAvg	673	43	29	33	33	38	46	74	81	74	71	84	63
	PrecMax	996	100	79	73	88	96	81	151	284	174	200	210	122
	PrecMin	442	8	5	3	1	7	8	20	16	20	16	38	6
	PrecStd	129	22	16	16	21	24	20	36	54	38	42	35	29
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.2	6.9	13.9	22.8	26.9	28.1	29.9	29.0	23.9	17.8	11.3	9.1
		MCWB	6.6	5.1	8.6	14.0	18.3	19.6	20.9	20.7	18.2	14.1	9.9	8.0
	2%	DB	6.1	5.4	9.2	19.1	24.0	25.0	27.7	26.2	21.0	15.3	10.6	8.1
		MCWB	5.3	4.4	6.0	11.9	16.5	18.6	20.3	19.2	16.5	13.2	9.4	7.3
	5%	DB	5.1	4.7	6.5	16.1	21.1	22.7	25.4	24.3	19.4	14.2	9.9	7.2
		MCWB	4.3	4.0	4.7	10.3	14.8	16.8	19.4	18.3	15.7	12.5	8.9	6.4
	10%	DB	4.1	3.9	5.1	13.2	18.2	20.2	23.2	22.8	18.1	13.2	9.1	6.3
		MCWB	3.5	3.3	3.9	8.7	13.3	15.8	18.5	17.9	15.2	11.7	8.1	5.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.6	5.6	8.8	15.1	19.4	21.2	22.8	22.3	18.7	14.9	10.5	8.4
		MCDB	6.9	6.2	12.5	21.2	24.8	25.8	27.1	26.5	22.1	16.7	10.9	8.7
	2%	WB	5.4	4.6	6.3	12.7	17.5	19.3	21.3	20.6	17.3	13.7	9.7	7.4
		MCDB	5.8	5.0	8.4	17.6	22.5	23.7	25.4	24.5	19.8	15.1	10.3	7.8
	5%	WB	4.4	4.0	5.0	10.9	15.6	17.7	20.3	19.4	16.4	12.9	8.9	6.6
		MCDB	4.9	4.4	6.1	15.2	20.0	21.2	24.1	22.9	18.5	14.2	9.6	7.1
	10%	WB	3.5	3.3	4.0	9.2	13.9	16.4	19.1	18.5	15.5	12.0	8.1	5.6
		MCDB	4.0	3.8	4.8	12.7	18.1	19.6	22.6	21.7	17.7	13.3	8.9	6.2
Mean Daily Temperature Range	5% DB	MDBR	4.5	4.9	6.0	8.5	9.0	8.1	7.9	8.2	7.5	5.8	4.1	4.0
		MCDBR	3.2	3.8	8.2	13.5	13.2	12.8	11.9	11.4	10.1	6.7	4.2	3.1
		MCWBR	3.3	3.3	5.8	7.6	7.3	6.9	6.1	5.8	6.5	5.2	4.0	3.2
	5% WB	MCDBR	3.2	3.5	7.0	12.3	12.1	10.7	10.1	9.6	8.3	6.2	3.9	3.0
		MCWBR	3.4	3.3	5.4	7.4	7.2	6.5	6.0	5.8	5.9	5.1	3.9	3.2
Clear-Sky Solar Irradiance	taub	0.304	0.330	0.353	0.388	0.381	0.376	0.407	0.402	0.369	0.351	0.337	0.304	
	taud	2.233	2.269	2.298	2.278	2.365	2.418	2.351	2.364	2.430	2.397	2.274	2.206	
	Ebn at Noon	576	718	801	826	858	867	827	806	782	691	527	468	
	Edh at Noon	54	78	97	115	111	107	113	105	85	69	53	44	
All-Sky Solar Radiation	RadAvg	0.39	1.03	2.42	4.25	5.65	5.97	5.42	4.36	2.98	1.42	0.48	0.26	
	RadStd	0.07	0.15	0.27	0.47	0.46	0.28	0.46	0.42	0.32	0.19	0.08	0.03	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.45	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (22 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page