

SALDUS, LatviaWMO: **264160**Lat: **56.6753N**Lon: **22.5036E**Elev: **114**StdP: **99.97**Time Zone: **2.00 (EUE)**Period: **96-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.8	-14.3	-20.5	0.6	-17.3	-17.4	0.8	-13.6	10.4	0.0	9.2	0.4	1.5	120	0.574

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.1	27.1	19.1	25.5	18.3	23.9	17.5	20.4	25.1	19.3	23.9	18.3	22.5	3.1	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.7	13.7	22.9	17.6	12.8	21.4	16.6	12.0	20.3	59.2	25.1	55.3	24.0	52.2	22.6	25.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.3	7.2	6.3	-21.5	29.6	5.1	1.8	-25.2	30.9	-28.2	32.0	-31.1	33.0	-34.8	34.3		
(5)			-21.8	22.3	4.9	1.4	-25.3	23.3	-28.2	24.1	-31.0	24.9	-34.5	25.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.9	-3.4	-2.9	0.4	6.2	11.4	14.9	17.7	16.8	12.4	6.7	2.6	-1.1
	DBStd	8.45	5.73	5.17	4.50	3.91	4.15	3.18	2.92	2.78	3.10	3.61	3.91	4.89
	HDD10.0	1926	416	361	298	126	31	2	0	0	13	114	223	343
	HDD18.3	4245	674	594	557	364	218	111	48	64	177	362	473	602
	CDD10.0	781	0	0	0	11	74	149	239	211	86	11	0	0
	CDD18.3	58	0	0	0	0	3	9	29	16	1	0	0	0
	CDH23.3	453	0	0	0	1	27	77	225	120	3	0	0	0
	CDH26.7	63	0	0	0	0	1	10	37	15	0	0	0	0
Wind	WSAvg	3.1	3.5	3.4	3.3	3.2	3.0	2.9	2.7	2.7	2.8	3.0	3.3	3.3
Precipitation	PrecAvg	669	52	40	36	36	47	65	74	77	62	72	56	54
	PrecMax	857	110	72	63	69	114	113	153	154	101	137	92	123
	PrecMin	513	18	6	7	4	13	21	2	2	26	6	12	32
	PrecStd	82	23	16	19	18	26	25	37	37	22	30	22	21
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.3	7.0	14.1	21.0	26.2	28.1	29.7	28.6	23.3	16.6	10.9	8.7
		MCWB	6.5	5.3	8.0	11.3	17.8	19.7	20.1	21.1	16.5	12.9	9.5	8.0
	2%	DB	5.4	5.4	10.8	18.1	23.7	25.6	27.6	26.1	21.2	14.5	9.4	7.2
		MCWB	4.5	4.0	6.3	10.7	16.1	18.0	19.6	18.5	15.7	12.2	8.3	6.2
	5%	DB	4.1	4.0	8.0	15.6	21.8	23.6	26.0	24.6	19.3	13.0	8.4	5.7
		MCWB	3.3	3.1	5.1	9.3	14.7	16.9	18.9	17.9	14.8	11.5	7.5	5.0
	10%	DB	2.9	3.0	5.9	13.3	19.5	21.6	24.1	22.8	17.7	11.9	7.6	4.7
		MCWB	2.3	2.2	3.9	8.1	13.5	15.6	18.0	17.0	14.2	10.5	6.8	4.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.6	5.6	8.7	13.1	19.0	21.2	22.1	21.8	17.9	13.7	9.9	8.2
		MCDB	7.2	6.5	12.8	18.0	24.0	26.4	26.8	26.6	21.8	15.3	10.4	8.6
	2%	WB	4.7	4.2	6.8	11.2	17.3	19.1	20.7	20.0	16.5	12.7	8.5	6.3
		MCDB	5.2	5.1	10.3	17.0	22.5	24.1	25.4	24.5	19.7	14.0	9.2	6.9
	5%	WB	3.4	3.2	5.3	9.8	15.7	17.6	19.6	18.7	15.5	11.7	7.7	5.1
		MCDB	3.9	3.9	7.6	14.6	20.2	21.9	24.3	22.8	18.1	13.0	8.3	5.6
	10%	WB	2.3	2.3	4.0	8.6	14.1	16.3	18.7	17.7	14.7	10.7	6.9	4.0
		MCDB	2.9	3.0	5.7	12.7	18.6	20.6	23.1	21.5	17.1	11.8	7.5	4.6
Mean Daily Temperature Range	5% DB	MDBR	4.1	4.6	6.6	9.4	10.2	9.4	9.1	8.8	7.6	5.6	3.5	3.5
		MCDBR	3.7	4.5	9.7	13.4	12.9	12.6	12.0	12.1	10.7	7.0	4.0	3.4
		MCWBR	3.6	3.5	6.1	7.2	6.7	6.1	5.2	5.5	5.9	4.9	3.5	3.4
	5% WB	MCDBR	3.8	3.8	8.8	11.7	11.3	10.9	10.5	10.2	8.6	6.2	3.8	3.3
		MCWBR	3.7	3.3	5.9	6.8	6.3	6.1	5.2	5.3	5.3	4.6	3.5	3.4
Clear-Sky Solar Irradiance	taub	0.288	0.317	0.346	0.382	0.374	0.370	0.401	0.395	0.363	0.342	0.326	0.288	
	taud	2.197	2.211	2.259	2.274	2.346	2.386	2.323	2.342	2.414	2.407	2.273	2.186	
	Ebn at Noon	587	726	805	831	864	871	832	811	787	701	536	478	
	Edh at Noon	54	81	100	115	113	111	116	106	86	67	52	43	
All-Sky Solar Radiation	RadAvg	0.45	1.14	2.49	4.00	5.40	5.62	5.29	4.25	2.88	1.40	0.48	0.29	
	RadStd	0.10	0.23	0.37	0.52	0.47	0.39	0.44	0.42	0.33	0.21	0.07	0.04	