

RIGA, Latvia

WMO: 264220

Lat: 56.9548N

Lon: 24.1047E

Elev: 24

StdP: 14.68

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.0	5.4	-5.7	4.1	-1.0	0.6	5.7	6.7	26.0	30.2	21.9	29.9	3.7	190	0.585

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.6	83.9	68.0	80.5	67.1	77.0	64.8	70.4	79.5	68.4	76.8	66.5	74.6	9.3	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.0	99.3	74.8	65.0	92.5	72.2	63.1	86.4	70.0	34.3	79.9	32.5	77.1	31.1	74.2	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.0	17.7	15.9	DB	-7.5	89.2	8.5	3.2	-13.7	91.5	-18.7	93.3	-23.4	95.1	-29.6	97.4	(4)
(5)			WB	-8.0	73.8	8.4	2.3	-14.0	75.5	-18.9	76.8	-23.6	78.1	-29.7	79.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	45.2	26.4	26.7	33.2	44.2	53.5	60.3	65.5	63.7	55.4	45.1	36.8	30.3
	DBStd	15.77	10.26	10.51	7.80	7.67	7.57	5.96	5.53	5.31	5.56	6.74	7.46	9.20
	HDD50	3361	730	651	522	208	46	1	0	0	16	180	396	611
	HDD65	7389	1195	1071	987	625	366	167	60	88	291	618	845	1076
	CDD50	1612	0	0	1	34	155	309	482	426	177	28	0	0
	CDD65	161	0	0	0	0	9	24	77	49	2	0	0	0
	CDH74	1405	0	0	0	11	100	248	625	400	21	0	0	0
	CDH80	319	0	0	0	0	13	54	169	82	1	0	0	0
Wind	WSAvg	7.6	8.6	8.3	7.9	7.6	7.3	7.1	6.8	6.4	6.7	7.6	8.3	8.7
Precipitation	PrecAvg	25.7	1.4	1.1	1.3	1.6	1.8	2.6	3.0	3.0	3.0	2.4	2.4	1.9
	PrecMax	33.4	3.0	2.0	3.0	4.7	4.0	5.2	5.8	9.5	5.8	6.3	4.7	3.6
	PrecMin	18.3	0.4	0.2	0.2	0.1	0.4	0.7	0.5	0.2	0.8	0.6	0.4	0.6
	PrecStd	4.0	0.7	0.5	0.7	1.0	0.9	1.1	1.6	2.1	1.4	1.2	1.0	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.5	46.3	58.9	75.3	82.2	85.7	88.9	86.2	77.0	64.3	53.3	49.9
		MCWB	45.0	42.8	47.3	58.3	65.4	68.5	70.3	69.8	64.2	57.3	49.7	47.8
	2%	DB	42.7	43.1	52.0	68.2	76.8	80.8	84.5	82.2	71.8	60.3	50.1	46.1
		MCWB	40.9	40.6	43.9	54.2	62.1	66.7	68.7	67.7	61.7	55.7	48.3	44.4
	5%	DB	39.6	41.0	46.7	62.8	72.4	76.2	80.7	78.6	68.2	57.2	48.2	43.1
		MCWB	38.3	39.1	41.6	51.4	59.3	63.5	68.1	66.2	59.8	53.7	46.8	41.9
	10%	DB	37.7	39.1	43.1	57.7	67.9	72.5	76.9	75.0	65.1	55.2	46.5	41.1
		MCWB	36.7	37.6	39.6	48.0	57.2	61.3	66.0	64.3	58.5	52.1	45.3	39.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.0	43.4	48.7	59.3	67.4	71.7	73.5	72.7	66.0	58.9	50.5	48.1
		MCDB	46.0	44.8	56.8	72.1	77.7	82.1	83.2	81.8	73.3	61.8	52.0	49.3
	2%	WB	40.8	40.8	45.0	55.4	64.1	67.8	71.0	69.7	63.2	56.4	48.4	44.2
		MCDB	41.7	42.5	49.9	65.9	74.2	77.5	80.6	78.0	69.2	59.4	49.5	45.0
	5%	WB	38.4	39.1	42.2	52.4	61.0	65.1	69.0	67.3	61.1	54.5	46.7	41.9
		MCDB	39.3	40.4	45.9	60.9	69.4	73.5	77.7	74.9	66.4	57.0	47.7	42.9
	10%	WB	36.6	37.3	39.9	49.7	58.3	62.9	67.1	65.4	59.5	52.5	45.1	39.6
		MCDB	37.4	38.6	42.7	57.0	66.2	70.8	75.2	73.3	64.3	54.9	46.0	40.6
Mean Daily Temperature Range	5% DB	MDBR	8.9	10.5	13.7	18.1	19.6	17.9	17.6	18.1	16.4	12.2	8.0	7.7
		MCDBR	8.2	9.5	18.9	26.4	25.3	24.5	23.4	23.7	21.2	14.2	9.2	7.7
		MCWBR	7.7	7.8	12.6	14.9	13.5	12.4	10.9	11.9	12.6	10.3	8.1	7.2
	5% WB	MCDBR	8.0	9.2	16.8	23.9	22.7	20.8	20.8	20.3	18.2	13.1	8.5	7.5
		MCWBR	7.8	7.9	12.2	14.5	13.3	11.7	10.8	11.3	11.7	10.2	7.9	7.3
Clear-Sky Solar Irradiance	taub	0.291	0.321	0.350	0.388	0.379	0.376	0.409	0.404	0.370	0.347	0.333	0.290	
	taud	2.182	2.179	2.208	2.264	2.362	2.405	2.336	2.350	2.423	2.410	2.261	2.183	
	Ebn at Noon	181	226	252	261	272	274	261	254	247	219	164	147	
	Edh at Noon	17	26	33	36	35	34	36	33	27	21	16	13	
All-Sky Solar Radiation	RadAvg	139	358	793	1263	1709	1783	1692	1350	890	426	139	87	
	RadStd	32	71	120	152	158	132	145	130	99	64	22	12	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (34 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page