

RIGA, Latvia

WMO: 264220

Lat: 56.9548N

Lon: 24.1047E

Elev: 7

StdP: 101.24

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.3	-14.8	-21.0	0.6	-18.4	-17.4	0.8	-14.1	11.6	-1.0	9.8	-1.2	1.6	190	0.585

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.8	28.8	20.0	26.9	19.5	25.0	18.2	21.3	26.4	20.2	24.9	19.2	23.7	4.1	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.4	14.2	23.8	18.3	13.2	22.3	17.3	12.3	21.1	62.0	26.6	57.8	25.1	54.4	23.5	25.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.9	7.9	7.1	DB	-22.0	31.8	4.7	1.8	-25.4	33.0	-28.1	34.1	-30.8	35.1	-34.2	36.4	(4)
(5)			WB	-22.2	23.2	4.7	1.3	-25.5	24.2	-28.3	24.9	-30.9	25.6	-34.3	26.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.3	-3.1	-2.9	0.7	6.8	11.9	15.7	18.6	17.6	13.0	7.3	2.7	-0.9	(6)	
	DBStd	8.76	5.70	5.84	4.34	4.26	4.20	3.31	3.07	2.95	3.09	3.74	4.14	5.11	(7)	
	HDD10.0	1867	406	362	290	116	26	1	0	0	9	100	220	339	(8)	
	HDD18.3	4105	664	595	548	347	203	93	33	49	162	343	469	598	(9)	
	CDD10.0	896	0	0	1	19	86	172	268	237	98	16	0	0	(10)	
	CDD18.3	89	0	0	0	0	5	13	43	27	1	0	0	0	(11)	
	CDH23.3	781	0	0	0	6	56	138	347	222	12	0	0	0	(12)	
	CDH26.7	177	0	0	0	0	7	30	94	46	1	0	0	0	(13)	
(14) Wind	WSAvg	3.4	3.8	3.7	3.5	3.4	3.3	3.2	3.0	2.9	3.0	3.4	3.7	3.9	(14)	
(15) Precipitation	PrecAvg	654	35	27	32	41	45	66	77	77	77	61	62	49	(15)	
	PrecMax	849	75	50	75	119	102	131	148	241	148	160	120	91	(16)	
	PrecMin	466	10	4	6	3	9	19	13	6	21	16	9	16	(17)	
	PrecStd	102	17	13	18	25	23	28	40	53	35	30	25	19	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.1	7.9	15.0	24.0	27.9	29.8	31.6	30.1	25.0	17.9	11.8	9.9	(19)	
		MCWB	7.2	6.0	8.5	14.6	18.5	20.3	21.3	21.0	17.9	14.0	9.8	8.8	(20)	
	2%	DB	5.9	6.2	11.1	20.1	24.9	27.1	29.2	27.9	22.1	15.7	10.1	7.8	(21)	
		MCWB	5.0	4.8	6.6	12.3	16.7	19.3	20.4	19.9	16.5	13.2	9.0	6.9	(22)	
	5%	DB	4.2	5.0	8.2	17.1	22.5	24.6	27.1	25.9	20.1	14.0	9.0	6.2	(23)	
		MCWB	3.5	3.9	5.4	10.8	15.2	17.5	20.1	19.0	15.5	12.1	8.2	5.5	(24)	
	10%	DB	3.2	3.9	6.2	14.3	20.0	22.5	25.0	23.9	18.4	12.9	8.0	5.0	(25)	
		MCWB	2.6	3.1	4.2	8.9	14.0	16.3	18.9	18.0	14.7	11.2	7.4	4.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.2	6.3	9.3	15.2	19.7	22.0	23.0	22.6	18.9	14.9	10.3	8.9	(27)	
		MCDB	7.8	7.1	13.8	22.3	25.4	27.8	28.5	27.7	23.0	16.6	11.1	9.6	(28)	
	2%	WB	4.9	4.9	7.2	13.0	17.8	19.9	21.7	20.9	17.3	13.5	9.1	6.8	(29)	
		MCDB	5.4	5.8	9.9	18.8	23.4	25.3	27.0	25.5	20.7	15.2	9.7	7.2	(30)	
	5%	WB	3.6	3.9	5.7	11.3	16.1	18.4	20.6	19.6	16.2	12.5	8.2	5.5	(31)	
		MCDB	4.1	4.7	7.7	16.1	20.8	23.1	25.4	23.9	19.1	13.9	8.7	6.0	(32)	
	10%	WB	2.6	2.9	4.4	9.9	14.6	17.2	19.5	18.6	15.3	11.4	7.3	4.2	(33)	
		MCDB	3.0	3.7	5.9	13.9	19.0	21.5	24.0	22.9	17.9	12.7	7.8	4.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.9	5.8	7.6	10.1	10.9	9.9	9.8	10.1	9.1	6.8	4.5	4.3	(35)	
		MCDBR	4.6	5.3	10.5	14.6	14.1	13.6	13.0	13.2	11.8	7.9	5.1	4.3	(36)	
	5% WB	MCWBR	4.3	4.4	7.0	8.3	7.5	6.9	6.1	6.6	7.0	5.7	4.5	4.0	(37)	
		MCDWR	4.5	5.1	9.3	13.3	12.6	11.6	11.6	11.3	10.1	7.3	4.7	4.2	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.291	0.321	0.350	0.388	0.379	0.376	0.409	0.404	0.370	0.347	0.333	0.290	(40)	
		taud	2.182	2.179	2.208	2.264	2.362	2.405	2.336	2.350	2.423	2.410	2.261	2.183	(41)	
	Ebn at Noon	Ebn at Noon	571	712	794	823	858	865	824	801	778	691	518	463	(42)	
		Edh at Noon	54	82	104	115	111	108	114	105	85	67	52	42	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.44	1.13	2.50	3.98	5.39	5.62	5.33	4.26	2.81	1.34	0.44	0.27	(44)	
	RadStd	RadStd	0.10	0.23	0.38	0.48	0.50	0.41	0.46	0.41	0.31	0.20	0.07	0.04	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)			
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (34 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page