

JELGAVA, Latvia

WMO: 264250

Lat: 56.5569N

Lon: 23.9642E

Elev: 6

StdP: 101.26

Time Zone: 2.00 (EUE)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-19.8	-15.6	-22.2	0.5	-19.4	-18.7	0.7	-14.8	8.9	1.0	8.2	-1.0	0.9	20	0.532

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.4	28.2	20.3	26.4	19.2	24.8	18.3	21.5	26.3	20.3	24.8	19.2	23.5	2.3	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.7	14.5	24.2	18.6	13.5	22.8	17.5	12.5	21.4	62.6	26.2	58.2	24.7	54.6	23.7	25.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.8	6.6	5.7	DB	-23.5	30.9	4.5	2.1	-26.8	32.4	-29.4	33.6	-31.9	34.8	-35.2	36.3	(4)
			WB	-23.3	23.3	4.7	1.4	-26.6	24.3	-29.4	25.1	-32.0	25.9	-35.4	26.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.0	-4.3	-2.7	0.7	6.6	11.9	15.7	17.9	16.7	12.3	6.6	3.1	-1.3
	DBStd	8.70	5.79	6.09	4.33	4.06	4.34	3.61	3.05	2.90	3.18	3.68	3.88	5.28
	HDD10.0	1922	442	357	288	116	28	2	0	0	14	117	206	352
	HDD18.3	4211	700	590	546	352	203	96	46	67	182	364	456	610
	CDD10.0	823	0	0	1	14	88	172	245	208	83	11	1	0
	CDD18.3	71	0	0	0	0	4	16	32	18	1	0	0	0
	CDH23.3	689	0	0	0	3	56	163	284	178	5	0	0	0
	CDH26.7	124	0	0	0	0	4	28	59	32	0	0	0	0
Wind	WSAvg	2.4	2.8	2.9	2.9	2.7	2.1	2.1	1.8	1.5	2.0	2.5	2.5	2.7
Precipitation	PrecAvg	655	44	35	34	34	51	68	85	73	61	70	52	47
	PrecMax	868	74	61	71	74	94	122	168	139	129	140	84	93
	PrecMin	519	15	11	8	4	15	24	11	0	25	3	9	24
	PrecStd	81	17	12	15	18	21	26	44	37	27	31	21	15
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.8	7.1	14.1	22.6	27.2	29.2	30.1	30.1	24.2	16.9	12.0	9.4
		MCWB	6.0	4.7	8.6	12.4	18.5	21.2	21.9	22.0	17.5	13.8	9.8	8.2
	2%	DB	4.6	5.7	10.4	19.6	24.9	27.1	28.3	27.0	21.6	15.0	10.1	7.5
		MCWB	3.6	4.0	6.4	11.6	16.9	19.5	20.5	19.5	15.8	12.9	8.8	6.5
	5%	DB	3.4	4.5	8.0	16.9	22.7	25.2	26.6	25.4	19.6	13.4	9.1	5.9
		MCWB	2.6	3.3	5.3	10.4	15.7	18.5	20.1	18.6	15.0	11.6	7.9	5.1
	10%	DB	2.5	3.6	6.2	14.2	20.4	23.2	24.5	23.7	18.0	12.1	8.2	4.7
		MCWB	1.8	2.6	4.1	8.8	14.2	17.4	19.0	17.5	14.6	10.6	7.3	3.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.1	5.4	9.2	14.1	19.4	23.0	22.9	22.8	18.3	14.3	10.3	8.5
		MCDB	6.6	6.5	13.6	19.6	25.7	28.9	28.2	28.0	22.2	16.0	11.1	9.1
	2%	WB	4.0	4.2	7.0	12.2	18.0	20.3	21.8	20.9	16.8	13.1	9.0	6.5
		MCDB	4.4	5.2	9.6	18.0	23.3	25.4	26.4	25.9	19.8	14.6	9.9	7.2
	5%	WB	2.8	3.5	5.6	10.9	16.3	19.1	20.7	19.5	15.9	12.0	8.1	5.2
		MCDB	3.3	4.4	7.6	16.1	21.1	23.8	25.0	23.5	18.5	13.2	8.9	5.9
	10%	WB	1.9	2.7	4.3	9.4	14.9	17.9	19.6	18.4	14.9	10.8	7.4	3.9
		MCDB	2.4	3.6	6.0	13.5	19.0	22.5	23.8	22.7	17.6	11.8	8.2	4.6
Mean Daily Temperature Range	5% DB	MDBR	5.1	5.3	7.1	10.7	11.9	11.0	10.4	11.3	9.3	6.6	4.0	3.7
		MCDBR	3.5	4.9	9.5	15.3	14.7	13.6	13.1	14.2	12.4	7.8	5.0	4.3
		MCWBR	3.3	3.8	6.2	8.1	7.5	6.8	6.1	7.1	7.3	5.6	4.3	3.7
	5% WB	MCDBR	3.6	4.6	8.6	13.7	12.4	12.2	11.9	12.5	9.8	6.7	4.8	4.0
		MCWBR	3.5	3.9	6.0	7.8	6.7	6.6	6.1	6.9	6.3	5.2	4.3	3.7
Clear-Sky Solar Irradiance	taub	0.291	0.323	0.355	0.393	0.383	0.379	0.412	0.407	0.371	0.348	0.333	0.291	
	taud	2.177	2.169	2.209	2.241	2.327	2.369	2.300	2.314	2.393	2.398	2.260	2.182	
	Ebn at Noon	582	714	793	820	855	863	821	798	776	694	528	477	
	Edh at Noon	56	84	105	119	116	113	118	110	88	68	53	43	
All-Sky Solar Radiation	RadAvg	0.47	1.17	2.50	3.96	5.34	5.55	5.25	4.23	2.84	1.38	0.47	0.29	
	RadStd	0.11	0.24	0.40	0.51	0.49	0.43	0.46	0.42	0.32	0.22	0.07	0.04	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (31 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page