

BAUSKA, Latvia

WMO: 264290

Lat: 56.3792N

Lon: 24.2218E

Elev: 106

StdP: 14.64

Time Zone: 2.00 (EUE)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.8	4.0	-7.1	3.8	-1.0	-1.8	5.0	5.0	21.9	26.2	19.2	26.8	3.8	160	0.543

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.1	82.8	68.5	79.5	66.5	76.8	64.9	70.1	79.3	68.1	76.5	66.4	74.6	6.7	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.9	99.3	74.8	65.0	92.8	72.2	63.2	87.1	70.3	34.1	79.5	32.4	76.4	31.1	74.8	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	17.8	15.5	13.7	DB	-6.3	87.4	7.5	2.6	-11.7	89.3	-16.1	90.8	-20.3	92.3	-25.7	94.1
(5)				WB	-6.5	74.0	6.9	2.2	-11.4	75.6	-15.5	76.8	-19.3	78.0	-24.3	79.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	44.8	23.5	26.5	33.9	44.6	54.4	61.1	65.2	62.9	54.8	44.0	36.8	29.1	(6)
(7)		DBStd	16.21	10.75	9.93	7.81	7.47	7.80	6.31	5.66	5.41	5.81	6.45	8.21	9.98	(7)
(8)		HDD50	3494	822	657	501	196	44	1	0	0	23	204	397	649	(8)
(9)		HDD65	7526	1287	1077	965	614	339	151	68	106	309	650	846	1114	(9)
(10)		CDD50	1602	0	0	0	32	179	333	472	400	166	20	0	0	(10)
(11)		CDD65	161	0	0	0	0	10	33	76	41	1	0	0	0	(11)
(12)		CDH74	1298	0	0	0	5	89	281	554	355	14	0	0	0	(12)
(13)		CDH80	249	0	0	0	0	8	46	116	79	0	0	0	0	(13)
(14)	Wind	WSAvg	6.4	7.1	7.1	7.3	7.1	6.1	5.8	5.2	5.5	5.9	6.6	6.6	6.9	(14)
(15)	Precipitation	PrecAvg	22.7	1.4	1.2	1.1	1.3	1.9	2.4	3.1	2.4	2.0	2.4	1.9	1.6	(15)
(16)		PrecMax	28.9	2.8	1.9	2.4	2.7	3.3	5.0	8.2	4.6	3.5	4.1	3.1	2.6	(16)
(17)		PrecMin	18.0	0.5	0.4	0.2	0.2	0.5	0.7	0.1	0.2	0.5	1.0	0.3	0.9	(17)
(18)		PrecStd	2.9	0.6	0.4	0.6	0.7	0.9	1.0	1.8	1.3	0.9	0.9	0.8	0.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.9	43.7	56.3	72.5	81.1	84.8	86.8	87.4	76.4	62.7	52.5	48.5	(19)
(20)		MCWB	42.4	39.9	47.0	55.2	65.2	68.2	70.5	71.3	62.9	56.2	49.3	46.5	(20)	
(21)		2%	DB	40.2	40.7	51.1	67.4	76.3	80.5	83.2	81.4	71.1	59.0	49.7	45.7	(21)
(22)		MCWB	38.9	38.2	44.1	52.5	62.5	67.7	68.7	67.1	60.3	54.7	47.6	43.6	(22)	
(23)		5%	DB	37.8	38.7	47.1	62.7	72.5	77.1	79.8	77.9	67.7	55.9	47.8	42.6	(23)
(24)		MCWB	36.4	37.0	41.8	51.4	60.0	65.2	67.5	65.1	58.6	52.7	46.1	41.1	(24)	
(25)		10%	DB	36.0	36.9	43.7	57.7	68.4	73.6	76.5	74.6	64.6	53.4	46.2	40.3	(25)
(26)		MCWB	34.8	35.5	40.0	48.1	57.9	63.3	65.8	63.2	58.1	50.7	44.8	38.8	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.4	40.5	48.3	56.9	66.6	73.0	72.5	72.6	64.9	57.6	50.2	46.9	(27)
(28)		MCDWB	43.3	42.7	55.4	67.3	77.9	82.0	82.2	82.0	72.9	61.2	51.9	48.2	(28)	
(29)		2%	WB	39.1	38.7	44.8	53.9	64.2	68.5	70.6	68.8	62.1	55.0	48.1	43.6	(29)
(30)		MCDWB	39.9	40.3	49.3	64.9	74.5	77.1	79.9	78.8	67.7	58.0	49.6	45.1	(30)	
(31)		5%	WB	36.6	37.2	42.3	51.7	61.6	66.4	68.7	66.8	60.4	53.0	46.3	41.2	(31)
(32)		MCDWB	37.5	38.5	46.2	61.5	69.7	74.9	76.8	75.4	65.7	55.6	47.6	42.6	(32)	
(33)		10%	WB	35.0	35.6	40.2	48.9	59.0	64.5	67.0	64.8	58.6	51.1	44.8	38.9	(33)
(34)		MCDWB	35.9	36.7	43.6	56.6	66.6	72.4	74.7	72.2	63.6	53.1	46.1	40.2	(34)	
(35)	Mean Daily Temperature Range		MDBR	8.4	8.2	11.4	16.9	18.6	17.6	17.1	17.5	14.2	10.4	6.1	6.2	(35)
(36)		5% DB	MCDBR	6.1	7.7	15.9	25.1	23.4	22.1	21.6	23.4	19.9	12.6	7.5	7.0	(36)
(37)			MCWBR	6.0	6.3	10.6	13.0	11.7	11.2	9.1	10.7	10.9	9.1	6.8	6.4	(37)
(38)			MCDBR	6.1	7.3	14.8	22.6	20.5	20.3	19.1	20.2	16.3	11.8	7.2	6.9	(38)
(39)		5% WB	MCWBR	6.0	6.1	10.4	12.8	11.1	11.3	8.8	10.3	9.9	9.1	6.8	6.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.290	0.322	0.355	0.394	0.384	0.378	0.412	0.408	0.372	0.348	0.332	0.291	(40)	
(41)		taud	2.174	2.165	2.208	2.237	2.322	2.365	2.294	2.305	2.386	2.398	2.259	2.183	(41)	
(42)		Ebn at Noon	187	227	252	260	271	274	261	253	246	221	169	154	(42)	
(43)		Edh at Noon	18	27	33	38	37	36	38	35	28	22	17	14	(43)	
(44)	All-Sky Solar Radiation	RadAvg	152	379	799	1254	1690	1756	1660	1344	899	436	147	94	(44)	
(45)		RadStd	37	78	131	159	157	144	148	133	99	71	23	14	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (32 neighbors)		+0.70	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page