

BAUSKA, Latvia

WMO: 264290

Lat: 56.3792N

Lon: 24.2218E

Elev: 32

StdP: 100.94

Time Zone: 2.00 (EUE)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.8	-15.6	-21.7	0.5	-18.3	-18.8	0.7	-15.0	9.8	-3.2	8.6	-2.9	1.7	160	0.543

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.5	28.2	20.3	26.4	19.2	24.9	18.3	21.2	26.3	20.0	24.7	19.1	23.7	3.0	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.4	14.2	23.8	18.3	13.3	22.3	17.3	12.4	21.3	61.5	26.4	57.4	24.7	54.5	23.8	25.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.0	6.9	6.1	-21.3	30.8	4.2	1.4	-24.3	31.8	-26.7	32.7	-29.1	33.5	-32.1	34.5		
			-21.4	23.3	3.8	1.2	-24.1	24.2	-26.4	24.9	-28.5	25.6	-31.3	26.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.1	-4.7	-3.0	1.0	7.0	12.4	16.1	18.5	17.2	12.6	6.7	2.7	-1.6
	DBStd	9.01	5.97	5.52	4.34	4.15	4.33	3.51	3.14	3.00	3.23	3.58	4.56	5.54
	HDD10.0	1941	457	365	278	109	24	1	0	13	113	221	361	
	HDD18.3	4181	715	598	536	341	188	84	38	59	172	361	470	619
	CDD10.0	890	0	0	0	18	99	185	262	222	92	11	0	0
	CDD18.3	89	0	0	0	6	18	42	23	1	0	0	0	0
	CDH23.3	721	0	0	0	3	49	156	308	197	8	0	0	0
	CDH26.7	138	0	0	0	0	4	26	64	44	0	0	0	0
Wind	WSAvg	2.9	3.2	3.2	3.3	3.2	2.7	2.6	2.3	2.4	2.6	3.0	3.0	3.1
Precipitation	PrecAvg	576	36	31	29	32	49	62	80	61	50	60	47	41
	PrecMax	735	71	48	62	69	84	127	209	118	90	104	80	67
	PrecMin	456	12	11	5	4	12	19	2	4	12	25	7	24
	PrecStd	73	14	10	14	17	23	26	46	33	22	23	20	12
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.6	6.5	13.5	22.5	27.3	29.3	30.5	30.8	24.7	17.1	11.4	9.2
		MCWB	5.8	4.4	8.3	12.9	18.5	20.1	21.4	21.8	17.2	13.4	9.6	8.1
	2%	DB	4.6	4.8	10.6	19.7	24.6	26.9	28.5	27.5	21.7	15.0	9.9	7.6
		MCWB	3.8	3.4	6.7	11.4	16.9	19.9	20.4	19.5	15.7	12.6	8.7	6.5
	5%	DB	3.2	3.7	8.4	17.1	22.5	25.1	26.6	25.5	19.8	13.3	8.8	5.9
		MCWB	2.4	2.8	5.4	10.8	15.5	18.4	19.7	18.4	14.8	11.5	7.8	5.0
	10%	DB	2.2	2.7	6.5	14.3	20.2	23.1	24.7	23.7	18.1	11.9	7.9	4.6
		MCWB	1.6	1.9	4.5	9.0	14.4	17.4	18.8	17.4	14.5	10.4	7.1	3.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.8	4.7	9.1	13.8	19.2	22.8	22.5	22.5	18.3	14.2	10.1	8.3
		MCDB	6.3	6.0	13.0	19.6	25.5	27.8	27.9	27.8	22.7	16.2	11.1	9.0
	2%	WB	4.0	3.7	7.1	12.2	17.9	20.3	21.5	20.4	16.7	12.8	8.9	6.4
		MCDB	4.4	4.6	9.6	18.3	23.6	25.0	26.6	26.0	19.8	14.4	9.8	7.3
	5%	WB	2.6	2.9	5.7	10.9	16.4	19.1	20.4	19.4	15.8	11.7	8.0	5.1
		MCDB	3.1	3.6	7.9	16.4	20.9	23.8	24.9	24.1	18.7	13.1	8.7	5.9
	10%	WB	1.7	2.0	4.5	9.4	15.0	18.0	19.4	18.2	14.8	10.6	7.1	3.8
		MCDB	2.2	2.6	6.4	13.7	19.2	22.4	23.7	22.4	17.6	11.7	7.8	4.5
Mean Daily Temperature Range	5% DB	MDBR	4.6	4.5	6.3	9.4	10.3	9.8	9.5	9.7	7.9	5.8	3.4	3.5
		MCDBR	3.4	4.3	8.9	14.0	13.0	12.3	12.0	13.0	11.1	7.0	4.2	3.9
		MCWBR	3.3	3.5	5.9	7.2	6.5	6.2	5.0	6.0	6.1	5.0	3.8	3.6
	5% WB	MCDBR	3.4	4.1	8.2	12.5	11.4	11.3	10.6	11.2	9.0	6.6	4.0	3.8
		MCWBR	3.3	3.4	5.8	7.1	6.1	6.3	4.9	5.7	5.5	5.1	3.8	3.6
Clear-Sky Solar Irradiance	taub	0.290	0.322	0.355	0.394	0.384	0.378	0.412	0.408	0.372	0.348	0.332	0.291	
	taud	2.174	2.165	2.208	2.237	2.322	2.365	2.294	2.305	2.386	2.398	2.259	2.183	
	Ebn at Noon	588	717	794	820	855	864	822	798	777	697	534	484	
	Edh at Noon	56	85	105	119	116	113	119	111	89	69	54	44	
All-Sky Solar Radiation	RadAvg	0.48	1.20	2.52	3.95	5.33	5.54	5.23	4.24	2.83	1.38	0.46	0.30	
	RadStd	0.12	0.25	0.41	0.50	0.49	0.45	0.47	0.42	0.31	0.23	0.07	0.04	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (32 neighbors)		+0.39	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page