

SKRIVERI, Latvia

WMO: 264350

Lat: 56.6425N

Lon: 25.1283E

Elev: 81

StdP: 100.36

Time Zone: 2.00 (EUE)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-20.2	-16.6	-23.1	0.5	-19.4	-19.8	0.7	-16.2	7.3	1.7	6.5	-0.4	1.3	50	0.528

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.2	28.2	19.8	26.4	18.7	24.8	17.9	21.0	25.9	19.8	24.3	18.8	23.4	2.6	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.2	14.1	23.7	18.1	13.1	21.9	17.1	12.3	21.0	61.0	26.0	57.0	24.3	53.7	23.5	25.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.2	5.4	4.9	DB	-23.1	30.7	4.6	1.4	-26.4	31.7	-29.1	32.6	-31.7	33.3	-35.0	34.4	(4)
(5)			WB	-23.4	22.6	4.5	1.1	-26.6	23.4	-29.3	24.1	-31.8	24.7	-35.1	25.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	6.7	-5.1	-3.6	0.4	6.5	12.1	16.0	18.1	17.1	12.1	5.9	2.0	-2.0	(6)	
	DBStd	9.14	5.94	5.95	4.39	4.28	4.50	3.71	3.27	2.97	3.07	3.63	4.63	5.56	(7)	
	HDD10.0	2059	468	381	298	123	29	2	0	0	15	133	239	371	(8)	
	HDD18.3	4335	726	614	557	356	198	90	45	61	187	384	488	629	(9)	
	CDD10.0	852	0	0	0	17	95	182	252	221	78	7	0	0	(10)	
	CDD18.3	86	0	0	0	0	6	19	38	22	1	0	0	0	(11)	
	CDH23.3	698	0	0	0	1	52	174	279	187	5	0	0	0	(12)	
	CDH26.7	127	0	0	0	0	3	26	58	40	0	0	0	0	(13)	
(14) Wind	WSAvg	2.4	2.7	2.6	2.7	2.5	2.1	2.2	2.0	1.9	2.1	2.4	2.6	2.7	(14)	
(15) Precipitation	PrecAvg	744	57	44	41	41	61	80	82	83	61	76	64	55	(15)	
	PrecMax	931	126	74	83	88	124	149	177	174	107	158	114	85	(16)	
	PrecMin	537	21	14	9	10	10	24	5	9	10	10	3	35	(17)	
	PrecStd	106	24	15	19	21	30	34	42	47	26	31	26	12	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.1	6.0	13.3	21.8	27.0	28.9	30.2	30.4	23.8	16.1	11.1	8.6	(19)	
		MCWB	5.4	3.8	7.6	11.7	18.1	19.2	21.9	21.6	16.5	13.1	9.9	7.7	(20)	
	2%	DB	4.1	4.7	10.1	19.6	24.7	27.2	28.3	27.4	21.0	13.9	9.5	6.8	(21)	
		MCWB	3.4	3.3	5.9	10.7	16.7	18.8	20.3	19.6	15.3	12.2	8.4	6.0	(22)	
	5%	DB	2.6	3.5	7.7	17.0	22.5	25.5	26.5	25.2	19.1	12.5	8.3	5.3	(23)	
		MCWB	2.0	2.6	4.7	9.8	15.1	17.9	19.4	18.1	14.4	11.0	7.5	4.7	(24)	
	10%	DB	1.8	2.6	6.0	14.3	20.3	23.4	24.5	23.5	17.4	11.4	7.4	4.2	(25)	
		MCWB	1.3	1.9	3.7	8.4	13.9	16.9	18.6	17.5	14.0	10.1	6.7	3.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.5	4.3	8.5	12.9	18.9	20.9	22.7	23.1	17.6	13.9	10.4	8.0	(27)	
		MCDB	6.0	5.2	12.7	18.6	24.9	25.6	28.5	28.0	21.0	15.6	11.0	8.6	(28)	
	2%	WB	3.6	3.4	6.4	11.5	17.6	19.7	21.3	20.6	16.2	12.4	8.7	6.0	(29)	
		MCDB	3.9	4.1	8.7	17.7	23.1	24.9	26.5	25.6	18.9	13.5	9.3	6.6	(30)	
	5%	WB	2.2	2.7	5.0	10.4	16.1	18.7	20.2	19.1	15.3	11.4	7.7	4.7	(31)	
		MCDB	2.5	3.3	7.3	15.6	20.7	23.6	24.6	23.7	17.8	12.3	8.3	5.3	(32)	
	10%	WB	1.3	1.9	3.9	9.0	14.8	17.6	19.1	18.1	14.4	10.3	6.8	3.5	(33)	
		MCDB	1.7	2.5	5.8	14.2	19.5	22.1	23.4	22.5	16.7	11.2	7.4	4.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.4	4.9	6.6	9.6	10.6	9.9	9.2	9.8	7.9	5.7	3.4	3.4	(35)	
		MCDBR	3.4	4.2	8.7	13.6	13.2	12.6	11.9	12.8	11.1	6.7	4.2	3.6	(36)	
	5% WB	MCWBR	3.3	3.4	5.5	6.8	6.2	5.5	4.9	5.7	6.2	4.9	3.8	3.4	(37)	
		MCWBR	3.4	3.8	7.8	11.7	11.3	10.8	10.4	10.8	8.5	5.6	4.0	3.5	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.286	0.317	0.350	0.389	0.379	0.375	0.407	0.405	0.369	0.345	0.329	0.286	(40)	
		taud	2.164	2.156	2.197	2.257	2.351	2.388	2.318	2.323	2.401	2.407	2.257	2.176	(41)	
	Ebn at Noon		584	719	797	824	859	866	826	800	779	698	530	480	(42)	
		Edh at Noon	56	85	106	117	113	110	116	109	87	68	53	43	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.46	1.18	2.51	3.93	5.32	5.53	5.25	4.23	2.79	1.34	0.44	0.28	(44)	
	RadStd		0.12	0.24	0.41	0.48	0.50	0.46	0.47	0.41	0.30	0.22	0.07	0.04	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (31 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page