

ZILANI, Latvia

WMO: 264360

Lat: 56.5200N

Lon: 25.9183E

Elev: 354

StdP: 14.51

Time Zone: 2.00 (EUE)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.6	0.6	-10.9	3.1	-5.0	-5.0	4.3	1.7	19.5	33.3	17.1	32.8	3.0	80	0.535

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.5	82.4	67.8	79.3	65.7	76.3	64.3	69.9	79.4	67.8	75.8	65.9	73.6	4.6	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.5	98.7	75.4	64.6	92.6	72.0	62.9	87.0	70.1	34.1	79.5	32.3	76.1	30.9	73.4	75.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.3	13.9	12.0	DB	-11.7	87.1	7.3	2.6	-16.9	89.0	-21.2	90.5	-25.3	92.0	-30.5	93.9	(4)
(5)			WB	-12.1	72.8	7.2	2.0	-17.3	74.2	-21.5	75.4	-25.5	76.5	-30.8	77.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	43.8	22.4	24.4	32.1	43.9	54.0	61.0	64.7	62.1	53.5	42.9	36.3	27.5	(6)	
	DBStd	16.63	10.91	11.29	8.01	7.61	7.95	6.52	5.88	5.40	5.82	6.67	7.14	9.80	(7)	
	HDD50	3769	856	718	555	214	50	3	0	0	32	235	410	696	(8)	
	HDD65	7870	1321	1138	1020	633	350	155	79	122	347	684	860	1161	(9)	
	CDD50	1522	0	0	0	31	174	332	457	376	136	16	0	0	(10)	
	CDD65	147	0	0	0	0	9	34	70	33	1	0	0	0	(11)	
	CDH74	1190	0	0	0	3	92	279	528	279	9	0	0	0	(12)	
	CDH80	223	0	0	0	0	6	41	120	56	0	0	0	0	(13)	
(14) Wind	WSAvg	5.5	6.0	5.6	6.3	5.9	5.0	5.0	4.5	4.4	5.1	5.7	5.9	6.1	(14)	
(15) Precipitation	PrecAvg	27.5	2.1	1.8	1.6	1.4	2.3	3.1	2.8	2.7	2.3	3.0	2.3	2.0	(15)	
	PrecMax	33.6	4.0	3.1	3.1	3.7	5.5	5.2	8.3	5.4	3.7	5.4	4.1	3.0	(16)	
	PrecMin	19.6	0.7	0.7	0.2	0.1	0.4	0.6	0.6	0.4	0.7	1.1	0.0	1.3	(17)	
	PrecStd	3.4	0.9	0.6	0.8	0.9	1.3	1.4	1.9	1.5	0.9	1.1	0.9	0.5	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.3	42.3	55.3	72.5	80.9	84.1	87.3	86.2	75.4	62.6	51.8	44.5	(19)	
		MCWB	41.0	39.6	44.5	54.7	64.0	66.6	71.3	72.6	62.1	55.3	49.5	42.5	(20)	
	2%	DB	39.1	39.9	49.9	66.9	76.4	80.7	83.3	80.0	70.0	58.0	48.7	41.9	(21)	
		MCWB	37.8	37.7	42.0	51.5	62.0	65.9	69.0	65.9	59.6	53.8	46.6	40.5	(22)	
	5%	DB	36.4	37.4	45.5	62.1	72.8	77.3	79.7	76.4	66.4	54.8	46.8	40.1	(23)	
		MCWB	35.3	35.7	40.2	50.2	59.2	64.5	67.3	64.4	57.7	51.9	45.0	38.8	(24)	
	10%	DB	34.7	35.8	42.3	57.6	68.6	73.7	76.2	73.6	63.3	52.5	45.1	38.1	(25)	
		MCWB	33.8	34.5	38.6	47.2	56.9	62.8	65.4	63.2	56.8	50.1	43.7	36.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.4	40.3	46.6	56.3	65.9	71.2	72.8	73.4	63.9	56.7	49.7	43.2	(27)	
		MCDB	42.4	41.7	54.0	68.4	77.9	82.0	84.4	83.9	70.5	60.8	51.4	44.1	(28)	
	2%	WB	38.1	38.0	43.3	53.1	63.5	67.5	70.5	69.0	61.2	54.3	47.2	40.7	(29)	
		MCDB	38.8	39.4	47.2	63.6	73.5	76.4	80.9	77.4	66.8	57.1	48.5	41.7	(30)	
	5%	WB	35.5	36.1	40.7	50.8	60.9	65.9	68.6	66.3	59.3	52.4	45.2	38.8	(31)	
		MCDB	36.2	37.2	44.5	60.4	69.5	74.5	77.0	74.0	64.9	54.6	46.5	39.9	(32)	
	10%	WB	33.9	34.7	38.8	48.2	58.4	63.9	66.7	64.2	57.5	50.5	43.7	36.9	(33)	
		MCDB	34.5	35.7	42.2	56.3	66.7	72.2	73.7	71.5	62.1	52.4	45.0	38.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.7	8.6	11.7	16.8	19.1	16.9	16.5	17.3	13.6	9.6	5.9	6.0	(35)	
		MCDBR	6.1	7.2	15.4	24.3	24.0	21.9	21.6	22.9	20.0	12.6	7.2	6.4	(36)	
	5% WB	MCWBR	6.1	5.7	10.0	12.5	11.6	9.8	9.2	10.5	10.8	9.0	6.6	6.2	(37)	
		MCWBR	6.2	6.9	13.6	21.4	20.7	18.7	18.8	19.4	15.9	11.4	7.2	6.5	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.286	0.318	0.351	0.390	0.381	0.375	0.407	0.405	0.369	0.345	0.328	0.285	(40)	
		taud	2.173	2.160	2.199	2.246	2.341	2.384	2.313	2.314	2.391	2.399	2.256	2.183	(41)	
	Ebn at Noon		187	228	253	261	272	275	262	254	247	221	170	154	(42)	
		Edh at Noon	18	27	34	37	36	35	37	35	28	22	17	14	(43)	
(44) All-Sky Solar Radiation	RadAvg		152	385	813	1247	1682	1753	1659	1341	882	419	138	91	(44)	
	RadStd		38	78	128	157	160	144	158	128	95	70	23	16	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (25 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page