

REZEKNE, Latvia

WMO: 264460

Lat: 56.5447N

Lon: 27.2806E

Elev: 519

StdP: 14.42

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.1	-0.5	-11.3	3.0	-5.2	-5.6	4.1	0.5	19.4	33.0	17.8	31.2	3.5	70	0.565

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.7	81.9	67.2	78.6	65.4	75.7	63.9	69.5	78.6	67.4	75.4	65.5	72.8	6.1	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.0	97.7	74.5	64.3	92.1	71.9	62.7	86.7	69.7	33.8	78.0	32.1	75.6	30.6	72.9	79.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.2	15.3	13.7	-13.5	86.2	6.8	2.8	-18.4	88.2	-22.4	89.8	-26.3	91.4	-31.3	93.4		
(5)			-13.9	72.3	6.8	3.1	-18.8	74.5	-22.7	76.3	-26.6	78.0	-31.5	80.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	42.9	21.4	22.9	30.9	44.1	53.2	59.9	64.0	61.4	52.5	42.6	33.6	26.6	(6)
(7)		DBStd	16.96	10.82	11.73	7.90	8.41	7.99	6.66	5.99	5.48	6.06	6.80	8.82	10.21	(7)
(8)		HDD50	4019	885	758	593	217	57	4	0	0	43	245	492	725	(8)
(9)		HDD65	8199	1350	1178	1058	626	372	179	92	142	375	695	942	1190	(9)
(10)		CDD50	1423	0	0	0	41	158	303	435	352	119	15	0	0	(10)
(11)		CDD65	128	0	0	0	0	7	28	63	29	1	0	0	0	(11)
(12)		CDH74	1024	0	0	0	3	69	210	486	246	10	0	0	0	(12)
(13)		CDH80	184	0	0	0	0	7	23	109	45	0	0	0	0	(13)
(14)	Wind	WSAvg	6.4	7.0	7.1	7.3	6.6	6.1	5.7	5.2	5.0	5.7	6.6	7.0	7.1	(14)
(15)	Precipitation	PrecAvg	25.9	1.9	1.5	1.3	1.3	2.6	3.2	2.7	2.8	2.2	2.5	2.1	1.8	(15)
(16)		PrecMax	32.3	3.7	2.4	3.4	3.0	5.4	7.3	7.0	5.2	4.1	4.7	4.5	3.3	(16)
(17)		PrecMin	19.8	0.6	0.5	0.6	0.0	0.8	0.9	0.6	0.4	0.6	0.5	0.0	1.0	(17)
(18)		PrecStd	3.3	0.7	0.5	0.6	0.8	1.2	1.6	1.5	1.4	1.0	1.1	0.9	0.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.5	42.5	54.3	73.5	80.8	82.8	87.0	85.2	75.1	63.0	50.8	46.3	(19)
(20)			MCWB	40.3	38.0	43.6	55.5	63.3	66.2	70.0	70.6	63.3	54.9	48.4	44.7	(20)
(21)		2%	DB	37.8	39.1	48.3	68.9	75.3	79.5	83.1	80.0	69.1	58.3	48.5	43.1	(21)
(22)			MCWB	36.7	36.9	40.4	52.8	61.7	65.1	68.8	66.1	60.0	52.9	46.4	41.5	(22)
(23)		5%	DB	35.5	37.3	44.1	63.7	71.3	76.2	79.3	76.3	65.7	54.7	46.1	40.4	(23)
(24)			MCWB	34.4	35.5	39.0	51.1	58.9	64.2	67.0	63.7	57.9	51.4	44.4	39.3	(24)
(25)		10%	DB	34.0	35.7	41.0	58.7	67.5	72.8	75.9	72.8	62.6	52.3	44.1	38.2	(25)
(26)			MCWB	33.1	34.3	37.3	48.5	56.6	62.6	64.9	62.1	56.7	49.6	42.9	37.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	40.4	39.4	45.5	57.4	65.6	69.6	72.6	72.0	64.7	56.4	49.3	45.4	(27)
(28)			MCD B	41.3	40.9	52.2	70.7	76.4	78.5	84.1	83.1	70.9	61.2	50.2	46.0	(28)
(29)		2%	WB	37.1	37.1	42.0	54.4	63.0	67.3	70.1	68.6	61.6	53.7	46.7	41.6	(29)
(30)			MCD B	37.8	38.4	45.7	65.1	72.6	75.8	80.0	76.9	66.7	56.8	48.0	42.7	(30)
(31)		5%	WB	34.7	35.8	39.6	52.1	60.6	65.4	68.3	65.7	59.4	51.9	44.6	39.5	(31)
(32)			MCD B	35.2	37.2	43.3	62.0	68.7	73.5	76.8	72.9	64.4	54.6	45.8	40.4	(32)
(33)		10%	WB	33.2	34.5	37.6	49.7	58.1	63.5	66.3	63.6	57.2	49.8	42.9	37.1	(33)
(34)			MCD B	33.8	35.6	40.7	57.7	65.5	71.2	73.2	70.4	61.7	52.1	44.0	38.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.7	9.4	11.5	16.1	18.4	16.5	16.7	17.3	14.0	10.5	6.8	6.4	(35)
(36)			MCDBR	5.7	6.9	15.2	23.2	22.8	21.1	21.7	22.4	19.0	13.8	8.2	6.5	(36)
(37)			MCWBR	5.6	5.7	10.2	11.6	11.7	10.2	9.5	10.2	11.2	9.5	7.4	6.2	(37)
(38)		5% WB	MCDBR	5.7	7.4	12.9	20.4	20.1	18.2	19.3	19.9	16.6	12.9	7.7	6.1	(38)
(39)			MCWBR	5.7	6.7	9.6	11.3	11.4	9.9	9.4	10.4	10.8	9.6	7.1	6.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.281	0.314	0.344	0.385	0.377	0.370	0.401	0.401	0.365	0.341	0.321	0.279	(40)	
(41)		taud	2.163	2.150	2.194	2.260	2.349	2.393	2.327	2.321	2.398	2.401	2.255	2.174	(41)	
(42)		Ebn at Noon	189	230	255	263	273	276	264	255	249	223	172	156	(42)	
(43)		Edh at Noon	18	27	34	37	36	35	36	35	28	22	17	14	(43)	
(44)	All-Sky Solar Radiation	RadAvg	156	397	835	1251	1681	1756	1658	1340	875	406	136	92	(44)	
(45)		RadStd	38	77	120	160	162	138	167	124	91	71	23	18	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (20 neighbors)		+0.70	N/A	N/A	N/A	N/A	N/A	-245	N/A	N/A	N/A	

Nomenclature: See separate page