

RZHEV, Russian Federation

WMO: 264980

Lat: 56.267N

Lon: 34.317E

Elev: 196

StdP: 98.99

Time Zone: 3.00 (E03)

Period: 90-98

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-23.4	-19.7	-25.6	0.4	-22.7	-22.4	0.5	-19.1	6.7	-0.9	5.4	-0.7	0.8	90	0.541

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.8	27.0	19.4	25.2	18.5	23.6	17.5	20.6	25.2	19.4	23.8	18.4	22.4	1.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.8	14.0	23.2	17.7	13.0	21.6	16.7	12.2	20.5	60.2	24.9	56.0	23.8	52.7	22.5	24.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5.8	5.0	4.3	-27.7	29.4	3.0	2.2	-29.9	30.9	-31.6	32.2	-33.3	33.5	-35.4	35.1
			-27.9	22.8	2.9	1.4	-30.0	23.7	-31.7	24.6	-33.3	25.3	-35.5	26.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	5.0	-6.0	-5.8	-1.1	5.6	11.7	15.8	17.1	15.8	10.1	4.5	-1.8	-6.1		
	DBStd	9.85	5.75	6.63	4.15	4.66	4.12	3.60	3.01	3.36	4.27	4.51	5.40	6.09		
	HDD10.0	2538	496	442	346	147	28	1	0	1	48	175	354	500		
	HDD18.3	4908	754	675	604	382	209	95	58	94	247	428	604	758		
	CDD10.0	730	0	0	0	16	81	174	222	179	53	6	0	0		
	CDD18.3	58	0	0	0	0	4	18	21	14	1	0	0	0		
	CDH23.3	414	0	0	0	1	28	108	169	97	12	0	0	0		
	CDH26.7	65	0	0	0	0	4	14	33	12	2	0	0	0		
(14) Wind	WSAvg	1.8	2.2	2.2	2.1	1.8	1.8	1.6	1.5	1.4	1.6	1.8	1.8	1.9		
(15) Precipitation	PrecAvg	626	36	31	31	36	58	78	82	70	61	47	47	47		
	PrecMax	778	84	83	76	78	111	182	152	174	157	146	114	101		
	PrecMin	447	2	6	7	6	16	4	12	10	11	1	1	12		
	PrecStd	83	19	19	18	20	28	42	39	42	35	29	22	21		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.2	6.0	10.0	22.1	27.0	28.6	29.9	28.2	24.7	17.1	9.4	3.5		
		MCWB	2.7	4.2	5.9	12.5	18.0	21.2	20.4	21.2	17.6	12.5	8.4	3.1		
	2%	DB	2.4	4.5	7.0	18.9	23.2	26.2	27.2	25.7	21.0	14.3	7.6	2.2		
		MCWB	1.4	3.3	3.6	11.3	15.1	19.0	19.8	18.7	15.9	11.3	6.8	1.6		
	5%	DB	1.6	3.1	5.2	16.2	21.3	24.5	24.9	24.1	18.0	12.1	6.0	1.6		
		MCWB	0.8	1.9	3.3	9.5	14.4	18.5	18.4	17.9	14.6	10.0	5.4	0.9		
	10%	DB	1.0	2.1	4.0	13.8	19.0	22.6	23.2	22.4	15.9	10.7	4.7	0.7		
		MCWB	0.4	1.0	2.2	8.7	13.2	17.3	17.7	17.1	13.6	9.0	4.2	0.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.2	4.7	6.9	13.1	18.6	21.8	22.1	22.0	18.6	13.6	8.5	3.2		
		MCDB	3.8	5.4	9.6	20.3	25.5	27.0	28.3	25.2	23.3	15.5	9.2	3.4		
	2%	WB	1.6	3.2	5.1	11.7	16.8	20.2	20.5	19.8	16.5	11.7	7.0	1.9		
		MCDB	2.2	4.3	6.2	17.3	21.8	24.7	25.3	24.1	19.1	13.2	7.6	2.2		
	5%	WB	1.0	2.3	3.6	10.4	15.2	19.1	19.3	18.5	14.9	10.6	5.4	1.1		
		MCDB	1.5	3.1	4.8	15.1	19.5	23.4	23.6	22.6	17.4	12.0	5.9	1.5		
	10%	WB	0.4	1.2	2.4	8.9	13.8	18.0	18.2	17.5	13.7	9.1	4.3	0.1		
		MCDB	0.9	1.8	3.7	13.0	18.1	21.4	22.0	21.4	16.0	10.5	4.8	0.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.9	5.7	6.1	8.3	9.1	8.8	8.8	8.8	6.9	5.7	4.0	4.0		
		MCDBR	4.1	4.1	6.5	12.9	12.4	10.5	12.1	12.4	10.1	8.3	3.8	3.0		
	5% WB	MCWBR	4.0	3.6	4.4	6.4	5.9	4.8	5.8	6.1	5.6	5.6	3.5	3.0		
		MCWBR	4.0	4.1	5.0	11.5	10.4	9.3	10.6	10.6	9.1	6.9	3.8	2.9		
(40) Clear-Sky Solar Irradiance	taub	taub	0.281	0.317	0.337	0.396	0.387	0.368	0.400	0.410	0.364	0.343	0.316	0.277		
		taud	2.133	2.096	2.161	2.196	2.328	2.401	2.327	2.291	2.393	2.388	2.248	2.137		
	Edn at Noon	Edn at Noon	596	718	812	816	852	874	834	796	786	703	556	498		
		Edh at Noon	58	91	110	124	116	109	115	112	88	69	53	45		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.54	1.37	2.87	3.98	5.22	5.48	5.35	4.25	2.75	1.26	0.46	0.30		
	RadStd	RadStd	0.11	0.20	0.32	0.38	0.45	0.53	0.56	0.46	0.35	0.24	0.09	0.09		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (9 neighbors)		+0.69	N/A	N/A	N/A	N/A	N/A	-157	-228	+97	N/A	

Nomenclature: See separate page