

PALANGA INTL, Lithuania

WMO: 265020

Lat: 55.973N

Lon: 21.094E

Elev: 33

StdP: 14.68

Time Zone: 2.00 (EUE)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	4.6	10.1	-1.9	5.0	7.4	2.9	6.4	12.3	22.1	34.9	20.5	34.4	6.2	70	0.568

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.4	82.3	68.5	78.6	66.2	75.0	64.9	71.0	77.6	68.6	75.0	66.6	72.5	9.5	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.4	104.3	73.3	66.3	96.9	71.7	64.4	90.6	69.7	34.8	77.6	32.8	73.9	31.1	72.2	82.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.6	17.3	15.6	0.7	88.4	7.3	4.4	-4.6	91.5	-8.9	94.1	-13.0	96.6	-18.3	99.8		
(5)			0.1	74.8	7.1	3.4	-5.0	77.2	-9.2	79.1	-13.2	81.0	-18.3	83.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	46.8	29.1	29.3	34.7	44.3	52.6	59.0	64.3	64.0	57.2	48.2	41.3	36.7
	DBStd	14.09	9.62	8.91	6.88	7.59	7.87	6.30	5.28	4.74	5.26	6.40	6.33	7.34
	HDD50	2768	649	580	474	209	56	3	0	0	10	112	263	412
	HDD65	6771	1114	1000	939	623	394	203	77	74	238	520	712	877
	CDD50	1607	0	0	1	38	136	272	443	435	224	57	1	0
	CDD65	135	0	0	0	1	10	22	55	44	3	0	0	0
	CDH74	925	0	0	0	13	97	180	361	258	16	0	0	0
	CDH80	202	0	0	0	0	13	41	91	55	2	0	0	0
Wind	WSAvg	7.7	8.9	8.3	7.7	7.2	6.9	6.8	6.5	6.7	7.3	8.5	8.8	8.8
Precipitation	PrecAvg	29.4	2.5	1.7	1.6	1.3	1.6	2.1	2.9	3.4	3.0	3.5	3.0	2.9
	PrecMax	40.2	5.6	3.7	3.5	3.0	4.4	3.8	8.4	7.5	6.6	7.1	6.0	5.9
	PrecMin	21.8	0.6	0.4	0.2	0.2	0.4	0.5	0.0	0.1	0.6	0.4	0.5	1.2
	PrecStd	4.4	1.1	0.7	0.8	0.7	0.9	0.9	1.7	1.9	1.4	1.6	1.5	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.2	44.6	58.7	75.2	81.0	84.6	87.7	85.9	75.5	65.8	53.3	49.8
		MCWB	45.0	41.5	47.9	60.5	65.4	67.3	71.4	70.9	64.9	58.2	49.8	47.7
	2%	DB	44.3	41.4	51.4	67.8	76.7	78.9	82.6	80.4	70.1	60.9	51.7	47.9
		MCWB	43.1	40.0	45.2	54.2	62.6	65.2	68.5	69.0	61.9	56.2	49.3	46.6
	5%	DB	42.6	40.5	45.0	62.5	71.4	73.7	78.5	76.7	67.9	58.9	50.2	46.4
		MCWB	41.5	39.4	41.5	51.4	59.5	63.0	67.4	66.3	60.5	55.2	48.4	45.3
	10%	DB	40.8	39.1	42.6	57.1	66.1	69.9	73.8	73.2	64.8	57.1	48.6	44.9
		MCWB	39.7	38.1	40.3	48.3	57.1	61.3	65.9	65.0	59.5	54.2	47.0	43.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.8	42.1	49.8	61.2	67.3	71.4	74.1	75.1	66.3	59.4	51.2	48.0
		MCDB	45.1	42.9	54.9	73.9	77.1	79.6	82.6	78.9	74.0	62.5	52.1	48.4
	2%	WB	42.7	40.3	45.1	56.0	64.0	67.6	71.1	71.1	63.7	57.2	50.0	46.4
		MCDB	43.1	41.0	49.6	64.2	74.0	75.4	78.0	76.7	68.1	60.3	50.7	46.9
	5%	WB	41.0	39.0	42.2	51.8	60.9	64.8	69.0	68.2	61.9	55.8	48.9	45.0
		MCDB	41.8	39.7	44.6	60.3	68.7	71.3	75.7	74.1	65.7	58.1	49.7	45.8
	10%	WB	39.3	37.6	40.0	49.0	58.2	62.7	67.0	66.0	60.3	54.6	47.4	43.7
		MCDB	40.1	38.4	41.6	56.5	65.1	68.7	72.6	70.9	64.2	57.0	48.5	44.6
Mean Daily Temperature Range	5% DB	MDBR	7.9	8.4	11.0	15.9	16.5	14.4	13.4	13.8	13.2	10.7	7.1	6.6
		MCDBR	5.5	7.6	15.2	23.9	22.9	21.9	20.1	19.9	16.7	12.4	8.0	4.9
		MCWBR	5.9	6.4	10.7	13.9	12.2	11.5	9.9	10.5	10.0	8.6	7.3	5.0
	5% WB	MCDBR	5.7	7.2	13.5	22.7	21.2	18.2	16.8	16.4	13.2	10.5	6.9	4.8
		MCWBR	6.1	6.4	10.0	14.2	12.6	11.3	9.9	10.6	9.2	8.4	7.1	5.3
Clear-Sky Solar Irradiance	taub	0.305	0.332	0.357	0.394	0.385	0.380	0.412	0.407	0.372	0.353	0.340	0.305	
	taud	2.232	2.261	2.281	2.252	2.346	2.395	2.327	2.339	2.413	2.397	2.279	2.216	
	Ebn at Noon	187	229	254	260	272	274	261	254	248	221	171	154	
	Edh at Noon	18	25	31	37	36	35	37	34	28	22	17	14	
All-Sky Solar Radiation	RadAvg	128	335	769	1344	1786	1871	1707	1388	961	460	161	88	
	RadStd	22	53	77	152	148	102	155	140	103	66	23	10	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (15 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page