

KLAIPEDA, Lithuania

WMO: 265090

Lat: 55.7314N

Lon: 21.0917E

Elev: 24

StdP: 14.68

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.6	10.8	-1.6	5.1	8.4	3.1	6.5	12.1	35.1	39.2	31.5	35.6	6.5	70	0.584

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.1	81.3	68.2	77.4	66.4	74.3	65.1	70.5	77.9	68.3	75.0	66.4	72.5	7.2	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.8	102.3	74.3	65.6	94.7	72.2	63.8	88.7	70.3	34.4	77.8	32.6	75.0	31.0	72.7	77.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.1	22.1	18.6	DB	1.4	87.2	6.5	4.0	-3.3	90.1	-7.1	92.4	-10.7	94.6	-15.4	97.5	(4)
(5)			WB	0.7	73.4	6.2	2.5	-3.8	75.2	-7.5	76.7	-11.0	78.1	-15.5	79.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	46.6	29.3	29.8	34.7	44.0	52.5	59.1	64.6	64.7	57.5	48.1	39.8	33.7	(6)
(7)		DBStd	14.36	9.21	8.47	6.02	7.25	7.55	5.64	5.24	4.57	5.19	6.33	7.12	8.40	(7)
(8)		HDD50	2881	640	567	476	212	53	1	0	0	8	112	306	506	(8)
(9)		HDD65	6863	1105	987	941	630	397	195	69	61	226	525	756	971	(9)
(10)		CDD50	1633	0	0	1	33	130	273	454	455	234	52	1	0	(10)
(11)		CDD65	138	0	0	0	0	9	17	58	51	3	0	0	0	(11)
(12)		CDH74	769	0	0	0	4	69	120	337	229	10	0	0	0	(12)
(13)		CDH80	155	0	0	0	0	9	25	77	43	1	0	0	0	(13)
(14)	Wind	WSAvg	9.1	10.9	10.3	9.2	8.1	7.5	7.8	7.4	7.5	8.3	9.9	10.6	11.2	(14)
(15)	Precipitation	PrecAvg	28.3	2.1	1.4	1.5	1.4	1.5	2.2	2.8	3.1	3.3	3.3	3.3	2.7	(15)
(16)		PrecMax	40.2	4.2	4.1	3.1	3.9	3.3	4.5	6.7	6.6	6.6	9.4	6.6	5.3	(16)
(17)		PrecMin	15.5	0.3	0.1	0.2	0.1	0.1	0.5	0.0	0.2	0.6	0.8	0.7	0.2	(17)
(18)		PrecStd	5.2	1.1	0.8	0.8	0.9	0.8	1.0	1.5	1.8	1.6	2.0	1.4	1.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.2	43.5	55.6	73.3	81.1	83.8	86.6	84.6	74.7	63.9	52.2	48.2	(19)
(20)			MCWB	43.3	40.3	45.9	59.5	65.1	69.7	71.5	70.8	64.8	57.3	49.8	46.4	(20)
(21)		2%	DB	43.0	41.4	48.8	66.0	75.0	77.1	82.1	79.6	70.1	60.2	51.0	46.4	(21)
(22)			MCWB	41.5	39.2	42.8	54.0	61.9	65.3	69.1	67.9	62.0	55.8	48.9	44.6	(22)
(23)		5%	DB	41.2	39.9	44.0	60.4	69.8	72.6	77.5	75.8	67.3	58.1	49.8	44.9	(23)
(24)			MCWB	39.6	38.3	40.2	50.8	59.9	63.2	67.8	66.0	60.6	54.6	47.9	43.1	(24)
(25)		10%	DB	39.4	38.8	41.3	55.6	65.1	68.6	74.1	73.0	65.0	56.4	48.5	43.4	(25)
(26)			MCWB	37.9	37.4	38.5	48.3	57.0	61.3	66.2	65.0	59.6	53.5	46.6	41.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.9	41.2	46.7	60.3	66.6	71.0	74.7	73.2	66.2	58.8	50.9	47.0	(27)
(28)			MCD B	44.6	42.4	53.4	72.0	78.5	81.4	83.5	81.3	71.7	61.1	51.7	47.8	(28)
(29)		2%	WB	41.9	39.6	43.0	55.4	63.4	67.3	71.2	69.9	63.7	56.6	49.5	44.9	(29)
(30)			MCD B	42.9	40.7	47.7	65.2	72.4	74.8	78.4	76.8	68.1	59.1	50.4	46.0	(30)
(31)		5%	WB	39.8	38.6	40.8	51.6	60.1	64.5	68.8	67.8	61.9	55.1	48.3	43.4	(31)
(32)			MCD B	40.9	39.7	43.3	58.8	68.0	70.3	75.6	73.5	65.7	57.4	49.4	44.6	(32)
(33)		10%	WB	38.1	37.6	39.1	49.0	57.6	61.9	66.8	66.0	60.4	53.9	46.9	41.9	(33)
(34)			MCD B	39.2	38.8	40.8	54.9	64.5	67.4	73.1	71.4	64.1	56.3	48.3	43.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.8	6.9	8.4	11.9	13.1	11.4	11.1	11.8	10.9	8.5	6.2	6.5	(35)
(36)			MCDBR	5.0	5.4	12.2	20.1	19.9	19.3	18.2	17.5	14.8	10.2	6.0	4.4	(36)
(37)			MCWBR	5.3	4.6	8.0	11.6	10.6	10.5	9.6	9.2	9.0	7.3	5.8	4.5	(37)
(38)		5% WB	MCD BR	4.9	4.9	10.4	18.0	18.2	16.2	15.2	14.5	11.6	8.2	5.5	4.6	(38)
(39)			MCWBR	5.2	4.4	7.6	11.2	10.4	9.8	9.3	9.1	8.4	6.9	5.8	4.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.308	0.334	0.360	0.398	0.388	0.384	0.415	0.410	0.375	0.355	0.342	0.307	(40)	
(41)		taud	2.238	2.260	2.275	2.243	2.345	2.394	2.324	2.335	2.410	2.400	2.282	2.223	(41)	
(42)		Ebn at Noon	188	229	253	260	271	273	261	254	247	221	172	156	(42)	
(43)		Edh at Noon	18	25	32	38	36	35	37	34	28	22	17	15	(43)	
(44)	All-Sky Solar Radiation	RadAvg	130	338	771	1343	1783	1860	1701	1390	968	465	166	91	(44)	
(45)		RadStd	23	55	73	153	150	108	159	142	104	68	23	10	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.79	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+117	N/A
(47) Regional (16 neighbors)		+0.76	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+94	N/A

Nomenclature: See separate page