

LAUKUVA, Lithuania

WMO: 265180

Lat: 55.6089N

Lon: 22.2394E

Elev: 166

StdP: 99.35

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.2	-14.9	-20.9	0.6	-17.6	-17.9	0.8	-14.2	13.2	1.3	12.0	0.7	2.6	110	0.602

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.7	27.2	20.1	25.3	18.9	23.6	18.0	20.9	25.7	19.7	24.1	18.7	22.7	3.4	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.2	14.3	23.6	18.1	13.3	22.2	17.0	12.4	20.9	61.3	25.6	57.2	24.2	53.5	22.7	26.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.2	9.0	7.4	DB	-20.4	29.3	3.9	1.7	-23.2	30.6	-25.5	31.6	-27.7	32.5	-30.5	33.8	(4)
(5)			WB	-20.7	22.7	3.8	1.3	-23.4	23.6	-25.7	24.4	-27.8	25.1	-30.6	26.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	6.6	-4.0	-3.2	0.1	6.4	11.2	14.6	17.3	16.6	12.1	6.8	2.2	-1.6	(6)
(7)		DBStd	8.55	5.71	5.42	4.21	4.34	4.12	3.31	3.12	2.86	3.09	3.69	4.16	5.04	(7)
(8)		HDD10.0	1990	436	371	306	124	33	2	0	0	14	111	234	358	(8)
(9)		HDD18.3	4338	694	604	564	357	223	120	59	70	187	359	484	617	(9)
(10)		CDD10.0	748	0	0	0	17	71	141	226	204	78	11	0	0	(10)
(11)		CDD18.3	54	0	0	0	0	3	8	27	16	1	0	0	0	(11)
(12)		CDH23.3	426	0	0	0	2	24	72	210	114	4	0	0	0	(12)
(13)		CDH26.7	68	0	0	0	0	1	10	41	17	0	0	0	0	(13)
(14)	Wind	WSAvg	3.5	4.1	4.1	3.8	3.5	3.3	3.1	2.9	2.8	3.2	3.7	4.0	4.0	(14)
(15)	Precipitation	PrecAvg	799	68	51	47	36	51	71	81	90	71	84	76	72	(15)
(16)		PrecMax	1025	165	131	103	76	111	123	191	164	147	174	129	166	(16)
(17)		PrecMin	519	20	8	8	3	11	18	0	1	18	8	16	36	(17)
(18)		PrecStd	129	32	26	26	19	24	26	39	42	37	38	32	28	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.0	6.3	13.6	23.1	25.9	28.2	29.8	29.0	23.5	16.8	10.7	8.2	(19)
(20)			MCWB	6.1	4.7	9.2	14.6	18.6	20.4	21.2	21.1	17.7	13.5	9.6	7.5	(20)
(21)		2%	DB	5.1	4.9	9.9	19.4	23.5	25.4	27.7	26.1	20.9	14.5	9.3	6.8	(21)
(22)			MCWB	4.4	4.0	6.4	12.4	16.8	19.0	20.4	19.2	16.1	12.5	8.4	6.1	(22)
(23)		5%	DB	3.7	3.8	7.2	16.6	21.4	23.3	25.7	24.3	18.7	13.2	8.3	5.5	(23)
(24)			MCWB	3.1	3.1	5.0	10.7	15.4	17.5	19.6	18.4	15.0	11.7	7.6	4.9	(24)
(25)		10%	DB	2.4	2.8	5.2	14.0	19.0	21.2	23.7	22.5	17.1	12.0	7.4	4.4	(25)
(26)			MCWB	1.9	2.2	3.7	9.3	14.0	16.3	18.6	17.6	14.3	10.8	6.7	3.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.3	5.1	9.7	15.3	19.9	21.4	23.1	22.2	18.4	14.2	9.9	7.6	(27)
(28)			MDCB	6.9	5.6	13.0	21.6	23.9	26.4	27.7	26.5	22.1	15.5	10.5	7.9	(28)
(29)		2%	WB	4.5	4.0	7.1	13.0	17.6	19.7	21.3	20.4	16.7	12.9	8.6	6.2	(29)
(30)			MDCB	4.9	4.7	9.0	18.5	22.6	24.5	26.0	24.8	19.6	14.1	9.1	6.6	(30)
(31)		5%	WB	3.2	3.2	5.2	11.4	16.0	18.2	20.1	19.2	15.6	11.9	7.6	4.9	(31)
(32)			MDCB	3.6	3.7	6.8	15.7	20.3	22.1	24.3	23.2	18.1	12.9	8.2	5.4	(32)
(33)		10%	WB	2.0	2.3	3.9	9.7	14.4	16.9	18.9	18.1	14.6	10.9	6.8	3.8	(33)
(34)			MDCB	2.4	2.7	5.2	13.1	18.2	20.4	23.2	21.6	16.7	12.0	7.3	4.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.1	4.4	5.9	8.7	9.9	9.0	8.7	8.6	7.5	5.5	3.5	3.4	(35)
(36)			MCDBR	4.0	4.0	8.9	13.0	12.6	12.2	11.9	11.7	10.0	6.8	4.2	3.4	(36)
(37)			MCWBR	3.8	3.5	6.3	7.2	7.0	6.7	6.0	6.0	6.1	5.1	3.8	3.4	(37)
(38)		5% WB	MCDBR	3.6	3.9	7.9	11.9	11.3	11.0	10.9	10.3	8.7	6.0	4.0	3.4	(38)
(39)			MCWBR	3.5	3.6	6.0	7.0	6.9	6.6	6.1	6.0	5.8	4.8	3.8	3.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.293	0.323	0.355	0.394	0.383	0.378	0.411	0.405	0.369	0.348	0.331	0.293	(40)	
(41)		taud	2.208	2.212	2.244	2.227	2.314	2.359	2.288	2.301	2.382	2.403	2.282	2.208	(41)	
(42)		Ebn at Noon	610	733	803	822	858	867	826	804	786	708	560	514	(42)	
(43)		Edh at Noon	57	84	103	121	118	114	121	112	90	70	55	46	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.50	1.23	2.55	4.13	5.51	5.73	5.32	4.35	3.01	1.47	0.54	0.33	(44)	
(45)		RadStd	0.11	0.23	0.36	0.52	0.48	0.41	0.49	0.45	0.34	0.24	0.07	0.04	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.56	N/A	N/A	N/A	N/A	N/A	-195	-244	N/A	N/A	(46)
(47)	Regional (20 neighbors)	+0.39	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page