

SIAULIAI, Lithuania

WMO: 265240

Lat: 55.9422N

Lon: 23.3311E

Elev: 352

StdP: 14.51

Time Zone: 2.00 (EUE)

Period: 94-14

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-4.5	3.0	-9.1	3.4	-3.8	-2.2	4.9	4.5	16.6	35.7	15.5	34.0	1.9	20	0.536

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.5	82.5	68.2	79.0	66.2	76.0	64.4	70.2	78.9	67.9	76.3	66.0	73.8	5.7	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.1	101.1	75.1	64.8	93.1	72.2	62.9	86.9	70.2	34.4	78.3	32.4	76.0	30.9	73.7	77.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.4	12.6	11.4	DB -9.9	87.0	7.2	3.3	-15.1	89.4	-19.3	91.3	-23.4	93.2	-28.6	95.6		
(5)			WB -10.3	73.0	7.1	2.7	-15.4	75.0	-19.5	76.5	-23.5	78.0	-28.7	80.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	44.6	25.7	25.2	32.9	44.8	53.2	59.5	65.1	63.4	54.6	45.0	36.1	28.4		
	DBStd	16.08	10.77	11.31	7.95	7.94	7.01	5.58	5.46	5.08	5.82	6.71	7.76	9.52		
	HDD50	3517	754	695	532	198	44	2	0	0	24	182	416	670		
	HDD65	7583	1219	1115	996	608	372	181	66	91	313	621	866	1135		
	CDD50	1542	0	0	1	40	142	287	468	416	162	26	0	0		
	CDD65	135	0	0	0	0	5	17	69	43	1	0	0	0		
	CDH74	1103	0	0	0	6	50	154	575	307	11	0	0	0		
	CDH80	221	0	0	0	0	3	19	149	50	0	0	0	0		
	WSAvg	5.6	6.6	6.4	6.2	5.7	5.4	5.1	4.6	4.4	4.8	5.6	6.3	6.6		
	PrecAvg	23.4	1.3	1.1	1.3	1.4	1.9	2.5	3.0	2.8	2.2	2.2	2.1	1.7		
(15) Precipitation	PrecMax	31.3	2.4	1.8	3.1	3.9	6.7	5.7	5.7	6.4	5.0	7.2	4.4	2.8		
	PrecMin	15.7	0.3	0.2	0.2	0.2	0.4	0.2	0.1	0.2	0.3	0.2	0.6	0.5		
	PrecStd	3.8	0.6	0.4	0.7	0.9	1.1	1.2	1.5	1.5	0.9	1.4	0.8	0.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.2	44.6	57.9	74.0	79.3	83.0	88.7	85.0	75.6	63.9	52.2	47.3		
		MCWB	44.0	41.8	46.5	57.2	65.8	67.7	70.0	69.7	63.0	57.1	49.5	45.4		
	2%	DB	42.0	42.1	51.8	68.6	74.6	78.7	84.4	80.6	70.6	59.4	49.2	43.7		
		MCWB	40.2	39.8	44.0	54.2	61.1	65.6	69.5	66.0	60.4	54.9	47.1	42.3		
	5%	DB	39.2	40.2	46.7	63.5	70.8	75.0	80.2	77.4	67.0	56.7	47.2	41.6		
		MCWB	37.8	38.3	41.7	51.7	58.9	63.4	67.7	65.1	59.0	53.1	45.5	40.2		
	10%	DB	37.0	38.4	42.8	58.6	67.0	71.1	76.7	74.1	64.1	54.3	45.7	39.6		
		MCWB	35.8	36.9	39.3	49.0	56.7	61.0	65.9	63.5	57.8	51.5	44.2	38.3		
	0.4%	WB	44.4	42.3	48.1	59.9	67.5	70.0	73.8	72.3	64.7	58.2	50.0	45.9		
		MCDB	46.1	43.8	55.9	71.2	77.1	79.7	83.8	81.7	72.0	61.7	51.8	47.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	40.4	40.3	44.9	55.4	63.1	66.7	71.3	68.8	62.0	55.7	47.4	42.5		
		MCDB	41.7	41.7	50.7	64.9	71.2	76.0	80.6	76.6	67.8	58.4	48.8	43.4		
	5%	WB	37.9	38.6	42.2	52.7	60.5	64.6	69.1	66.7	60.0	53.7	45.8	40.4		
		MCDB	39.0	39.9	46.2	61.9	68.4	72.6	77.5	74.3	65.6	56.3	47.0	41.5		
	10%	WB	35.9	36.9	39.6	50.0	57.9	62.3	66.9	64.8	58.3	51.8	44.4	38.4		
		MCDB	36.8	38.3	42.5	56.8	65.5	69.4	74.8	72.1	63.0	54.0	45.7	39.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.4	9.2	11.8	16.2	17.9	16.0	16.5	16.4	13.8	10.3	6.5	6.4		
		MCDBR	7.0	7.3	17.5	23.8	23.2	21.9	22.3	21.8	18.3	13.0	7.7	5.9		
		MCWBR	6.7	6.2	11.1	11.6	12.0	10.9	10.0	9.6	10.0	8.6	6.8	5.6		
		MCDBR	6.8	6.6	16.1	21.6	20.4	18.9	19.6	18.9	15.7	11.5	7.3	5.9		
	5% WB	MCWBR	6.7	6.3	10.8	11.2	11.6	10.6	10.2	9.8	9.5	8.2	6.7	5.7		
(40) Clear-Sky Solar Irradiance	taub		0.291	0.323	0.355	0.394	0.384	0.377	0.411	0.406	0.370	0.348	0.330	0.291		
	taud		2.198	2.188	2.227	2.228	2.311	2.357	2.285	2.299	2.381	2.401	2.274	2.202		
	Ebn at Noon		191	230	253	260	272	275	261	254	248	223	175	160		
	Edh at Noon		18	27	33	38	37	36	38	36	29	22	17	14		
(44) All-Sky Solar Radiation	RadAvg		162	393	809	1286	1724	1790	1677	1363	937	460	166	104		
	RadStd		36	78	126	168	151	131	148	140	105	76	23	12		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	+1.94	N/A	N/A	N/A	N/A	
(47)	Regional (24 neighbors)	+0.77	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page