

SIAULIAI, Lithuania

WMO: 265240

Lat: 55.9422N

Lon: 23.3311E

Elev: 107

StdP: 100.04

Time Zone: 2.00 (EUE)

Period: 94-14

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-20.3	-16.1	-22.8	0.5	-19.9	-19.0	0.7	-15.3	7.4	2.0	6.9	1.1	0.9	20	0.536

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.2	28.1	20.1	26.1	19.0	24.5	18.0	21.2	26.0	19.9	24.6	18.9	23.2	2.5	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.5	14.4	23.9	18.2	13.3	22.3	17.2	12.4	21.2	62.0	25.7	57.6	24.4	54.0	23.2	25.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.4	5.6	5.1	-23.3	30.6	4.0	1.8	-26.2	31.9	-28.5	33.0	-30.8	34.0	-33.7	35.3		
(5)			-23.5	22.8	3.9	1.5	-26.3	23.9	-28.6	24.7	-30.8	25.6	-33.7	26.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.0	-3.5	-3.8	0.5	7.1	11.8	15.3	18.4	17.5	12.6	7.2	2.3	-2.0		
	DBStd	8.94	5.98	6.28	4.41	4.41	3.90	3.10	3.03	2.82	3.23	3.73	4.31	5.29		
	HDD10.0	1954	419	386	296	110	24	1	0	0	13	101	231	372		
	HDD18.3	4213	677	619	553	338	207	101	37	51	174	345	481	631		
	CDD10.0	857	0	0	1	22	79	159	260	231	90	14	0	0		
	CDD18.3	75	0	0	0	0	3	9	38	24	1	0	0	0		
	CDH23.3	613	0	0	0	3	28	86	319	171	6	0	0	0		
	CDH26.7	123	0	0	0	0	2	11	83	28	0	0	0	0		
(14) Wind	WSAvg	2.5	2.9	2.9	2.8	2.6	2.4	2.3	2.1	2.0	2.1	2.5	2.8	2.9		
(15) Precipitation	PrecAvg	595	34	27	33	36	47	64	75	70	55	55	53	43		
	PrecMax	795	62	46	78	99	169	146	145	162	126	183	111	70		
	PrecMin	398	8	6	4	4	10	6	2	5	8	4	16	12		
	PrecStd	96	15	11	18	23	29	30	39	38	23	36	20	15		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.9	7.0	14.4	23.3	26.3	28.3	31.5	29.5	24.2	17.7	11.2	8.5		
		MCWB	6.7	5.4	8.1	14.0	18.8	19.9	21.1	21.0	17.2	13.9	9.7	7.4		
	2%	DB	5.5	5.6	11.0	20.3	23.6	26.0	29.1	27.0	21.5	15.2	9.5	6.5		
		MCWB	4.5	4.3	6.7	12.3	16.2	18.7	20.8	18.9	15.8	12.7	8.4	5.7		
	5%	DB	4.0	4.6	8.2	17.5	21.6	23.9	26.8	25.2	19.4	13.7	8.5	5.3		
		MCWB	3.2	3.5	5.4	10.9	14.9	17.4	19.8	18.4	15.0	11.7	7.5	4.6		
	10%	DB	2.8	3.5	6.0	14.8	19.4	21.7	24.8	23.4	17.8	12.4	7.6	4.2		
		MCWB	2.1	2.7	4.0	9.4	13.7	16.1	18.8	17.5	14.3	10.8	6.8	3.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.9	5.7	9.0	15.5	19.7	21.1	23.2	22.4	18.2	14.6	10.0	7.7		
		MCDB	7.8	6.5	13.3	21.8	25.1	26.5	28.8	27.6	22.2	16.5	11.0	8.4		
	2%	WB	4.6	4.6	7.2	13.0	17.3	19.3	21.8	20.4	16.6	13.2	8.6	5.8		
		MCDB	5.4	5.4	10.4	18.3	21.8	24.5	27.0	24.8	19.9	14.7	9.3	6.4		
	5%	WB	3.3	3.7	5.7	11.5	15.8	18.1	20.6	19.3	15.6	12.1	7.7	4.7		
		MCDB	3.9	4.4	7.9	16.6	20.2	22.6	25.3	23.5	18.7	13.5	8.4	5.3		
	10%	WB	2.2	2.7	4.2	10.0	14.4	16.8	19.4	18.2	14.6	11.0	6.9	3.5		
		MCDB	2.7	3.5	5.8	13.8	18.6	20.8	23.8	22.3	17.2	12.2	7.6	4.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.1	5.1	6.5	9.0	9.9	8.9	9.2	9.1	7.7	5.7	3.6	3.5		
		MCDBR	3.9	4.1	9.7	13.2	12.9	12.2	12.4	12.1	10.2	7.2	4.3	3.3		
	5% WB	MCWBR	3.7	3.5	6.2	6.5	6.7	6.0	5.6	5.3	5.5	4.8	3.8	3.1		
		MCDWR	3.8	3.7	8.9	12.0	11.4	10.5	10.9	10.5	8.7	6.4	4.0	3.3		
(40) Clear-Sky Solar Irradiance	taub		0.291	0.323	0.355	0.394	0.384	0.377	0.411	0.406	0.370	0.348	0.330	0.291		
		taud	2.198	2.188	2.227	2.228	2.311	2.357	2.285	2.299	2.381	2.401	2.274	2.202		
	Edn at Noon		603	726	799	820	856	866	824	801	782	704	551	504		
		Edh at Noon	57	84	104	121	118	114	121	112	90	69	54	45		
(44) All-Sky Solar Radiation	RadAvg		0.51	1.24	2.55	4.05	5.43	5.64	5.29	4.30	2.96	1.45	0.52	0.33		
	RadStd		0.11	0.25	0.40	0.53	0.48	0.41	0.47	0.44	0.33	0.24	0.07	0.04		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only		N/A	N/A	N/A	N/A	N/A	+1.08	N/A	N/A	N/A	N/A
(47) Regional (24 neighbors)		+0.43	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page