

BIRZAI, Lithuania

WMO: 265310

Lat: 56.1931N

Lon: 24.7742E

Elev: 62

StdP: 100.59

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-19.6	-16.0	-22.0	0.5	-19.2	-18.7	0.7	-15.4	8.8	-0.3	8.1	-1.9	1.8	110	0.558

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.4	28.4	20.1	26.6	19.0	24.9	18.0	21.2	26.3	20.0	24.8	19.0	23.7	3.1	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.4	14.2	23.9	18.3	13.3	22.4	17.3	12.4	21.3	61.6	26.2	57.6	24.7	54.2	23.7	27.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.6	6.7	6.0	DB	-23.2	31.0	4.2	1.9	-26.2	32.4	-28.7	33.6	-31.0	34.6	-34.0	36.0	(4)
(5)			WB	-23.4	22.7	4.1	1.4	-26.4	23.8	-28.8	24.6	-31.1	25.4	-34.1	26.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.0	-4.0	-3.7	0.4	7.1	12.4	15.8	18.4	17.4	12.7	6.9	2.2	-1.8	(6)	
	DBStd	9.05	5.91	6.08	4.40	4.39	4.17	3.35	3.05	2.99	3.27	3.80	4.36	5.32	(7)	
	HDD10.0	1971	433	383	298	108	22	1	0	0	12	111	236	367	(8)	
	HDD18.3	4209	692	617	556	336	190	90	38	54	171	356	486	625	(9)	
	CDD10.0	887	0	0	0	22	96	176	259	229	92	13	0	0	(10)	
	CDD18.3	86	0	0	0	0	5	15	39	26	1	0	0	0	(11)	
	CDH23.3	728	0	0	0	3	46	132	326	209	12	0	0	0	(12)	
	CDH26.7	148	0	0	0	0	4	22	80	41	1	0	0	0	(13)	
(14) Wind	WSAvg	3.0	3.3	3.2	3.2	3.0	2.9	2.7	2.5	2.5	2.7	3.0	3.3	3.3	(14)	
(15) Precipitation	PrecAvg	660	46	41	37	37	54	74	80	69	52	64	54	50	(15)	
	PrecMax	878	103	65	70	70	111	133	195	133	105	117	96	73	(16)	
	PrecMin	504	16	17	8	7	12	16	4	9	9	14	2	31	(17)	
	PrecStd	93	19	14	17	19	25	28	44	35	24	26	22	11	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.2	6.7	14.2	23.6	27.0	29.1	31.4	30.3	25.2	17.7	11.2	8.9	(19)	
		MCWB	6.2	4.9	7.9	14.1	18.9	19.8	21.0	21.4	17.2	13.7	9.9	8.0	(20)	
	2%	DB	5.2	5.3	10.6	20.3	24.5	26.7	28.9	27.6	22.2	15.2	9.7	7.0	(21)	
		MCWB	4.3	4.0	6.7	11.9	16.7	19.0	20.6	19.3	16.1	12.7	8.6	6.0	(22)	
	5%	DB	3.6	4.2	7.9	17.5	22.5	24.7	26.9	25.7	20.0	13.6	8.6	5.6	(23)	
		MCWB	2.9	3.2	5.1	10.8	15.2	17.8	19.6	18.4	15.2	11.9	7.7	4.8	(24)	
	10%	DB	2.4	3.1	6.0	14.8	20.3	22.6	25.0	23.7	18.2	12.3	7.6	4.3	(25)	
		MCWB	1.8	2.3	4.0	9.5	14.1	16.6	18.7	17.5	14.5	10.7	6.8	3.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.5	5.3	8.9	14.7	20.0	21.7	22.8	22.6	18.3	14.5	10.2	8.2	(27)	
		MCDB	7.1	6.2	13.1	21.7	25.4	26.7	28.6	27.7	22.9	16.6	10.8	8.9	(28)	
	2%	WB	4.4	4.2	7.0	12.9	18.0	19.8	21.5	20.6	16.9	13.2	8.8	6.1	(29)	
		MCDB	5.0	5.0	10.0	18.7	22.5	24.9	26.9	25.3	20.3	14.7	9.5	6.8	(30)	
	5%	WB	2.9	3.3	5.5	11.5	16.2	18.6	20.4	19.4	15.8	12.0	7.8	4.9	(31)	
		MCDB	3.5	4.1	7.5	16.3	21.0	23.5	25.3	24.0	18.8	13.4	8.5	5.5	(32)	
	10%	WB	1.9	2.4	4.2	10.1	14.8	17.3	19.4	18.4	14.9	11.0	6.9	3.6	(33)	
		MCDB	2.4	3.0	5.8	13.9	18.9	21.5	23.8	22.6	17.7	12.2	7.5	4.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.1	5.1	6.5	9.2	10.2	9.3	9.4	9.7	8.2	5.9	3.6	3.5	(35)	
		MCDBR	3.7	4.2	9.4	13.5	13.1	12.3	12.7	12.8	11.2	7.3	4.4	3.5	(36)	
	5% WB	MCWBR	3.5	3.5	6.1	6.7	6.5	5.9	5.4	5.5	6.0	5.0	3.8	3.3	(37)	
		MCWBR	3.4	4.0	8.3	11.7	11.4	10.9	11.1	11.0	9.4	6.7	4.1	3.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.290	0.322	0.355	0.395	0.385	0.379	0.412	0.409	0.373	0.348	0.332	0.291	(40)	
		taud	2.175	2.162	2.203	2.231	2.320	2.366	2.294	2.299	2.379	2.399	2.258	2.189	(41)	
	Ebn at Noon		593	719	795	819	854	864	822	797	777	700	539	492	(42)	
		Edh at Noon	57	86	106	120	117	113	119	112	90	69	54	45	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.49	1.23	2.55	3.96	5.31	5.52	5.22	4.25	2.83	1.37	0.46	0.30	(44)	
	RadStd		0.12	0.25	0.42	0.49	0.50	0.48	0.47	0.41	0.31	0.23	0.07	0.05	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.43	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (28 neighbors)		+0.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page