

VERHNEDVINSK, Belarus

WMO: 265540

Lat: 55.8208N

Lon: 27.9400E

Elev: 434

StdP: 14.47

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.9	-0.7	-11.5	3.0	-6.7	-5.3	4.2	0.3	19.8	31.7	17.7	29.1	3.6	100	0.554

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.6	82.2	67.5	79.1	65.8	76.1	64.4	69.9	79.2	67.9	76.2	66.1	73.2	6.2	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.6	99.4	74.4	64.8	93.3	72.1	63.1	87.7	70.4	34.1	79.6	32.4	76.3	31.0	73.4	77.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
16.6	14.4	12.7	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-16.0	86.7	5.1	3.1	-19.7	88.9	-22.6	90.7	-25.5	92.5	-29.2	94.7
			-16.3	72.5	5.0	2.0	-20.0	73.9	-22.9	75.1	-25.8	76.3	-29.4	77.8
	</													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	43.5	22.8	23.2	31.5	44.3	53.6	60.5	64.9	62.3	53.4	43.1	34.2	26.9	(6)
(7)		DBStd	16.95	11.43	11.66	8.14	7.86	7.44	5.81	5.37	5.40	5.96	7.04	8.47	10.36	(7)
(8)		HDD50	3880	845	750	574	206	46	1	0	0	34	233	475	716	(8)
(9)		HDD65	7982	1310	1170	1039	621	361	160	69	118	349	679	925	1181	(9)
(10)		CDD50	1510	0	0	0	35	157	316	463	383	136	20	0	0	(10)
(11)		CDD65	133	0	0	0	0	7	24	67	35	0	0	0	0	(11)
(12)		CDH74	1090	0	0	0	2	65	179	536	292	16	0	0	0	(12)
(13)		CDH80	204	0	0	0	0	6	18	124	56	0	0	0	0	(13)
(14)	Wind	WSAvg	6.2	6.9	6.6	6.8	6.2	6.1	5.9	5.0	5.1	5.5	6.4	6.7	7.0	(14)
(15)	Precipitation	PrecAvg	24.2	1.3	1.1	1.3	1.4	2.3	2.7	3.1	2.7	2.2	2.1	2.1	1.7	(15)
(16)		PrecMax	33.1	2.8	2.8	2.4	4.0	5.2	5.6	7.6	5.9	5.9	4.1	4.8	3.1	(16)
(17)		PrecMin	17.6	0.4	0.2	0.2	0.1	0.4	0.9	0.4	0.2	0.6	0.3	0.7	0.3	(17)
(18)		PrecStd	3.7	0.6	0.5	0.6	1.0	1.1	1.3	1.8	1.4	1.2	1.1	0.9	0.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.0	43.3	56.0	73.3	80.7	82.7	88.2	86.2	76.5	64.7	52.9	47.2	(19)
MCWB			41.2	40.2	45.3	56.7	66.3	67.3	69.3	72.1	61.4	57.4	50.3	45.3	(20)	
2%		DB	39.4	39.9	49.7	68.0	75.0	79.2	83.7	80.7	70.5	58.9	49.2	43.6	(21)	
		MCWB	37.8	37.5	41.8	53.3	62.0	65.6	69.1	66.5	60.1	54.3	47.3	42.1	(22)	
5%		DB	37.2	37.8	45.2	62.8	71.4	75.8	79.9	77.0	66.8	55.7	46.6	40.8	(23)	
		MCWB	35.7	36.0	39.9	50.4	58.9	63.8	66.8	64.9	58.0	52.2	44.9	39.6	(24)	
10%		DB	35.1	35.9	41.9	58.3	67.6	72.0	76.5	73.5	63.4	53.1	44.4	38.2	(25)	
		MCWB	33.9	34.4	37.8	48.2	56.7	62.1	65.4	63.7	56.7	50.4	42.9	36.9	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.7	40.5	46.4	57.9	67.8	70.1	72.8	72.8	63.6	58.0	50.7	45.8	(27)
MCD B			42.5	42.5	53.9	70.4	77.6	79.0	83.1	83.5	71.1	62.8	52.0	47.1	(28)	
2%		WB	38.0	37.9	43.2	54.5	64.3	67.6	70.4	69.3	61.2	54.9	47.6	42.2	(29)	
		MCD B	39.1	39.3	47.7	64.6	73.1	76.3	80.6	77.2	67.4	57.9	48.9	43.1	(30)	
5%		WB	35.9	36.3	40.5	52.1	60.9	65.6	68.4	66.8	59.5	52.7	45.0	39.7	(31)	
		MCD B	36.9	37.5	44.3	60.6	68.9	73.1	77.3	73.4	64.8	55.0	46.3	40.8	(32)	
10%		WB	34.1	34.6	38.3	49.5	58.0	63.4	66.6	64.7	57.6	50.6	43.0	37.0	(33)	
		MCD B	35.0	35.8	41.4	56.8	65.8	69.7	74.0	71.2	62.2	52.9	44.2	38.1	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.0	9.7	11.9	16.3	17.3	15.6	16.6	16.9	15.2	10.3	6.7	6.7	(35)
MCDBR			6.3	7.2	16.2	24.5	23.0	21.6	22.2	23.1	20.8	14.2	8.9	6.5	(36)	
MCWBR			6.0	6.0	10.3	12.2	11.2	10.2	9.6	10.3	11.4	9.6	7.6	6.1	(37)	
5% WB		MCD BR	6.1	6.5	14.1	20.5	20.3	18.2	19.6	19.0	17.4	12.4	8.0	6.3	(38)	
		MCWBR	6.0	5.8	9.9	11.4	11.1	9.8	9.2	9.7	10.5	9.0	7.4	6.1	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.287	0.320	0.351	0.395	0.386	0.377	0.406	0.408	0.371	0.348	0.328	0.287	(40)	
taud		2.162	2.136	2.174	2.233	2.331	2.382	2.318	2.304	2.382	2.398	2.256	2.183	(41)		
Ebn at Noon		192	230	254	260	271	275	263	254	248	223	176	162	(42)		
Edh at Noon		19	28	35	38	37	36	37	36	29	22	17	15	(43)		
(44)	All-Sky Solar Radiation	RadAvg	170	436	871	1264	1660	1761	1657	1358	899	421	141	102	(44)	
(45)		RadStd	41	83	137	154	167	143	169	125	81	81	24	25	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)			
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page