

BELY, Russian FederationWMO: **265850**Lat: **55.833N**Lon: **32.933E**Elev: **729**StdP: **14.31**Time Zone: **3.00 (E03)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.3	-4.1	-14.9	2.5	-9.9	-9.0	3.5	-3.2	19.3	22.3	17.6	25.9	2.9	90	0.555

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.5	81.9	66.6	78.8	65.9	75.9	64.2	69.2	77.9	67.3	75.7	65.5	73.5	4.9	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.8	97.8	74.4	64.1	91.9	71.6	62.5	86.9	69.8	33.7	77.8	32.1	75.4	30.7	73.8	75.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
17.8	14.4	13.0	-18.6	85.7	4.8	3.0	-22.0	87.9	-24.8	89.7	-27.5	91.4	-31.0	93.6		
			-18.8	71.0	4.7	1.9	-22.3	72.4	-25.0	73.5	-27.7	74.6	-31.1	76.0		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	41.7	19.6	21.6	29.3	43.8	53.0	61.0	64.2	60.2	51.0	41.4	30.6	23.5	
	DBStd	17.93	11.00	11.72	8.28	9.42	8.80	6.70	5.54	5.54	6.75	7.61	9.79	11.40	
	HDD50	4437	941	796	643	235	69	3	0	0	69	279	582	820	
	HDD65	8626	1406	1216	1108	635	385	155	83	169	421	731	1032	1285	
	CDD50	1411	0	0	0	50	161	333	440	316	98	13	0	0	
	CDD65	126	0	0	0	0	12	36	58	20	0	0	0	0	
	CDH74	1027	0	0	0	4	100	278	462	171	12	0	0	0	
	CDH80	164	0	0	0	0	10	38	98	18	0	0	0	0	
Wind	WSAvg	5.5	6.2	6.5	6.4	5.2	5.1	4.4	4.1	4.1	4.7	6.2	6.5	6.6	
Precipitation	PrecAvg	25.4	1.7	1.4	1.3	1.2	2.4	3.0	3.4	2.8	2.8	2.3	1.9	1.6	
	PrecMax	32.5	2.6	2.5	2.5	2.0	4.0	6.9	7.4	5.2	4.8	5.6	4.0	2.5	
	PrecMin	17.8	0.5	0.5	0.4	0.4	0.9	0.6	0.6	0.0	1.4	0.3	0.0	0.7	
	PrecStd	4.7	0.5	0.5	0.6	0.6	0.9	1.6	2.1	1.3	1.1	1.3	1.0	0.4	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.7	40.4	54.7	73.8	81.3	83.8	87.1	82.6	75.5	67.5	51.3	45.5	
		MCWB	36.7	36.9	45.1	56.2	64.4	66.1	70.3	67.2	65.1	57.8	49.2	43.9	
	2%	DB	35.7	37.3	48.1	69.2	77.1	80.6	82.9	78.6	69.7	58.2	48.0	40.6	
		MCWB	34.4	34.4	39.6	54.5	62.3	64.8	68.4	65.9	60.0	52.6	46.0	39.2	
	5%	DB	34.1	35.6	43.3	64.9	72.3	77.2	79.1	75.2	65.3	54.5	45.8	37.6	
		MCWB	32.9	33.3	37.1	52.0	59.7	64.8	67.1	64.6	57.3	50.8	44.2	36.4	
	10%	DB	32.9	34.3	39.7	59.9	67.6	73.6	75.7	72.1	61.5	51.7	42.9	35.4	
		MCWB	31.8	32.5	35.4	50.0	57.3	62.8	64.8	62.9	55.3	48.8	41.4	34.1	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	37.2	37.5	45.8	58.2	66.6	69.6	72.9	70.1	66.0	58.0	49.8	44.2
			MCDB	37.5	39.8	53.1	71.1	77.3	79.8	83.4	78.5	71.2	66.8	50.8	45.5
2%		WB	34.8	35.1	40.9	54.9	64.0	67.5	70.4	67.4	61.4	54.0	46.6	39.2	
		MCDB	35.5	36.4	45.4	66.3	74.2	77.1	79.6	75.6	67.9	56.8	47.7	40.4	
5%		WB	33.2	33.9	38.2	52.8	61.5	65.6	68.1	65.7	58.5	51.3	44.1	36.6	
		MCDB	33.9	35.1	42.0	62.8	69.3	73.8	76.1	73.6	62.9	53.7	45.5	37.5	
10%		WB	32.0	32.8	35.9	50.8	58.8	64.0	66.1	63.7	56.3	49.2	41.6	34.3	
		MCDB	32.8	34.1	39.3	59.0	65.9	71.7	74.0	70.8	60.6	51.6	42.8	35.2	
Mean Daily Temperature Range	5% DB	MDBR	8.5	10.8	12.6	15.8	17.7	16.3	16.5	16.6	14.8	10.8	7.5	7.2	
		MCDBR	5.8	7.5	17.4	24.0	23.3	21.4	22.4	22.9	21.3	15.5	8.9	6.3	
		MCWBR	5.9	6.5	10.9	12.0	11.5	9.5	9.9	12.0	13.1	10.5	7.9	5.9	
	5% WB	MCDBR	5.6	6.4	14.0	21.3	21.3	18.8	19.2	21.4	18.5	13.0	8.5	6.1	
		MCWBR	5.9	6.0	9.7	11.5	11.9	9.4	9.6	12.6	12.6	9.5	7.9	5.8	
Clear-Sky Solar Irradiance	taub	0.285	0.318	0.340	0.398	0.387	0.368	0.397	0.411	0.363	0.344	0.320	0.282		
	taud	2.143	2.105	2.163	2.200	2.334	2.405	2.336	2.290	2.398	2.393	2.257	2.155		
	Ebn at Noon	192	230	258	259	271	278	266	253	251	225	179	161		
	Edh at Noon	19	29	35	39	37	35	36	36	28	22	17	15		
All-Sky Solar Radiation	RadAvg	182	450	930	1267	1643	1732	1691	1347	879	404	149	109		
	RadStd	39	66	93	126	140	166	167	158	92	81	29	32		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	+1.08	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+148	N/A

Nomenclature: See separate page