

LYNTUPY, Belarus

WMO: 266450

Lat: 55.0489N

Lon: 26.3069E

Elev: 694

StdP: 14.33

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.8	0.5	-9.9	3.3	-5.2	-3.7	4.6	1.1	16.2	33.8	14.5	32.2	2.2	30	0.543

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.6	82.4	66.3	79.1	65.0	76.0	63.3	69.0	78.3	67.1	75.6	65.2	73.0	6.0	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.8	97.6	73.0	63.9	91.3	70.7	62.2	85.9	68.9	33.5	78.4	31.9	75.3	30.5	73.0	74.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
13.8	12.0	10.5	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-14.5	87.5	6.8	3.6	-19.3	90.1	-23.3	92.2	-27.1	94.2	-32.0	96.8
			-14.8	71.3	6.7	1.9	-19.6	72.7	-23.6	73.8	-27.3	74.9	-32.2	76.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	43.3	23.0	24.1	31.4	43.9	53.1	59.4	64.1	61.8	52.8	42.8	34.5	26.9
	DBStd	16.52	10.91	11.02	8.47	7.91	7.61	6.07	5.60	5.62	6.08	7.15	8.34	10.00
	HDD50	3875	836	726	578	214	53	2	0	0	42	242	467	715
	HDD65	8056	1301	1146	1042	633	375	188	87	133	368	687	916	1180
	CDD50	1413	0	0	1	31	150	286	436	366	124	19	0	0
	CDD65	121	0	0	0	0	7	21	58	34	1	0	0	0
	CDH74	1112	0	0	0	6	74	171	542	301	18	0	0	0
	CDH80	219	0	0	0	0	8	19	134	58	0	0	0	0
Wind	WSAvg	4.8	5.7	5.4	5.4	4.8	4.5	4.4	3.7	3.7	4.0	5.1	5.5	5.7
Precipitation	PrecAvg	27.4	1.9	1.7	1.7	1.6	2.5	2.9	3.1	2.9	2.4	2.4	2.0	2.1
	PrecMax	35.3	3.9	2.8	4.0	3.3	5.9	5.6	6.2	6.9	5.6	4.4	3.5	3.3
	PrecMin	20.7	0.2	0.8	0.5	0.4	0.5	1.1	0.1	0.3	0.6	0.4	0.2	0.8
	PrecStd	3.8	0.7	0.5	0.7	0.8	1.3	1.2	1.8	1.8	1.2	1.1	0.8	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.0	43.7	56.9	74.0	81.1	82.7	88.6	85.7	76.9	64.7	52.7	46.3
		MCWB	42.1	40.2	46.4	56.8	64.5	65.5	68.1	68.0	60.4	56.5	49.8	44.9
	2%	DB	39.7	40.4	50.8	67.7	75.5	79.1	83.9	80.8	70.8	59.1	49.3	43.1
		MCWB	38.5	38.0	42.9	52.8	60.7	64.7	68.2	65.5	59.6	54.4	47.3	41.8
	5%	DB	37.2	38.2	46.0	62.7	71.6	75.4	79.9	77.1	66.6	55.8	46.7	40.6
		MCWB	36.0	36.5	41.0	50.3	58.1	62.9	65.9	63.9	57.5	52.5	45.1	39.6
	10%	DB	35.0	36.2	42.2	58.4	67.9	71.5	76.4	73.6	63.3	52.9	44.6	37.9
		MCWB	34.2	34.8	38.6	48.3	56.3	61.1	64.7	62.8	56.4	50.4	43.3	36.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.2	41.2	48.1	58.0	66.4	69.3	72.5	70.9	63.3	57.9	50.5	45.3
		MCDB	43.4	43.1	53.3	70.9	77.6	78.1	82.7	82.8	71.3	61.8	51.6	46.0
	2%	WB	38.6	38.5	44.2	54.2	63.0	66.5	69.7	68.6	61.0	55.3	47.6	42.0
		MCDB	39.4	39.8	49.1	64.6	72.4	75.5	79.2	77.2	67.4	58.6	49.1	42.7
	5%	WB	36.2	36.7	41.5	51.8	60.2	64.6	67.6	66.1	59.0	52.8	45.3	39.6
		MCDB	37.0	38.0	45.4	59.9	68.8	71.7	76.6	72.6	64.4	55.1	46.5	40.6
	10%	WB	34.2	34.9	39.1	49.6	57.7	62.5	65.9	64.0	57.3	50.8	43.4	36.9
		MCDB	34.8	36.0	42.0	57.1	65.6	69.4	74.2	70.7	62.2	52.9	44.4	37.8
Mean Daily Temperature Range	5% DB	MDBR	7.6	9.5	12.5	17.5	18.5	16.7	17.6	17.9	15.9	10.4	6.6	6.6
		MCDBR	6.2	8.1	17.5	25.8	24.7	22.8	24.1	24.2	21.9	15.0	8.3	6.4
		MCWBR	6.1	6.6	11.5	13.0	11.7	10.5	10.0	10.2	12.2	10.2	6.9	6.2
	5% WB	MCDBR	6.2	7.4	15.0	21.6	20.7	18.4	20.3	18.4	18.4	12.8	7.7	6.5
		MCWBR	6.2	6.5	10.6	11.7	11.0	9.6	9.8	8.8	11.5	9.4	6.9	6.5
Clear-Sky Solar Irradiance	taub	0.284	0.317	0.351	0.398	0.387	0.377	0.409	0.407	0.370	0.348	0.327	0.285	
	taud	2.178	2.145	2.188	2.224	2.327	2.382	2.308	2.307	2.383	2.415	2.281	2.200	
	Ebn at Noon	201	235	256	261	272	276	263	256	250	227	184	172	
	Edh at Noon	19	29	35	39	37	36	38	36	29	22	18	15	
All-Sky Solar Radiation	RadAvg	185	446	871	1283	1656	1757	1639	1378	929	448	154	112	
	RadStd	40	83	138	150	166	149	167	125	84	89	25	26	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (15 neighbors)	+0.77	N/A	N/A	N/A	N/A	+0.99	N/A	-283	N/A	N/A	

Nomenclature: See separate page